

LIBRARY

g1

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM
AND IMPACT ANALYSIS OF ITS INTEGRATION
INTO LIBYAN POWER GRID

A THESIS SUBMITTED TO THE GRADUATE
SCHOOL OF APPLIED SCIENCES
OF
NEAR EAST UNIVERSITY


By
SAND MUSTAFA AL-REFAI

In Partial Fulfilment of the Requirements for
The Degree of Master of Science

III

Electrical and Electronic
Engineering


NICOSIA, 2016



SAND MUSTAFA AL REFAI: Design of a Large Scale Solar~.Y System and
Impact Analysis of Its Integration into Libyan Powe ~:jj,d e\}\-
~Er=t(O~ ~~

Approval of Director of Graduate School of

Applied Sciences



Prof. Dr. İlkay SALİHOĞLU

We certify this thesis is satisfactory for the award of the degree of Masters of
Science in Electrical and Electronic Engineering

Examining Committee in Charge:

AA~O....4~L(.

Assoc. Prof. Dr. Timur Aydemir



Assoc. Prof. Dr. Murat Fahrioglu

Electrical & Electronic
Engineering Department, NEU

umar

Dr. Umar Özgünalp

Electrical & Electronic
Engineering Department, METU

,A1\0-y~
Assoc. Prof. Dr. Timur Aydemir

Electrical & Electronic
Engineering Department, NEU

Electrical & Electronic
Engineering Department, NEU

I hereby declare that all information in this document has been obtained and presented in accordance with academic rules and ethical conduct. I also declare that, as required by these rules and conduct, I have fully cited and referenced all material and results that are not original to this work.

Name, Last name: SAND MUSTAFA AL-REF AI

Signature: *P, -ll----*

Date: 31 / ٢٠١٦

ACKNOWLEDGEMENTS

I would like to express my sincere appreciation and thanks to my supervisor, Assoc. Prof. Dr. M. Timur Aydemir , for his guidance and mentorship during my graduate studies. His impressive knowledge and creative thinking have been source of inspiration throughout this work.

My deepest gratitude goes to my parents, my wife, my brothers, sisters, and my son, to whom I am most indebted. I thank them for constant love, prayers, patience and support while I was studying abroad. I know I can never come close to returning their favor upon me.

A special thanks to my beloved Dad for his sacrifices, never-ending support and encouragement during my study. I would like to thank him for being a constant source of inspiration and motivation for me. Without him I would be no-where near what I have become today.

I will always be thankful to my friends and colleagues for their unlimited support. I extend my thanks to all the Libyan community that gave me a second family away from home.

To my parents and family....

ABSTRACT

Electrical energy is very important for sustainability and quality of life on this planet. Solar photovoltaic (PV) is one of the most adequate technologies used to convert the energy of the sun to electrical energy. Suitable exploitation of solar energy implies important diminution of the emissions of greenhouse gases.

In Libya, due to environmental, economic and development perspectives the Renewable Energy Authority of Libya (REA OL) is planning to implement a grid-connected 14 MW photovoltaic (PV) power plant near the Houn city in the Jufra District in Libya. The implementation of such large scale solar project may affect the normal parameters of the existing power station. These parameters are mainly voltage control, stability, protection equipment, and harmonic distortion levels. Therefore, this thesis develops a study of the design of PV system to be implemented in Houn substation 220 kV. The study aims to find the optimal parameters of the PV system such that it can function correctly. In addition, it investigates the impact of integrating PV directly with the existing grid. Different analysis tools will be used to perform load flow analysis to ascertain the effect on the PV to the grid. Analysis of the voltage variations and voltage stability after the integration of the PV system will also be assessed. Harmonic distortion analysis of the system is also going to be experimented after the connection of the PV plant to ensure the conformity of the resulting system with the international power quality standards.

In order to prove the design validity of the proposed system, models and simulations in MATLAB/SIMULINK and ETAP program will be established for a practical distribution grid. Real loads and solar energy data will be used in the simulation models for more realistic design. The results obtained from the analysis will be presented, tabulated, and discussed throughout this work.

Keywords: Solar energy; photovoltaic (PV); Houn city; Houn substation 220kV; MATLAB/Simulink; ETAP

ÖZET

Elektrik enerjisi gezegenimizdeki ya amın sürdürülebilirli i ve kalitesi için çok önemlidir. Güne enerjisini elektrik enerjisine dönü türmek için kullanılan en uygun teknolojilerden biri fotovoltaik panellerdir. Güne enerjisinden uygun biçimde yararlanarak sera etkisi yapan gazların yayımı azaltılabilir.

Libya Yenilenebilir Enerji Kurumu (REAOL) çevresel, ekonomik ve gelim perspektifleri ile Jufra bölgesinin Haun ehri yakınlarında ebeke balantılı 14 MW gücünde fotovoltaik enerji tesisinin kurulumunu planlamaktadır. Bu ölçekte bir güne enerjisi sisteminin kurulumu, mevcut enerji santralinin normal parametrelerini etkileyebilir. Bu parametrelerinบาลicuları gerilim kontrolü, kararlılık, koruma cihazları ve harmonik bozunum seviyeleridir. Bu tezde 220 kV gerilimli Haun alt merkezinde kurulacak PV sistemin tasarımına yönelik bir çalışma gerçekle tirilmektedir. Çalışmanın amacı, PV sisteminin levini doğrudan biçimde yerine getirebilmek için gerekli optimum parametrelerin bulunmasıdır. Ayrıca, PV sisteminin mevcut ebekeye doğrudan bağlanmasıının etkileri incelenmektedir; PV sisteminin ebekeye etkisini de erlendirmek amacıyla yük akı analizini yapmak için farklı analiz araçları kullanılmaktadır. PV sisteminin entegrasyonununบาลatısından sonra gerilimdeki değişimlerin ve gerilim kararlılığının analizi de gerçekle tirilmektedir. Sistemin uluslararası güç kalitesi standartlarına uygun davranışını görmek için harmonik bozunum analizi de yapılmaktadır.

Önerilen sistemin tasarımının doğruluunu göstermek için gerçek sistemin ve daima ebekesinin MATLAB/SIMULINK ve ETAP programları ile modellemesi ve benzetimi gerçekle tirilmişdir. Daha gerçekçi bir tasarım için gerçek yük ve güne enerjisi verileri kullanılmıştır. Çalışmada, analizlerden elde edilen veriler sunulmakta ve tartılmaktadır.

Analitik Kelimeler: Güne enerjisi; Photovoltaik (PV) enerji; Haun ehri; Haun 220 kV altmerkezi; MATLAB/Simulink; ETAP

TABLE OF CONTENTS

ACKNOWLEDGEMENTS	ii
ABSTRACT	iv
ÖZET	v
TABLE OF CONTENTS	vi.
LIST OF ABBREVIATIONS	xiii

CHAPTER 1: INTRODUCTION

1.1 Introduction	1
1.2 Aim of the Thesis	5
1.3 Overview of the Thesis.....	6

CHAPTER 2: LITERATURE REVIEW

2.1 Introduction	7
2.2 Literature Review	7

CHAPTER 3: DISTRIBUTED GENERATION SYSTEMS

3.1 Introduction	9
3.2 Electric Power Networks vs. Distributed Generation	9
3.2.1 History of distributed generation.....	11
3.2.2 Types of distributed generation technologies.....	13
3.2.2.1 Gas turbines.....	13
3.2.2.2 Micro turbines	13
3.2.2.3 Engines.....	13
3.2.2.4 Fuel'cells.....	14
3.2.2.5 Wind turbines	14
3.2.2.6 Photovoltaic solar cell	15
3.3 Photovoltaic Systems	15
3.3.1 Advantages and drawbacks of solar energy	16

3.4 Energy Potential in Libya	17
3.4.1 Photovoltaic applications in Libya	20
3.4.1.1 PV system for Libyan microwave communication networks	20
3.4.1.2 Solar energy for cathodic protection	21
3.4.1.3 Rural electrification with PV systems	21
3.4.1.4 PV systems for water pumping	22
3.5 Methodology of the Work	23
3.6 Modelling and Analysis Software	24
3.6.1 MATLAB / SIMULINK (version 7.8.0.347 (R2009a)}.....	24
3.6.2 ETAP (version 12.6.0H).....	24

CHAPTER 4: DESIGN AND SIMULATION OF GRID CONNECTED PV SYSTEM FOR LIBYAN NATIONAL GRID

4.1 Introduction	25
4.2 Design Procedure of the PV Station.....	25
4.2.1 Design and selection of grid tied inverter	26
4.2.1.1 Design of the central inverter.....	28
4.2.2 Layout of grid connected PV system with the central inverters.....	32
4.2.3 Cable sizing	33
4.2.3.1 Sizing cables between PV modules.....	34
4.2.3.2 Sizing of cable from PV array bus-bar to inverter	35
4.2.3.3 Sizing of cable from inverter to main junction	35
4.2.4 Sizing of circuit breakers.....	36
4.2.4.1 Sizing of circuit protection between PV array and inverter	36
4.2.4.2 Sizing of circuit protection on every phase output of inverter.....	37
4.2.5 Synchronization with the system.....	37
4.3 PV Modelling Using SIMULINK.....	38
4.3.1 Electrical circuit models of PV modules.....	38
4.3.2 Simulink modelling for PV module	41
4.3.3 PV Simulation results and discussions.....	43

CHAPTER 5: POWER SYSTEM STUDIES FOR PV INTEGRATION

5.1 Introduction	45
5.2 Load Flow Study and Analysis Using ETAP	45
5.2.1 Load flow simulation using ETAP	46
5.3 Short Circuit Study and Analysis Using ETAP	48
5.3.1 Short circuit simulation using ETAP.....	48
5.4 Harmonics Study and Analysis Using ETAP	49
5.5 Transient Stability Study and Analysis Using ETAP	50

CHAPTER 6: RESULTS ANALYSIS OF POWER SYSTEM STUDIES

6.1 Introduction	51
6.2 Load Flow Analysis	51
6.3 Short Circuit Analysis	51
6.4 Harmonics Analysis	52
6.5 Transient Stability Analysis	56

CHAPTER 7: CONCLUSION AND FUTURE WORK

7.1 Conclusion	58
7.2 Future Work	59

REFERENCES 60

APPENDICES	64
Appendix 1: Houn Substation Loads	65
Appendix 2: Module Datasheet	66
Appendix 3: ABB Central Inverter	67
Appendix 4: Load Flow Analysis Without PV.....	68
Appendix 5: Load Flow AnalysisWith PV.....	82

Appendix 6: Short Circuit Analysis Without PV	100
Appendix 7: Short Circuit Analysis With PV	114
Appendix 8: Harmonics Analysis Without PV	131
Appendix 9: Harmonic Analysis With PV	153
Appendix 10: Harmonic Analysis With Filters and No PV Connection	186
Appendix 11: Harmonic Analysis With Filters and PV	208
Appendix 12: Transient Stability Analysis Without PV	243
Appendix 13: Transient Stability Analysis With PV	265

LIST OF FIGURES

Figure 1.1: General power system topology	2
Figure 1.2: The location of the proposed project activity near the town of Houn, Jufra	4
Figure 1.3: Schematic diagram of the connection of the solar station	5
Figure 3.1: Structure of the electric power grid	10
Figure 3.2: A power system with distributed generation	11
Figure 3.3: Solar map in Libya	18
Figure 3.4: Load growth in Libya 2003-2012	19
Figure 3.5: Electricity production growth in Libya between 2003 and 2012	19
Figure 3.6: PV and diesel stations in the communication network	20
Figure 3.7: Flow chart of the station design and analysis process	24
Figure 4.1: (a)- String inverter a vs. (b)- central inverter	28
Figure 4.2: The array configuration of the central inverter	31
Figure 4.3: General structureof the arrays with the inverters	32
Figure 4.4: Wiring diagram of connection of inverters output to ma~n combiner box	33
Figure 4.5: Solar cell's model using single diode	38
Figure 4.6: Solar cell model using single diode with R_s and R_p	39
Figure 4.7: Block diagram of the model based upon the equations of PV model.;	41
Figure 4.8: Masked PV module in Simulink.....	42
Figure 4.9: The final model of PV system	42
Figure 4.10: Simulink model of solar panel (160 strings) V-I characteristic curves	43
Figure 4.11: Simulink model of solar panel (160 strings) P~V characteristic curves	43
Figure 4.12: Simulink model of solar panel (160 strings) V-I characteristic curves	44
Figure 4.13: Simulink model of solar panel (160 strings) P-V characteristic curves	44
Figure 5.1: Electrical power system study methodology flow chart.....	45
Figure 5.2: Load flow simulation with PV disconnected.....	47
Figure 5.3: Load flow simulation with PV connected	47
Figure 5.4: Short circuit simulation with PV disconnected	48
Figure 5.5: Short circuit simulation with PV connected	49
Figure 6.1: Voltage waveform at bus 1 with PV disconnected.....	53
Figure 6.2: Analysis results of harmonic with PV connected.....	53
Figure 6.3: Waveform and spectrum ofbus1 voltage after using PV plant.....	54

- Figure 6.4:** Harmonic study with filters and PV connection..... 55
Figure 6.5: Bus 1 voltage waveform and spectrum with filters and PV connection..... 55
Figure 6.6: Percentage of bus nominal (kV) without PV connection 57
Figure 6.7: Percentage of bus nominal (kV) with PV connection 57

LIST OF TABLES

Table 1.1: Technical specifications of PV modules to be used in Houn project.....	4
Table 3.1: The total installed PV capacity in Libya.....	23
Table 4.1: Basic features of the discussed PV modules	26
Table 4.2: Features of the ABB 1 MW central inverter used.....	29
Table 4.3: Cable sizing for the PV system.....	37

LIST OF ABBREVIATIONS

AC	Alternative Current
CB	Circuit Breaker
CHP	Combined Heat and Power
CP	Cathodic Protection
CPV	Concentrated Photovoltaic
CSA	Cross Sectional Area
CSES	Center of Solar Energy Studies
DC	Direct Current
DG	Distributed Generation
EIA	Energy Information Administration
ETAP	Electrical Transient Analyzer Program
FACTS	Flexible Alternative Current Transmission Systems
FC	Fuel Cell
GECOL	General Electrical Company of Libya
MATLAB	Matrix Laboratory
MPPT	Maximum Power Point Tracking
PCC	Point of Common Coupling
PU	Per Unit
PV	Photovoltaic
REAOL	Renewable Energy Authority of Libya
SCADA	Supervisory Control and Data Acquisition
STC	Standard Test Conditions
THD	Total Harmonic Distortion
UPS	Uninterruptible Power Supplies
VTs	Voltage Transformers

CHAPTER I

INTRODUCTION

This work is an introduction Of the Photovoltaic (PV) solar energy in the Libyan national electrical network. It represents a study of the implementation of 14 MW solar power station into Houn sub-station in Libya.

1.1 Introduction

Electrical energy is one of the most central human needs. Life without electrical energy is not imaginable. Nowadays Libya, similar to the other countries of the Middle East, uses oil and natural gas to produce its electrical energy needs. However, as these types of non-renewable energy sources will exhaust one day, it is very important to find alternative electrical energy sources like wind, sea waves, and solar energy. One of the great wealth that Libya has is the incredible distribution and amount of solar energy incident. Therefore, the significance of the investment in this source for the production of electrical energy by using the high efficiency photovoltaic generators becomes evident.

Normally power systems meet load growth demands through installation of centralized large generation plants, transmission lines and substations as well as distribution infrastructure. Figure 1.1 shows the traditional power delivery structure, from centralized generation to long distance transmission distribution. The generation station generates electricity at lower voltage level, generally 11 kV. This voltage is stepped up through a generation step up station. Stepped up voltage at the level of 220 kV or 400 kV is transmitted for long distances until the destination consumption areas. This power is then stepped down to different distribution levels according to consumers' needs. Solar generation is generally a small source of electric power generation ranging in size from less than a kW to tens of MW. PV sources are not generally part of the central power generation and are more suited to be installed near to the load, as shown, in the green distribution area in Figure 1.1.

Photovoltaic systems are widely used in different applications, from small cells in calculators that consume small amount of power to large scale PV plants that produce power in the range of many MW. Although there is a broad variety of PV applications, the main applications for PV systems are in the power generation on-board craft and in

standalone, systems in rural areas. In the last decades an important revolution in the use of grid-connected solar generators has been witnessed. The newly developed technologies encouraged consumers to start shifting toward the use of distributed energy resources like PV systems. Prices and initial installation costs of the PV systems have noticeably been decreased in the last 10 years especially with the exclusion of back-up batteries.




Figure 1.1: General power system topology (Condon, 2004)

Photovoltaic energy is one of the cleanest sources of renewable energy. The recent observations of the climatic alterations have encouraged the humanity for more investigation in the renewable resources of energy like solar. Although the technology was very costly in its beginnings, it has spread and has become very familiar and most used especially with the introduction of programs to encourage people to investigate in this technology. The use of distributed resources and especially PV systems in connection with power systems has many advantages such as (Steffel, et al., 2012):

- Voltage profile improvement.
- Voltage stability improvement for the whole system.
- Reactive power flow reduction.
- Power loss reduction.
- Pollution reduction.
- Maintenance cost reduction.

However, the use of individual solar applications or large scale PV generators can affect power systems and cause serious problems that need to be taken in consideration. For that reason, the penetration of distributed generation systems in the power systems has become one of the hottest topics of electrical power engineering. The variable nature of PV sources may cause serious power quality issues in the distribution systems. Such problems must be studied and mentioned preliminary to the installation of distributed generation system to avoid the failure of the systems. These problems or disadvantages can be summarized in the next few points (Coster et al., 2010; Steffel et al., 2012):

- Injection of harmonics due to the use of power inverters.
- The interruption of solar generation during night.
- The challenges of protection because of the bidirectional powerflow.
- Over voltage of the systems.

In this work, the use of solar energy power station with a total capacity of 14 MW in the Libyan distribution station of Haun is studied. The study will include the effect of the solar power station on the stability of the distribution station. It will include the analysis of load flow, short circuit faults, system stability, and harmonics of the system after the installation of the solar station. The project was proposed by the Renewable Energy Authority of Libya (REAOL) to build a photovoltaic (PV) power plant. The power rating of this first grid-connected plant of Libya which will be near the city of Haun in the Jufra District is 14 MW. The project is expected to produce an annual net electricity of approximately 23,140 MWh. High technology PV modules, power electronic systems, transformers and protection devices will be employed in this plant. Measurement and communication equipment will also be used to ensure reliability and surveillance of the system. The geographical location of the proposed project activity is as shown in Figure 1.2. The town of Haun situates at the latitude of $29^{\circ} 08' 52''$ N, and longitude of $16^{\circ} 00' 57''$ E, at a distance of about 250 km from the coastal line and 700 km from the capital city of Libya. The total available area for the project is approximately 10 hectare. The plant is planned to be connected to the distribution substation of 66/11 kV near Haun station of 220 kV as explained in Appendix 1. The specifications of the solar panels that must be used as sited by the REAOL are shown in Table 1.1. The substation has 2 step down transformers 66/11 kV of 20 MVA each. The connection between the solar field and the 11 kV bus bar will be established through 7 step-up transformers of 3 MVA each. The voltage rating of these

transformers is 0.4/11 kV and situated 100 m away from the field (UNFCCC, 2012).

Figure 1.3 presents the scijematic diagram of the connection between the solar system and the distribution grid through step-up transformers.




Figure 1.2: The location of the proposed project activity near the town of Houn, Jufra

Table 1.1: Technical specifications of PV modules to be used in Houn project

Parameter	Value
Cell type	Crystalline PV module
Power	Different power ratings: 230- 245 Wp
Number of modules	- 51;140 - 60,870
Module efficiency	14.1 - 15.1 %
Maximum rated current series	15 A
Power tolerance	+/-3 %
Maximum power voltage	29.4-30.7 V
Plant load factor	18.87 %




Figure 1.3: Schematic diagram of the connection of the solar station

1.2 Aim of the Thesis

Voltage control and stability are very critical for safe and reliable operation of power systems. They need to be taken in consideration during the generation, transmission and distribution levels of electric power. Voltage control for traditional power systems is well established. However, voltage control for distributed power systems is a rather new concept. Several researchers have been proposing new control algorithms to overcome the problems related to voltage regulation and stability so that renewable energy plants can be safely connected to national grids.

Libya is a country rich in solar energy and needs new power plants. Therefore it is expected that new solar energy projects will be carried out in near future, which means voltage stability and regulation problems should be studied before connecting these plants to existing networks.

The purpose of this work is to establish the analysis of the distributed solar generation that is planned in Houn in Libya. The analysis has the aim of determining the effect of installing 14 MW solar station connected to the distribution station of Houn. This analysis will focus on studying the voltage profile, voltage stability; short circuit faults, reactive power flow, and harmonic distortions due to the connection of the solar station to the distribution system at Houn. The study will discuss the general structure of the solar generation station and its components. The connection between the solar system and the power distribution station of Houn will also be discussed. A load flow and short circuit analysis of the studied systems will be performed in an attempt to obtain the optimal levels of voltage quality and stability of the system. In order to verify the feasibility and validity of the studied system, model of the distribution station combined and connected with the solar PV station will be built in ETAP software. Different analysis methods of load flow,

short circuit, voltage stability, and harmonics are going to be analysed. Separately, modelling of the solar system will be discussed and studied to show the different parameters that affect the function of the solar cells. The model will be carried out using Matlab software and different operating conditions will be studied and discussed.

As a conclusion, the objectives of this study can be resumed in the next few points:

- To study the capability of solar generation systems in the load demand and power flow reduction at the distribution station level in Libya.
- To study the effect of connecting large scale commercial solar sources directly with the public grid. And to open the opportunity for future analysis of the techno-economic benefits of connecting large or small size solar projects to the Libyan National Grid.
- To inspect the consequences of grid connected solar systems on the voltage regulation levels in the public network in Libya and its participation in load reduction and stabilization of transmission systems.

1.3 Overview of the Thesis

In Chapter 2, a review of the existing literature on the topic is presented. In Chapter 3, discussion on the distributed generation systems is presented, the methodology followed in the thesis is described and the two simulation and analysis software programs are presented. In Chapter 4, the design and simulation of the grid connected plant are given. In Chapter 5, load flow, short circuit analysis, harmonic analysis and voltage profile studies are explained. In Chapter 6, results are discussed. In Chapter 7, the thesis is concluded and future work is discussed.

CHAPTER2

LITERATURE REVIEW

2.1 Introduction

The Energy is defined conventionally as the capability of work production. The origin of the word energy comes from the ancient Greek. It is a compound term from the two Greek word "en" and "ergon". The terms mean something that can work in the body. Scientists define the energy as the ability or capacity to perform work. The famous physician Max Planck has given a more accurate and scientific definition of the energy. He defined the energy as: "The ability of a system to produce outside activity" (Tzanakis, 2006).

Electrical energy has been the main source of energy for humanity during the last two hundred years. However, this energy is produced based on the burn of fossil fuels like gas and petrol oil. These fuels suffer from two disadvantages that pushed toward the investigation in new natural resources; these are the environment pollution and the non-renewable nature of these fuels. Scientists have focused on the investigation of renewable energy resource for electrical energy production. In the last decades, different technologies were developed to produce green energy. One of the main developed technologies was the solar energy technology. Throughout the course of its development, renewable solar energy has witnessed different revolutions in terms of power production, back-up and efficiency. Recently, solar or renewable energy systems became able to be connected directly to the electric grids. This allowed these systems to support the existing power generation systems directly with the minimum costs. They share now in a great amount of power production all around the world. However, these advantages were combined with some drawbacks concerning the effects of distributed generation systems which a term is describing all power sources that are connected to the main sources at any point- connected to the existing power systems. These drawbacks concern mainly the lack of stability, voltage regulation, and harmonic distortions caused by distributed generation systems.

2.2 Literature Review

Different researches were pointed toward the study and analysis of these drawbacks and different solutions to overcome their effects. (Coster, Myrzik, Kruimer, & Kling, 2011) Has discussed the effects of the Distributed Generation (DG) systems on the power grid stability as reported by Dutch distribution system operators. The authors discussed the

different opportunities to handle network planning challenges in the existence of distributed sources. Paper demonstrated that voltage control issues and protection errors are rarely happening in compact power systems. A study of the issues combined with the use of distributed generation systems on the power grids was presented in (Therien, 2010). The author discussed different issues like voltage regulation, protection system faults, harmonics, power flow, and intermittency of power systems with DG. A case study of a grid connected solar system was presented to address the different issues related to the DG. In (Nazari & Ilic, 2008) different problems related to the use of distributed generation systems on power grids were discussed.

The effects of the location of DG and technology on the stability of the power system voltage were discussed in (Angelim & Affonso, 2016). In the paper, three distributed generation technologies were discussed and experimented. In addition, different DG locations were used and the effects on the stability of the power systems were discussed. An analysing method of the financial value of the DG systems was proposed and discussed in (Ault, McDonald, & Burt, 2003). The authors discussed different factors and issues concerning the DG systems. The developed function is helpful in determining the DG impact on the network, business, and the penetration of system. A case study of the United Kingdom distributed generation system was also discussed in this work. Line losses reduction due to the use of DG systems was discussed by (Dang, Yu, Dang, & Han, 2011). The work presented the study of radial feeder and distributed generator system under various load conditions, Results of losses reduction were presented and discussed. Impact of distributed generation on the dispatch of power systems was discussed in (Liu, Zhang, Zhou, & Zhong, 2012). Different renewable energy distributed generators were discussed and their impact was studied.

A study of the investigation of hybrid distributed generation system of wind, PV, and hydro power sources was presented by (Liu, Zhang, Zhou, & Zhong, 2012). The dynamic impact of these DG systems was analysed and presented (Olulope, Folly, & Venayagamoorthy, 2013). Different issues related to the placement of distributed generators into power grid were discussed in (Yadav & Srivastava, 2014). Review of the most DG technologies also was presented in this paper work. The work in (Zhao, Li, & Liu, 2014) discussed the analysis of distributed generators and the optimal design techniques of these generators.

CHAPTER3

DISTRIBUTED GENERATION SYSTEMS

3.1 Introduction

Life cannot be imagined, to have the same quality it is having without electricity. It is so important for life and human civilization. It is the source of light that clear the darkness, it is the way how we keep our foods in fridges, and it is the mean we use to operate our air conditioners, electricity is the invention that gives our life its comfort, None of our basic needs for comfort life can be achieved without electricity. TV's, cameras, personal computers, digital processors, phones, cellular phones, radio, modem cars, home appliances, and many other electronic devices could not happen to work without electricity. Based on reports of the Energy Information Administration (EIA); until 2030, the electrical energy is expected to remain the fastest developing form of energy worldwide (Dorian, Franssen; & Simbeck, 2006). The traditional resources used for electrical energy production have dangerous consequences on the environment especially under the actual and predicted electrical consumption rates.

The nature and sources of electricity is well known and understood. This knowledge allows various uses of electrical energy to be useful. Nowadays, the integration of clean electrical energy sources into the actual infrastructures is growing quickly; governments as well as environment organizations are paying more attention for the subject. However, governments need to do more efforts to increase the chances of renewable resources to be more competitive.

New policies and technologies aim to decrease environment pollution due to energy production by finding new clean, renewable, and low cost resources. Renewable resources like solar, wind, sea waves, and many other energy sources are nowadays more and more investigated. The use and development of these renewable clean free energy sources has led to the use of Distributed Generation systems DG.

3.2 Electric Power Networks vs. Distributed Generation

An electrical grid is an interrelated network of electrical components distributing electrical power between producers and clients. Power systems in our days are very complex grids that can be essentially categorized into four main groups: generation system, transmission

system, distribution system, and different loads (Paolone & Cherkaoui). Figure 3.1 shows a general structure of the electric power grid. In the generation system, electricity is mostly produced by huge centrifuged alternators located in generation stations. The electrical power is usually generated under the level of 11 kV or 30 kV.




Figure 3.1: Structure of the electric power grid (Paolone & Cherkaoui)

Overhead transmission networks are responsible for the transmission of electrical power between different parts of the system. They transfer energy from main stations to distribution stations and between generation stations as well. The distribution grid can be either low or medium voltage distribution network. It uses transformers to step down high or extra high voltages to low level or medium level voltages. Transformers in the distribution unit feed electrical power to a number of secondary feeders whom consumer is connected to. Customers are connected to feeders either directly or through transformers to step down the voltage to a suitable level.

Distributed generation (DG) term is used to describe the use of group of interconnected small size power generators. These generators produce low voltage level electricity by usually using alternative fuel. The distributed generators are constructed such that they can

be connected directly to the nearest available network and loads. A general description of a power system including distributed generation systems is present in Figure 3.2. Distributed generation is still used and considered as spare or emergency endorsement source of power and restricted to a limited part of grid tied sources.




Figure 3.2: A power system with distributed generation (The grid as it is today, 2016)

DG systems are less used in many countries where prices of oil and natural gas are low, or where regulatory batteries are used. However, widespread of DG is being reconsidered due to the changes in relation between centralized and distributed power generation; in addition to the excessive use of natural gas and restrictions on the new transmission lines, and the new technologies that are implemented in the DG systems (The grid as it is today, 2016).

3.2.1 History of distributed generation

In 80s of the 19th century, the Pearl Street electric system that was created by Edison and served Wall Street and the near buildings can be considered as a distributed generation system. The same generation structure continued until the end of nineteenth century in the United State of America (USA) and around the world. Such systems served few small areas by direct current sources. Over more, individual factories were served individually by systems that supplied electric power with heating in Combined Heat and Power (CHP)

systems (Hughes, 1993). The main struggle of the distributed Direct Current (DC) system was the huge amount of losses under low voltages. The transmission of electricity under low voltages for long distance causes a lot of power losses. As a result, other competitors supported the use of alternating current based systems. In the Alternative Current (AC) systems larger and spread out areas can be served easily. This was possible thanks for the invention of power transformers.

With technological developments in alternating current systems, more economical investments in large and centralized power systems were required. These centralized high load systems were built in huge networks. They have the ability to spread out in wide areas providing consistent services. Unfortunately, storage of large amounts of electrical power is very difficult; this implies the requirement that demand and supply are balanced all the time. For more efficient use of the transmission and generation systems, different customers need to stabilize their consumption through days and seasons. The grouping of different industrial, commercial, and residential loads helps achieving smooth demand profile the maximum possible. This goal implies the service to be extended over larger areas and the interconnection of multiple areas together. Another motivation for the use of extended electrical services network was the availability of resources of energy. Mines and water hydraulic energy resources are mostly located far from centres of industrial and residential zones. The two possible choices were to transport fuel to the distributed power stations or to transmit the electrical energy from the places of energy resources using high voltage systems. By the 1930s, industrial states had established huge electrical grids, joining together around the steam turbine generation system. Smaller generation systems were then naturally melted and shut down. An increase from 80 MW generation station in 1920 to 600 MW unit in 1960 and then to 1400 MW in 1980 have been witnessed. The idea to return back to the distributed generation in the 20th century came after the petrol shocks in the 1970s and the need to increase the systems efficiencies. The efficiency of large scale economic generation system was limited to 33 % of the used energy (Nishida, et al., 2003).

Evolution of small scale distributed generation has led to important reduction in cost, increased reliability, and less pollution emissions of different turbines, fuel cells, engines, and solar panels. On another side, particularly in the past two decades; a great evolution in

the management, monitoring, surveillance, and control systems has happened (Hamlyn, Cheung, Lin, Cuiigang, & Cheung, 2008) & (Lin, et al., 2009) ..

3.2.2 Types of distributed generation technologies

Actually, types of distributed generators extend to cover all types of power generation methods. These types include the traditional generators like oil and gas generators in addition to recently developed technologies like micro turbines, solar plants, wind farms and other sources of electrical energy.

3.2.2.1 Gas turbines

Gas turbines or power generation based on gas turbine technologies is common with very large generation capacities. Sizes of gas turbines vary from small gas turbines of 500 kW and reaching the capacity of huge gas stations of 50 MW. Gas turbines are very common due to low costs of their maintenance in addition to higher efficiency achieved due to the high ability for heat recovery. Gas turbines are the most favourite type for almost all distributed generation requirements (Davis, 2002).

3.2.2.2 Micro turbines

The same functional cycle of conventional turbines is implemented in micro turbines. However, micro turbines are commercially less developed compared to the mentioned conventional turbines. The development of micro turbine has started from the design of fast and small turbines. These turbines rotate at high speeds of up to 100000 cycles per minute. Their components like nozzles and burners are more and more compressed. Generally, the sizes of micro turbines range between 30 and 250 kW (Pilavachi, 2002). Micro turbines require less maintenance costs and use an air cooling system. However, micro turbines are a little bit less efficient than their conventional large sized gas turbines because of low functional temperatures.

3.2.2.3 Engines

The technology of internal combustion engines is a well-known and conventional engines structure. These engines are fed by natural or diesel oil. Natural gas engines are using spark ignition while diesel oil engines implement a compression ignition technology to fire. The energy of combustion is divided into three main parts; the first part is the mechanical energy that is converted into electricity with the ratio of 26-39 %; the second

part is a useful heat that can be used for different goals and represent 46-60 %; the last part represents different losses of the engine due to radiations and exhaust gas losses in addition to gear box losses.

Power production engines are of the size of 1 MW typically. They are more and more used in distributed generation systems. They are increasingly being used in combined heat power for peak load or standby needs in different applications (Daley, ASCO Power Technol., & Siciliano, 2003).

3.2.2.4 Fuel cells

Fuel cells (FC) produce electromechanical energy out of chemical energy without the need for any thermal energy phase. Fuel cells have very high efficiency compared to other engines. In the fuel cell the hydrogen and the oxygen are fed to the cell. Chemical reactions combining hydrogen and oxygen molecules producing water and energy take place in the fuel cell. The oxidation of hydrogen to produce water creates equilibrium where electrons flow through an external electric structure providing energy. Unlike normal batteries, fuel cells can provide continuous energy provided with the two main functional elements which are oxygen and hydrogen. However, the direct oxidation of natural gas is still impossible which implies the conversion between different materials. This conversion is less efficient and still need more scientific researches and investigations.

Fuel cells have their own advantages including high power efficiency and performance under variable loading values. Their emissions are very small and they cause no noise. The main disadvantage of the use of fuel cells is as mentioned above the high initial costs.

3.2.2.5 Wind turbines

Wind power generation existed since long time and it can be considered as distributed generation sources if it is located near the demand source. Generally, areas with high and stable wind speed over the year can have wind turbine farms. The annual capacity factor of a good wind turbine area is 20-40 %. Typical wind turbine can provide its services for more than 20 years with six month interval maintenance. Rotating axe of the wind turbine transfer the mechanical energy from the wind to a gear box connected to an electrical generator. Normal wind turbine sizes range from few hundreds of watts for residential needs to huge turbines with the power of over 5 MW (Spera, 2009). The main

disadvantages of wind powers reside in the initial costs in addition to the intermittent nature of the energy source.

3.2.2.6 Photovoltaic solar cell

Solar cells have the ability to produce electricity directly from the sunlight by taking advantage of photovoltaic effect (Williams & Ogden, 1989). Solar cells are constructed totally of fixed parts; there are no rotating or moving parts within the solar cell. Typical photovoltaic cell can produce a maximum of 2 W and about 1.5 V. For commercial and technical reasons, multiple cells are normally grouped in series and parallel combinations to produce more power and higher voltage levels suitable to be used in different applications. The group of multiple series and parallel combined cells is called PV module.

3.3 Photovoltaic Systems

PV system is a system able to convert energy from the sun directly into electrical energy. The main part of the solar system is the solar cell combined in groups to produce solar modules and arrays. Solar systems are used to produce energy to be used in feeding different electrical loads. Solar cells produce DC electrical energy that can be used directly in feeding some types of DC loads; or converted through different converter types to feed other DC and AC loads. Solar systems can be connected together to form larger systems or even can be combined with public grids to exchange their power with. The general structure of the solar system is composed of a DC-DC converter, DC-AC inverter, battery system, controllers, protection devices, in addition to some auxiliary power sources and the loads. Recently, batteries in solar systems became an optional part in the grid tied solar systems; these systems exchange the energy directly with the electric grid with the need to locally stock it. By consequence, costs of grid tied solar systems have reduced to half the initial costs.

Solar systems can be found in different forms and sizes from residential application size of less than 10 kW to medium size of 10-100 kW, and other large systems with production capacity of more than 100 kW. These systems are either used as standalone systems, hybrid systems in combination with other energy sources, or connected directly to the power grid to exchange energy interactively.

Commercial solar modules produce the energy from the sun with an approximate energy efficiency of 10-20 %. This means that 10-20 % of the solar energy falling on the module is being captured and converted to electricity. Scientists and research laboratories are making huge efforts to increase these efficiency ratios and decrease the costs of solar applications. As a result of these efforts appeared the solar cells or Concentrated Photovoltaic Cells (CPV). These systems focus solar energy on multi-junction solar cell to increase cell's efficiency. In CPV systems, the solar cells are fit in concentrating collectors. Concentrating collectors use mirrors or lens to concentrate the light of the sun on the solar cells. Some special tracking systems are used with CPV systems to ensure continuous tracking of the sunlight. The main advantage of CPV systems is the very high efficiency achieved. Some references concluded that CPV can produce an energy efficiency of up to 50 % (Luque, 2011). However, the need for special sophisticated tracking systems is one of CPV's costs.

3.3.1 Advantages and drawbacks of solar energy

Solar energy has its own advantages and disadvantages, the advantages of solar energy systems can be resumed by (Deendayal, 2012):

- 1- Solar energy is available mostly everywhere and solar systems are flexible; they can be used in different manners and can be easily implemented.
- 2- Solar energy is available when its need is maximum, the peak demand happens in midday when the solar energy produces its maximum energy.
- 3- Solar structures can work for long periods of time with the minimum maintenance and operating costs.
- 4- Solar energy is clean and environment friend, it is safe and cause minimal pollution.
- 5- Solar systems are modular; any extra power generation can be added easily with no extra needs or expenses.
- 6- Solar systems are the perfect choice to be implemented in remote areas as they are cheap and reliable compared to the creation of public grids infrastructures.
- 7- The main and most important advantage of solar systems is that their source of energy is infinite, charge free, and accessible all the time.

Although solar energy is clean and cheap source of power, it still presents some disadvantages. The main disadvantages of solar energy are:

- 1- Solar energy needs to be stocked in batteries especially in remote areas; that amplify the expenses and imply extra maintenance costs.
- 2- The most important drawback of solar energy resides in its initial costs if compared to other large scale electrical power sources. However, in the last 10 years the costs of the solar energy have decreased to about 50 % due to the use of new technologies in their production and development.
- 3- Another drawback of solar systems is the variable output power that is a function of the solar irradiation and temperature. Areas that have short day times or covered by clouds for long periods will produce very low amounts of energy. Over more, the efficiency of solar arrays is less than 20 %; this means more and more reduction in power generation.

3.4 Energy Potentiatin Libya

Libya is one Qf the main exporting countries in Africa and the world with 6 million populations spread over its area of 1.75 million squarekilometres. WeatherIn Libya is Middle Eastern hot in summer and warm in winter. Like most of Middle East countries, Libya has high average solar irradiation that makes it a great solar energy potential. The daily average irradiation varies between 7.1 kWp and 8.1 kWp(Mopfa&Qellich, 2009). Figure 3.3 presents the solar map of Libya showing the solar energy distribution in the Libyan territories. Until 2011, Libya had a large electric grid with big and well-arranged infrastructure, 12000 km of high voltage networks combined with 12500 km of medium voltage grid in addition to 7000 km of low voltage grid constructed the main nerves of the Libyan national grid (Hassan, Nafeh, H.Fahmy, & El-Sayed, 2010). However, after the war in 2011 the situation in Libya has changed and national electric grid became unable to feed the country with the required energy. Many high and medium voltage transmission lines were destroyed during and after the war and couldn't serve the distribution stations. Power consumption in Libya is in continuous growth. Load profile in Libya during the years 2003-2012 is presented in Figure 3.4. It shows a constant annual increase in the consumption during this period except for 2011 where political and civil war events have affected all the fields of the life including the energy consumption and production. Many generation and distribution station went off service during the war that has a great effect on

the overall energy sector. (Figure 35) demonstrates the growth in Libyan electricity generation during the period ext~11di11gfr9m2003 until the year 2012. The figure shows that the energy production was growing in a fixed rate of approximately 7.6 % between 2003 and 2Q10. However, the energy production sector has faced some troubles during the year 2011 as a result of the political and security instability. However, during the year 2012 the energy production sector has recovered its normal growth rate and the annual production reached the value of 35000 GWh.




Figure 3.3: Solar map in Libya (Solargis, 2016)




Figure 3.4: Load growth in Libya 2003-2012 (Ibrahim & Khalifa, 2003)




Figure 3.5: Electricity production growth in Libya between 2003 and 2012 (Ibrahim & Khalifa, 2003)

3.4.1 Photovoltaic applications in Libya

The investigation in solar potential in Libya is still weak and need more plans and governmental support. There exist four main applications of solar energy sector in Libya; these are solar energy for communication systems, cathodic protection, rural electrification and water pumping.

3.4.1.1 PV system for Libyan microwave communication networks

The Libyan communication networks consist of about five hundred stations of repeaters. In the end of the year 1997, 9 rural stations were driven using solar systems. The approximate total peak power demand was about 10.5 kW peak. Among the 9 solar energy powered communication stations, four stations solar systems are still working after more than 30 years of service. The batteries of the system were replaced many times with an average life time of 8 years. On the other hand, the other stations that use diesel generators have faced many struggles due to the lack of diesel and maintenance. Problems include continuous interruption in the communication services and stolen fuel and engine parts. One of the most famous cases was in Zalaf station that went of service for 17 days during the year 1997 (saleh, 2006). Nowadays, more than 80 communication stations in Libya are using solar energy to obtain their power needs. This increase in the number of solar energy ~~provided~~ stations is due to the success of solar energy applications and the reductions in the costs of solar applications. Figure 3.6 shows the relation between the number of diesel based communication stations compared to those powered using solar energy sources between the years 1980 and 2003 (Ibrahim & Khalifa, 2003).




Figure 3.6: PV and diesel stations in the communication network
(Ibrahim & Khalifa, 2003)

3.4.1.2 Solar energy for cathodic protection

The Cathodic Protection (CP) stations are usually situated at large distances from public networks; this signifies that it's impossible practically to use the public grids in feeding these stations with their power requirements. A cathodic protection station requires up to 15 kWh daily. Solar systems offer a perfect and reliable source of energy for CP stations. Solar systems must be chosen to fit best the load profile of a CP station. Solar systems for CP stations can be set up in any place near to the station to convert directly the sun energy to the required type of energy need by the station. For reasons related to maintenance of diesel generators, the need for continuous supply of fuel. In addition to the lack of power grids that solar resources were chosen as the best alternative for CP station empowerment (Al-Jadi, EK.biat, & Krema, 2012). The first system used in CP stations in Libya was set up into service in 1976, CP stations comes the next in the total accumulated solar power in Libya after communication systems. By the year 2005 over than 300,CP stations were powered using solar energy systems in Libya. The total set up systems produced about 450kW peak (AI-Jadi, EK.hlat,& Krema, 2012).

3.4.1.3 Rural electrification with PV systems

The main problems that face the planners of power distribution systems in different countries can be concluded in low population, and distance from the existing networks. The extension of high voltage lines to cover rural areas through the desert is a very costly process and needs special budgets. In the less populated countries of the developing countries, just main cities are empowered through the public network. The electrification of rural areas is accomplished by the use of other resources available within the possibilities of the governments.

As an example, in a 200 citizen's village located at a distance of fifteen kilometres from the distribution station in Libya, and considering an average annual individual consumption of JOOO kWh, the village will need 200 MWh per year. A price of 0.75 \$/kWh will be charged to be able to provide such a village with electricity from this station without loss which is 10 times the actual national tariff in Libya. For such reason, a rural area was accepted to be a place having 200 citizens and situated at a distance more than 5 km from the low voltage grid (AI-Jadi, EK.biat,& Krema, 2012).

The Libyan national plan to cover all the remote areas by electricity is to electrify all distributed houses and villages in addition to water pumping units. A project for the electrification of 10 villages was presented earlier to be established as a first step in this plan (Al-Jadi, EK.biat,& Krema, 2012). Some of these villages are:

- a) Mrair Gabis village.
- b) Swaihat village.
- c) Intlat village.
- d) Beer al-Merhan village.
- e) Wadi Marsit village.
- f) Intlat village.

The first works of installation of solar systems in this project was initiated in 2003. The total number of installed projects by the General Electrical Company of Libya (GECOL) was 340 with capacity of 220 kW peak. Projects that are installed by the Center of Solar Energy Studies (CSES) and the Saharian Center is about 125 kW peak divided on 150 individual projects. The applications were as following:

- 380 projects for isolated houses.
- 30 projects for police stations.
- 100 projects for street lighting.

3.4.1.4 PV systems for water pumping

Water pumping is one of the most suitable applications of solar energy systems. The variable nature of the-produced solar power is acceptable in water pumping applications. The project of water pumping included the installation of 35 individual solar projects. The total power generated by these projects is 96 kWp. Table 3.1 shows the total solar power generation for different applications in Libya until the year 2014 (Al-Jadi, EKhlat, & Krema, 2012).

Table 3.1: The total installed PV capacity in Libya

APPLICATIONS	NUMBER OF SYSTEMS	TOTAL POWER [KWP]
COMMUNICATION	100	420
CATHODIC PROTECTION	300	540
RURAL ELECTRIFICATION	510	345
WATER PUMPING	40	110
TOTAL	950	1415

3.5 Methodology of the Work

In this research, a large scale grid connected photovoltaic system is designed with 14 MW installed capacity. Details of the design include the total number of PV modules, inverter, cables and circuit breakers. In this study, the main system design is undertaken based on the amount of generated power. The generated output power from the PV system is at 0.4 kV voltage level. It is stepped up through 0.4 kV to 11 kV bus-bars by 7 step-up distribution transformers with 3 MVA rating each. The output of the power transformer is synchronized to the national grid at Houn substation less than 100 m of the supply point. To achieve the power ratings, 7 arrays with 2 MW for each array resulting at 14 MW generated power were adopted.

Results and objectives of this study presented in three main areas. Detailed design section, Matlab/Simulink PV Simulation, and power analysis studies using ETAP. Design section starts with considering the methods of connection of solar arrays and their connection with the inverter and power transformers, cables selection, inverter selection, and protective devices selection. Load flow, short circuit, harmonics and voltage stability studies were carried out. The results of power flow, busses voltages, busses angles and line losses were compared. Flow chart of the methodology is depicted below in Figure 3.7.




Figure 3.7: Flow chart of the station design and analysis process

3.6 Modelling and Analysis Software

In this work, two software packages have been used which are:

3.6.1 MATLAB / SIMULINK (version 7.8.0.347 (R2009a))

The Matlab is a high level powerful programming language dedicated for technical processing and mathematics purposes, it has an easy to use and manipulate user interface. Matlab environment presents mathematical problems and solutions simple and familiar mathematical notation. Matlab has a very powerful graphical user interface called Simulink. Simulink is used to build easily models for different systems. The interactive graphical environment of Simulink simplified the process of modelling processes or systems, removing all necessity of writing differential equations in programming languages (MathWorks, 2016).

3.6.2 ETAP (version 12.6.0H)

ETAP is the most wide-ranging analysis software that is designed especially to design and apply tests of power systems. ETAP program can use real data obtained from normal operation of the systems to perform offline data analysis, simulation, energy management, and load control. The name ETAP stands for (Electrical Transient Analyzer Program). It is designed to be used by engineers to perform different tasks of power systems analysis for different areas of industries in a one package.

CHAPTER4

DESIGN AND SIMULATION OF GRID CONNECTED PV SYSTEM FOR LIBYAN NATIONAL GRID

4.1 Introduction

In this chapter, the details of the design and calculations of 14 MW PV integrated to the Libyan national grid at Haun city which is the capital of the Jufra District in Libya will be presented. Also, mathematical modelling of the PV panels used in the design will be discussed and presented; Matlab simulations of the panels will also be discussed and presented in this chapter.

4.2 Design Procedure of the PV Station

This section introduces the design procedure before the integration of solar PV power system into an existing grid with power generation of 14 MW. The main system design is undertaken based on the amount of generated power (14 MW). The generated voltage is 0.4 kV and it will be stepped up to 66 kV. It is stepped up through two stages:

- First stage: voltage step-up from 0.4 kV to 11 kV by seven step-up distribution transformers with 3 MVA rating each.
- Second stage: voltage step-up from 11 kV to 66 kV by two step-up power transformers with 12.5 MVA rating.

The output voltage of the power transformer is synchronized to the national grid at Haun main substation. To achieve the power ratings, 7 PV arrays with 2 MW for each array resulting at 14 MW generated power will be used.

PV modules must be selected based on some criterions related to their efficiency, price, warranty, life period, and atmospheric conditions. The selection must take these considerations in account in order to guarantee the best performance, highest benefit, reliability, at suitable prices. The first decision is to choose between mono-crystalline and poly-crystalline modules. The choice must consider the price and efficiency as the first criterions as the other criterions are approximately the same. Generally, the prices of poly-crystalline are more expensive than the mono-crystalline panels. However, the efficiency

in poly crystalline modules is a little better than mono crystalline panels. Due to the high costs of the project as the project needs a huge number of PV panels to generate the required power of 14 MW. The Renewable Energy Authority of Libya "RE AOL" decided to use mono crystalline panels. Suniva ART245-60 modules of 240 Wp solar panels are going to be used in the project. ART245-60 module is a well-known robust solar cell's type that is designed to be used in grid tied solar projects and power stations. The characteristics of the ART245-60 are taken under STC "Standard Test Conditions" in laboratory environment. The standard conditions are 1000W/m² irradiation, 25°C, and 1.5 solar spectrum air mass. Basic features of the used modules are presented in Table 4.1 while the detailed data sheet of the module is presented in Appendix 2 (Suniva, 2010).

Table 4.1: Basic features of the discussed PV modules


Maximum power	240W
Voltage @ maximum power point	30.9V
Current @ maximum power point	7.95
Open circuit voltage	37.4
Short circuit current	8.44
Cells per module	60
P (Voltage de-rating factor (Voc% /°C))	-0.332
a (Current de-rating factor (Isc % /°C))	0.035
y (Power de-rating factor (Pmax % /°C))	-0.465

4.2.1 Design and selection of grid tied inverter


Inverter is a power electronic device used to invert/convert electrical energy from DC to AC. The inverter is actually bi-directional device; the power conversion is achieved from AC to DC or from DC to AC. However, it is mainly used as an AC generator (Rashid, 2001). The DC side of the inverter is fed from a battery or a group of batteries while the AC side can be connected directly or via a special transformer to increase the voltage level and improve the quality of the generated voltage. Inverters are used in UPS systems, static compensators, active filters, flexible alternative current transmission systems (FACTS), and many other applications (Rashid, 2001). The development of power electronic

technologies has led to a great evolution in the voltage source inverters topologies and control schemes. Recently, synchronised or grid connected inverters are widely spread and used in renewable energy applications. Such inverters have the ability to synchronise their output voltage and current with the grid's voltage. They can be directly connected to existing powergrid and interchange energy with the latter. Grid connected inverters have greatly decreased the costs of solar and wind energy systems as they reduced the need for batteries to backup generated energy. Instead, generated energy is being fed directly to the grid that is considered as a huge battery for the power system.

Two types of inverters can be used in large scale projects; these are multiple string inverter and central inverter. Multi string inverter topology is presented in Figure 4.1-a. Each group of panels or strings are connected together and fed to a suitable DC-AC inverter. The group of inverters are then connected individually and separately to the grid. The main advantage of this topology is the use of small, size and rating inverters instead of using one large inverter in central topology. It also requires less maintenance in general than the other topology. The failure of one inverter in a string system causes the failure of a part of the system and not the whole system. Over more, the maintenance required will be considered for that one inverter and not for the whole system. However, the initial cost of string inverter based system is higher than the central inverter. String inverters are still new topologies and not used too much in large scale stations. One more advantage of the string inverter is that it can be connected with strings with different angles and different voltage levels. Central inverters are the most used in power stations. Figure 4.1-b shows the topology of the central inverter. Multiple PV strings are combined in a one DC box out of which one connection is fed to a high rated inverter. The DC connection of multiple strings implies that their tilt angle and generated power are exactly the same. Central inverter requires less space and less initial costs compared to string inverters. However, the failure of the inverter causes the failure of the whole system (Cenergypower, 2014).



{a) String inverter



{b) Central inverter

Figure 4.1: (a) - String inverter a vs. (b) - Central inverter (Cenergypower, 2014)

Due to the low initial costs and the familiarity of central inverter in similar applications as it is used widely all over the world in similar applications, central inverter has been chosen to be implemented in this work. Details of the design and sizing of the system are going to be discussed in the next sections of this chapter.

4.2.1.1 Design of the central inverter

The aim of the present study is to design a large scale grid connected PV generator. The design must take different rating and power calculations in consideration to avoid future failures and problems as much as possible. The system is going to be connected to the Houn station in the Jufra district. The capacity of the solar system is decided to be 14 MW of mono crystalline solar panels. The design needs to consider the maximum input voltage for the inverter to find the maximum series strings or modules. Also, the maximum current rating of the inverter is used to decide the parallel strings that are going to be fed. Cables

sizes also must consider the current rating of the strings. Central inverters of 1 MW rating from ABB were chosen to be used in the project. Total of 14 inverters are going to be connected and used in the system. Central inverter PVS800-57-1000 kW-C model is used. Main features of this inverter's model are presented in Table 4.2 while the documentation is provided in Appendix 3 (ABB, 2014). To accomplish the design task of the project, the total power was divided on seven fields. Each field has a power capacity of 2 MW. The design considers the calculations for one field and then generalized for the rest of the fields of project. Given that the maximum power of each module is 240 W_p, the total number of modules to be used in each field can be found easily by:

$$\text{Number of modules per field} = \frac{2000\text{kW}}{240\text{W}} = 8333 \text{ PV module}$$

Table 4.2: Features of the ABB 1 MW central inverter used

Model	PVS800-57-1000kW-C
Rated power	1000 kW
Maximum power	1200 kW
DC voltage range (MPPT)	600-850 V
Maximum DC voltage	1100V
Maximum DC current	1710 A
DC inputs	8-20
Nominal AC voltage (3-phase)	400V
Nominal AC current	1445 A

The total number of the PV modules in the project is then given by:

$$\text{Total number of modules} = 8333 \times 7 = 58,331 \text{ PV module.}$$

It is important to remember here that the power ratings given in the datasheet of the solar modules are measured under standard test conditions that are difficult to be achieved in real life. The real maximum power obtained from the module is mostly less than this value due to high temperature and low irradiation levels. The open circuit voltage values given in Table 4.1 were given at standard temperature of 25 degrees. However, the temperature is variable that can decrease to less than zero or more than 60 at the cell's surface. For this

reason, open circuit voltage values are going to be calculated at the highest and lowest temperature limits of the modules that are -40 and 90 degrees. The next relation can be used to give an approximation of the open circuit voltage.

$$V(T) = V_{OC} \times (1 + f_3 \times J \times T) \quad (4.1)$$

Where f_3 is the temperature de-rating factor shown in table 4.1. The maximum and minimum voltages of the system can be given as:

$$(V_{OC})@-40^{\circ}C = 37.4 \times [1 + (-0.332) \times (-40 - 25)/100] = 45.6 V$$

$$(V_{OC})@90^{\circ}C = 37.4 \times [1 + (-0.332) \times (90 - 25)/100] = 29.32 V$$

$$\begin{aligned} (VMPP)@-40^{\circ}C &= 30.9 + (-0.332 \%) \times J \cdot T = 30.9 + (-0.00332) \times (-65) \times 29.8 \\ &= 36.2 V \end{aligned}$$

$$(VMPP)@+90^{\circ}C = 30.90 - 0.00332 \times J \cdot T \times 30.9 = 30.90 - 65 \times 0.00332 = 24.32 V$$

From Table 4.2, the maximum permissible DC input voltage is 1100 V, and the maximum power point voltage ranges between 600 and 850 V. It is important to notice that both the open circuit and maximum power point voltages are maximal at the minimum temperature $-40^{\circ}C$ and minimum at $90^{\circ}C$. These values are important to find the number of series connected modules per each string that can be connected to the inverter. These values are going to be calculated after minimum acceptable temperature that is $-40^{\circ}C$.

$$\text{Number of rigid modules per string} = \frac{V_{maxinverter}}{VMPP@-40^{\circ}C} = \frac{850}{36.2} = 23.4 \quad (4.2)$$

The optimum number of modules per string is found to be 23 modules per string. Now it is important to find the maximum possible number of modules per string as follows:

$$\text{modules per string}_{\max} = \frac{V_{maxinverter}}{V_{OC}@-40^{\circ}C} = \frac{1100}{37.4} = 29.4 \quad (4.3)$$

That means the maximum allowed number of series modules is 29 modules. The optimal design implies that the number of series module will be between 23 and 29 modules as maximum. In order to find the maximum number of parallel strings, it is important to

consider the short circuit and maximum power point currents. The number of strings is found as follows:

$$\text{String number per inverter} = \frac{I_{max,inverter}}{I_{SC\text{mod}/e.}} = \frac{1710}{8.49} = 201.4 \text{ strings} \quad (4.4)$$

This means that a maximum of 201 parallel strings can be connected at the input of the inverter. For each inverter, taking in consideration the total number of modules per field found previously to be 8333 modules that will be distributed on two inverters. That means each inverter will be connected to a total of 4167 modules. If we accept that each string will contain 26 series modules for better performance and security, the number of parallel string is then given by:

$$\text{String number per inverter} = \frac{\text{StringSper inverter}}{\text{Modules per string}} = \frac{4167}{26} = 160 < 201 \quad (4.5)$$

From the previous calculation it was found that the design must use 160 strings of 26 modules each respecting the inverter and modules specifications. Figure 4.2 shows the connection of the strings and modules as calculated previously.




Figure 4.2: The array configuration of the central inverter

4.2.2 Layout of grid connected PV system with the central inverters

Since there exist 7 distribution transformers with 3 MVA rating each, the modules were distributed on 14 arrays. Each two arrays were connected to 1 transformer through two separate central inverters. The seven transformers primary sides are connected to the 11 kV grid bus bar. Inverters are connected to the panels such that each inverter is connected with 160 parallel strings, and 26 modules per string in series. Figure 4.3 below presents the connection scheme of the arrays, inverters, transformers and bus bars.




Figure 4.3: General structure of the arrays with the inverters

The wiring diagram connection of the inverters output to the main AC combiner box is shown in Figure 4.4. It must be mentioned here that the output of the main combiner box was connected to a step-down distribution transformer from the secondary side. This transformer is selected to be (11/0.4) kV, since it is connected to the inverter from the 0.4 kV level side. The 11 kV voltage level is selected because the Houn station has an 11 kV bus-bars. The connection between each two elements is done through special AC

protection and disconnection circuits to ensure the total safety of equipments and persons against any faults or electric hazards as shown in Figure 4.4. These protection circuits in addition to the suitable cable sizing calculations are going to be discussed in the next parts of this work gradually.




Figure 4.4: Wiring diagram of connection of inverters output to main combiner box

4.2.3 Cable sizing

Cable sizing is one of the most important issues in electrical works and installations. It is a very vital measure of security to ensure the capability of connection wires to handle all types of electrical and electromagnetic stresses under the different possible atmospheric conditions. In addition, the wiring must not affect the performance of the designed system due to extra losses caused by wrong sizing of cables. Cables must be sized to withstand the current flowing through it, to support short circuit fault levels for short periods until the tripping of protection circuits, to handle changes in temperature and moisture, to be able to withstand the voltage levels they are carrying, and to ensure the minimum possible voltage drop. The voltage drop in a wire can be given by:

$$V_d = \frac{P_x L}{A} \quad (4.6)$$

Where,

ρ : is the resistivity of used wire which is normally taken to be 0.0183 $\Omega \cdot \text{mm}^2/\text{m}$ for copper.

l = the length of cables in meters.

I = the current through the cables in amperes.

A is the cross sectional area (CSA) in mm^2 .

The multiplication by 2 accounts for total circuit wire length. We can rearrange the above equation to obtain the following equation:

$$A = \frac{2\rho I l}{V_{\text{dmax}}} \quad (4.7)$$

In the design of the system, a maximum cable voltage drop of 5 % was used and this is the maximum allowable voltage drop in the international standards.

4.2.3.1 Sizing cables between PV modules

The cable is sized based on the following information:

Length of cable is 1.5 m, while the maximum current that can flow through the wire is given by:

$$I_{\text{max}} = 1.25 \times I_{\text{SCmodule}} = 1.25 \times 8.44 = 10.55 \text{ A} \quad (4.8)$$

Where, the factor of 1.25 was considered for reason of security. The maximum allowable voltage drop is given by:

$$V_{\text{dmax}} = V_{\text{MPPT}} \times 5\% = 30.4 \times 5\% = 1.52 \text{ V} \quad (4.9)$$

The wires are considered copper wires that have resistivity of 0.0183 $\Omega \cdot \text{mm}^2/\text{m}$, from which the cross sectional area is found as:

$$A = \frac{2\rho I l}{V_{\text{dmax}}} = \frac{2 \times 0.0183 \times 1.5 \times 10.55}{1.52} = 0.3 \text{ mm}^2 \quad (4.10)$$

This means that any cable of cross-sectional area above 0.38 mm² can be used for the wiring between PV modules. However, this value is suitable to ensure the minimum voltage drop, but it is not enough to ensure that the wires can handle the maximum current flowing through it. By referring to the NEC tables for cable sizing it is found that a wire of 15 mm² is needed to withstand a current of 9A while a wire of 2.5 mm² is needed to withstand 16A. In our application the maximum current with safety factor is 10.55, then the best choice is a 2.5 mm² wire. It is important to notice that special insulated DC wires with PVC cover are used. This insulation is suitable to be used under ultraviolet rays without need for any extra covering.

4.2.3.2 Sizing of cable from PV array bus-bar to inverter

The cable is sized based on the following information:

Length of cable is 20 m, the maximum current from array is 8.44 x 160 x 1.25 = 1688A.

The maximum voltage drop is given by:

$$Vd = 5\% \times V^{\circ} \times i_{\text{min}} = 5\% \times 600 = 30V \quad (4.11)$$

The minimum cross sectional area is found by:

$$A = \frac{2 \times p \times l \times I}{Vd} = \frac{2 \times 0.0183 \times 20 \times 1688}{30} = 41.2 \text{ mm}^2 \quad (4.12)$$

That means the minimum cable cross sectional area needed to ensure acceptable voltage drop is 41.2 mm², however; the design must consider the cables' ampacity. As the wires need to handle an amount of current of 1688A, by referring to the cable tables it is found that the maximum cable size is 240 mm² and can handle a maximum of 400A. A good choice of cables was found to be 6 wires of 150 mm² that can handle a maximum of 1722A.

4.2.3.3 Sizing of cable from inverter to main junction (inverter / distribution panel)

The cable is sized based on the following information:

Maximum length of cable is 30 m; the maximum current from inverter at full load on each phase (line) is given by:

$$lpIbase = \frac{\text{Inverter } V_{ax}}{V_{LL} \times J_f} - \frac{1200}{400 \times J_f} = 1.73kA \quad (4.13)$$

The maximum allowable voltage drop is given by:

$$vdmax = 5\% \times 400 / J_f = 11.5V \quad (4.14)$$

The minimum cross sectional area correspondent to voltage drop can be calculated by:

$$A = \frac{2xpxlxl}{vdmax} = \frac{2 \times 0.0183 \times 30 \times 1.730}{11.5} = 165.2mm^2 \quad (4.15)$$

By considering the cable ampacity, 6 cables of 185 mm² should be used to connect each inverter to the bus bar.

4.2.4 Sizing of circuit breakers

Circuit breakers are installed in the system to protect against over current of the circuits and sized to not be below 125 % of the current flowing through the wiring. The circuit breakers used in this installation must be bi-directional. However, the sizing of circuit breakers should be less than the maximum ampacity of the protected cables in the circuit.

4.2.4.1 Sizing of circuit protection between PV array and inverter

There are generally two ways of undertaking the circuit protection between PV array and Inverter.

- 1- Each parallel string of modules can be fused before entering DC collection point.
- 2- The total output of the PV array is fused before being joined to the inverter.

In this study installation, the first option is used because that makes it easier to find suitable DC circuit breakers at suitable prices.

The maximum current is 1.25 x short circuit current of modules (8.44 amperes) = 1.25 x 8.44 = 10.55A

Therefore, the minimum rate of DC circuit protection is $\frac{125}{100} \times 10.55 = 13.18\text{ A}$ per parallel string.

4.2.4.2 Sizing of circuit protection on every phase output of inverter

The maximum current from inverter at full load on each phase (line) was found earlier in this chapter, the current was 1730A per phase. During the cable sizing calculations it was found that we need to use 6 cables of 185mm². The best circuit breaker value for this cable size is 300A circuit breaker. That means 6 circuit breakers with capacity of 300A are going to be used at the output of the inverter.

4.2.5 Synchronization with grid system

In a grid tied system, the synchronization is a very important notion to take care of. The connection between two power sources needs to take in consideration that the two sources have the same variables. The variables that must be equal are the voltage, the phase, and the frequency. The connection between sources is done just when these three variables are equal in both sources. There are two connection points between the grid and the solar system; these are the 0.4 kV level bus-bar and the 11 kV level bus-bar. Synchronization must be achieved when there is a closed loop system; this is implemented by using Synchro-check relay. Two voltage transformers (VTs) on phase measure the voltages, one on the system circuit side and the other on the bus-bar. The Synchro-check relay compares the line voltage and the bus-voltage, and then a closing pulse command comes from the SCADA centre, and closes a normally open contactor if the synchronization conditions are achieved, then the circuit breaker closes. The synchronization is very important to protect the systems from being short circuit connected to each other and it is used in all stations to connect multiple sources of power. Table 4.3 resumes the cable and circuit breaker sizing of the designed system as per calculation.

Table 4.3: Cable sizing for the PV system

Cable	Cable Length (m)	Cable size (mm ²)	CB rating
Sizing cables between PV modules	1.5	2.5	No
Cables from PV array to the inverter	20	6x150	No
Sizing of AC wires	30	6x185	300

4.3 PV Modelling Using SIMULINK

4.3.1 Electrical circuit models of PV modules

Models of photovoltaic cell provide a comprehensive description of the behaviour of photovoltaic cell for scientists to be able to study it. A well-known model commonly used in the electrical engineering is the so called single diode PV cell model. The ideal photovoltaic cells model consists of a single diode connected in parallel with a light generated current source (I_{sc}) as shown in Figure 4.5. The equation for the output current is given by:

$$I = I_{sc} - I_D \quad (4.16)$$

While the diode's current is given by:

$$I_D = I_0 [e^{(V + I R) / V_T} - 1] \quad (4.17)$$




Figure 4.5: Solar cell's model using single diode

The light generated electric current depends on both temperature of the cell and irradiance. It is measured under laboratory special conditions. Thus:

$$I_{sc} = I_{sc,ref} + k_s (T_k - T_{ref}) \times 0^{\circ} / 1000 \quad (4.18)$$

Where:

I_{sc} is the light generated current at the STC (25°C and 1000W/m^2).

K_i is the short circuit current/temperature coefficient at $I_{sc,r}$ (0.0017 A/K).

T_I and T_{ref} are the actual and reference temperature in Kelvin.

a is the irradiation on the device surface, and 1000W/m^2 is the STC value.

The model presented in Figure 4.5 cannot describe the total behaviour of the cell under all environmental variations. Some extra losses need to be considered in a more practical model as shown in Figure 4.6; R_s and R_p are the series and parallel resistance losses.




Figure 4.6: Solar cell model using single diode with R_s and R_p

In this model, a photo electric current source I_{sc} depending on the solar radiation, cell temperature and voltage, a diode whose inverse saturation current is a function of temperature, and two series and shunt resistances to represent different losses in the cell are used. The formula that describes the $I-V$ characteristic of the cell in Figure 4.6 is given by:

$$I = I_{sc} - I_D - \frac{V}{R_p} \quad (4.19)$$

The reverse saturation current I_{rs} is given as:

$$I_{rs} = I_{sc\ ref} \left[\exp \left(\frac{qV_{oc}}{N_s K A T} \right) - 1 \right] \quad (4.20)$$

The module's saturation current I_Q changes with the cell temperature and is given by:

$$I_Q = I_{sc\ ref} \left[\exp \left(\frac{qV_{oc}}{N_s K A T} \right) - 1 \right] \quad (4.21)$$

Where, I_Q is the diode saturation current (A). The formula describing the output current of a PV cell or module of the single diode equivalent circuit is given by:

$$I_{pv} = N_p I_{sc} - N_s I_o \left\{ \exp \left(\frac{q(V_{pv} + I_{pv} R_s)}{N_s A K T} \right) - 1 \right\} - V_{pv} + \left(\frac{I_{pv} R_s}{R_p} \right) \quad (4.22)$$

Where:

K : is Boltzmann's constant ($1.38 \times 10^{-23} \text{ J K}^{-1}$).

q : is the electronic charge ($1.602 \times 10^{-19} \text{ C}$).

T : is the cell temperature (K).

A : is the diode ideality factor.

R_s : the series resistance (Q).

R_p : is the shunt resistance (Q).

N_s : is the number of cells connected in series = 26.

N_p : is the number of cells connected in parallel = 160.

$V_{pv} = 37.30 \text{ V}$.

The formula described by equation 4.22 depends on the solar irradiance, and the cell temperature (Abdulkadir, Samosir, & Yatim, 2012). Nameplate values of solar arrays are given under STC conditions. Real operation conditions differ from the STC. The use of the simple model of solar cell in our work simplifies the work without affecting the accuracy or generalization of the theory. It makes it easier for power electronic engineers to consider this model while working with power converters. The value of the shunt resistance R_p is

typically high such that it can be neglected (Abdulkadir, Samosir, & Yatim, 2012) (Yusof, 2004).

4.3.2 Simulink modelling for PV module

Mono-crystalline 240W PV Module is taken as the reference module for simulation and the data sheet details are given in Table 4.1. In addition the simulation for one array of 2 MW is conducted and then the simulation is generalized to all arrays in a similar way. A block diagram of the model based upon the equations of PV model is represented in Simulink environment as given in Figures 4.7, 4.8 and 4.9.

These models are developed in moderate complexity to include the temperature dependence of the photo current source, the saturation current through the diode, and a series resistance is considered based upon the shackle diode equations described previously. Since the main objective is to develop a functional PV model for the Simulink environment, the system is modelled to supply power to the load.




Figure 4.7: Block diagram of the model based upon the equations of PV model




Figure 4.8: Masked PV module in Simulink




Figure 4.9: The final model of PV system

4.3.3 PV Simulation results and discussions

The model discussed previously and shown in Figures 4.7, 4.8 and 4.9 was simulated under different conditions to evaluate the different characteristics of the PV modules. Figure 4.10 presents the V-I curve of the system simulated in Matlab environment. The simulation has considered 160 strings of 26 series modules parallel connected. The curves show the variations in voltage and current under different irradiation levels and fixed temperature of 25°C. Figure 4.11 presents the P-V curve of the same system under same conditions of temperature and irradiation. These two figures show that the system has one peak at which the system can provide the maximum power.




Figure 4.10: Simulink model of solar panel (160 strings) V-I characteristic curves




Figure 4.11: Simulink model of solar panel (160 strings) P-V characteristic curves

Figures 4.12 and 4.13 present the variations in the I-V and P-V curves under variable temperature and a solar irradiation of 1000W/m². The figures show that the higher the

temperature the lower generated power becomes. Also, the figures show that the generated voltage decreases slightly with the increase in temperature of the cells.




Figure 4.12: Simulink model of solar panel (160 strings) V-I characteristic curves




Figure 4.13: Simulink model of solar panel (160 strings) P-V characteristic curves

CHAPTERS

POWER SYSTEM STUDIES FOR PV INTEGRATION

5.1 Introduction

This chapter introduces the electrical power system studies for the project using ETAP software. The used methodology is as shown in the flow chart of Figure 5.1 below:




Figure 5.1: Electrical power system study methodology flow chart

5.2 Load Flow Study and Analysis Using ET AP

ETAP software uses the buses voltages, flow of current and power in the system, and branches power factor to perform load flow analysis. It is a very powerful software that can analyse the load flow for loop or radial electrical systems. Furthermore, ETAP software is designed to be able to perform different types of load flow analysis based on the custom ~~advices~~ and purposes of the specific case.

The purpose of load flow analysis in ETAP is to build an extensive idea about the behaviour of the power system under different supply and load conditions. It helps electrical power systems planners to design and test the performance of their systems prior to their installation and during their real time operation. It is also used to detect and forecast possible faults or power flow problems to propose the suitable solutions. The load flow Study is capable to define and adjust the parameters of the system for each case separately. ETAP has multiple choices to define the display options based on the user's needs and requirements from load flow analysis.


Load flow analysis in ETAP is based mainly on numerical solutions of systems of differential equations.

2.1 Load flow simulation using ETAP

This section discusses the implementation of Haun substation project simulation with the 14 MW PV plant as presented in Figure 5.2. Figure 5.2 shows the components of the Haun substation in addition to the PV Plant model in ETAP. As discussed earlier in chapter 4, PV arrays are connected through 7 transformers to the 11 kV bus-bars. The latter are connected through 2 step-up transformers to buses 11 and 12 as shown in the figure. The figure shows the load flow results for each one of the buses and branches.

In the figure buses voltages can be seen in per unit (PU). It is important to mention that in Figure 5.2 the PV plant is disconnected. The voltage on the 66 kV bus 1 is 99.12 % while the power of the PV plant is zero. Figure 5.3 shows the system load flow after the connection of PV plant. The voltage at bus 1 has increased to 99.39 % while a total of 11641 kW is flowing from the PV plant to the system. Power factor of the PV plant is approximately 1.


One-Linc Diagram • HOON SUBSTATION 220 kV (Load Flow Analysis With Out PY).



J**.ta.xls Tr<ijffm, QODINSUBSATIDXmkV Eng,W,O MUSTAFAAI,REFAI

Figure 5.2: Load flow simulation with PV disconnected

One-Line Diagram - HOON SUBSTATION 220 kV (Load Flow Analysis With PY)



Jrin 28.tml Projeci:FH-HOONSUBSTATION210kV Eng, SANDMUSTAFAA-REFAI

Figure 5.3: Load flow simulation with PV connected


5.3 Short Circuit Study and Analysis Using ETAP

The ETAP has the functionality of ShortCircuit analysis in electrical distribution systems. It can find the short circuit currents and the contributions of each load in the short circuit. Fault duties are based on the new editions issued by IEC and ANSI/IEEE standards (ETAP, 2016). ETAP presents a very powerful short circuit detection and calculation ability. It is one of the main short circuit analysis software used in power systems by power engineers to estimate the effects of short circuit consequences in power systems.

5.3.1 Short circuit simulation using ETAP

Short circuit analysis was performed onthe substation of Haun without PV plant as shown in Figure 5.4 and with the PV plant connected as shown in Figure 5.5. The figures show the short circuit currents at all buses and branches. It is obvious that the existence of PV plant in Figure 5.5 has increased the short circuit currents slightly at most of buses. However, the increase in short circuit current levels is very small and doesn't introduce extra problems.


One-Line Diagram - HOUNSUBSTATION 220kV (Short-Circuit Analysis With Out PY)



Jun 1B2016 Prajd FUC HOUNSUBSTATION 220kV Eng.SA. fil 31USTAFAAL-REFAI

Figure 5.4: Short circuit simulation with PV disconnected

One-Line Diagram - HOUN SUBSTATION 220 kV (Short-Circuit Analysis With PY)



Jun 28, 2016 Project File: HOUN SUBSTATION 220kV Eng. SAND MUSTAFA AL-REFAI

Figure 5.5: Short circuit simulation with PV connected

5.4 Harmonics Study and Analysis Using ETAP

As a result of the continuously increasing uses of power electronic equipment like variable speed motor drives, UPS systems, power converters, rectifiers, and different power electronic devices, power quality of system's voltage and current is strictly affected in different areas. Components of higher frequencies start to circulate in power systems causing the wave forms of voltage and current to be distorted. Such higher frequency components are integer multipliers of the fundamental frequency which are known by the term harmonics. The harmonic emitting devices are called nonlinear loads and include power electronic switching devices, transformers, motors, fluorescent lights, arc furnaces and many other different devices. Such devices cause very serious problems affecting the power quality of power systems.

The existence of harmonics in any power system causes different problems and effects that include but not limited to over temperature of equipment, low power factor of devices, low performance of electrical components, unexpected behaviours of protective devices, interferences with communication systems, resonance with other equipment that cause failure of these equipment, noise, vibration of electrical motors, and other effects. Over

more, harmonic currents don't stay near to their source; instead, they penetrate the electrical distribution networks and start circulating throughout the electric systems. The circulation of harmonic currents in the electric systems distorts electric voltages fed to the other users and the harmonic problem is accumulated. This phenomenon has become a main hot topic for power quality as a result of the increasing spread of electronic devices and equipment in power systems,

Using computer simulation, the problem of power system harmonics can be modelled and analysed. The ETAP harmonic analysis module offers a great tool to model different power system elements and equipment accurately to study their frequency dependency, nonlinear behaviour, and other effects of the presence of harmonic currents and voltages.

5. Transient Stability Study and Analysis Using ETAP

The ETAP is constructed to study the system's dynamic behaviour and steady state limits of a power system. This study or analysis is implemented before, throughout, and following changes or disturbances in the electric systems. The program implements the events and activities defined by the user to analyse the system. It then determines the response of the system to these events. These analyses are important to determine the protective and design parameters of the system.

Voltage profile is the numerical description of the system voltages at a given point, generally a bus or a node of the electric system at some determined circumstances. Examples of voltage profile are: no load profile, light load profile, full load profile, and finally overload profile. In the most of power systems, voltage is limited to predefined values that shouldn't be exceeded. Some variations in the voltage profile parameters can lead the system to instability. Voltage stability is a description of the ability of the system to preserve steady state parameters and voltages at their state values after different faults or occurrences (Cutsem & Vournas, 1998).

CHAPTER6

RESULTS ANALYSIS OF POWER SYSTEM STUDIES

6.1 Introduction

To simulate a real system, models of each element have to be built and incorporated in the power system simulation software ETAP. This provides the ability to simulate load flow, short circuit, harmonics and stability analysis work in the same software environment. This chapter introduces the results and analysis for electrical power system studies for the project using ETAP software.

6.2 Load Flow Analysis

Load flow analysis is a great tool that produces essential computation practice in order to establish the characteristics of power system under steady state conditions. In this thesis load flow analysis for Haun substation which consists of 42 buses, 14 transmission lines and 26 transformers in addition to switches and circuit breakers as shown in the single line diagram Figure 5.2 and Figure 5.3. Modelling and simulation are carried out by using ETAP simulation software for two cases; first case without PV connection and the second case with PV connection. The results are tabulated as shown in Appendixes 4 and 5.

Tabulated reports show that integrating a PV system into Haun distribution network improves the system voltage profile as can be observed in most of the busses and particularly bus 10 which became normal after it was critical before connecting the PV system. The importance of the load flow analysis is to make sure that the distribution network is safe enough to be connected with PV generators. The results obtained from the load flow study of Haun substation show that the use of PV generators at Houn power station is safe, feasible, and advantageous. It can noticeably improve the voltage stability at each bus of the system, and increase the voltage profile.

6.3 Short Circuit Analysis

The short circuit of power system under consideration is performed to identify the strong and weak buses in the power system under disturbance. The possibilities for a short circuit in three phase system are as follows:

- 1- Symmetrical three phase fault.
- 2- Single Line to Ground fault.
- 3~ Line to Line fault.
- 4- Double Line to Ground fault.

Short circuit analysis basically based on finding the steady state solution of the power system under study. This information is needed to determine the required interrupting capacity of the circuit breakers and to design proper relaying system (Saadat, 2010). To get enough information, different types of faults are simulated at different locations and the study is carried out for two cases; first case, without PV connection to Haun network, and the second case when the PV plant is connected to Houn network. In this thesis the ETAP report results of short circuit studies is tabulated as shown in Appendixes 6 and 7. The reports include the following information:

- 1- Short circuit contributions from all buses connected to the faulted buses or between any other two buses specified in the input, or both.
- 2- Voltage at the remote buses where fault contributions are specified by (I).
- 3~ System X/R ratio at the fault point for medium voltage circuit breaker interrupting duty with its associated multiplying factor.
- 4- Symmetrical and asymmetrical current for breaker momentary duty.
- 5~ Local and remote fault contributions.

The report includes input data, total fault level at each faulted bus, and also contributions from all connecting buses. Short circuit studied diagrams for Haun network as depicted in Figure 5.4 and Figure 5.5 showing all system faulted busses results.

6.4 Harmonics Analysis

Harmonics were presented earlier in this work and they present one of the most important problems in power systems. PV systems can represent a source of harmonics to the grid under some conditions; produced harmonics can be the effect of the solar panels unstable functionality due to variable irradiations or from the power electronic elements used as interface. However, it is important to notice here that modern power inverters provide high power quality factors. The injected harmonics by such inverters are mostly high order harmonics that can be filtered easily.

In this research work simulations were carried out for the system under consideration, to obtain the voltage and current waveforms at bus bars 1 and 2 which are the Point of Common Coupling (PCC), where the study were performed for two cases one without PV connection, and the other with PV connection. Figure 6.1 shows the waveforms of the bus 1 voltage before the connection of PV plant. Figure 6.2 presents the Total Harmonic Distortion (THD) amounts of all buses after connecting the PV plant.





Figure 6.1: Voltage waveform at bus 1 with PV disconnected

One-Line Diagram - HOUN SUBSTATION 220 kV (Harmonic Analysis with PV and No Filters)



Jun1B,1016 Project File: HOUN SUBSTATION 220kV Fig- SA.11JD PdI STAF A AL-REFAI

Figure 6.2: Analysis results of harmonic with PV connected

Figure 6.3 presents the waveform and spectrum of the bus 1 voltage after the connection of the PV plant.





Figure 6.3: Waveform and spectrum of bus 1 voltage after using PV plant

From Figure 6.2 it can be noticed that THD values of voltages at buses 1 and 2 are 2.33 % and 1.15 % respectively. The results show that the injection of solar power through solar inverters causes the injection of voltage harmonics into the power system. However, the THD values after the use of PV plant are still less than 5 % and don't cause any problems according to different international standards like IEC.

To improve the stability condition such as reducing the 5th and higher orders harmonics and reduce the harmonic content in the waveforms, passive filter can be connected at the common coupling busses as shown in Figure 6.4. The figure shows that the use of harmonic passive filters has reduced the THD value of voltage at bus 1 to 0.63 % at bus 1 and 0.41 % at bus 2. It is important to mention here that the filter was tuned specifically to cancel the 11th harmonic as it was the dominant harmonic as shown in Figure 6.3. It is important

to notice that the 11th harmonic was cancelled as shown in Figure 6.5. Another filter tuned at the 13th harmonic could reduce more the THO and increase the power quality at bus 1 and bus 2.

One-Line Diagram - HOUN SUBSTATION 220 kV (Harmonic Analysis With PV and Filters)



Jrm28.10Ui Project#: ROLIN SUBSTATION 12dkV Eng SAND MUSTAFA JREFAJ

Figure 6.4: Harmonic study with filters and PV connection




Figure 6.5: Bus 1 voltage waveform and spectrum with filters and PV connection

The complete reports of the study including THDV value with filters are depicted in the Appendixes 8, 9, 10 and 11.

6.5 Transient Stability Analysis

Stability of power system is the criterion that guarantees it to keep in equilibrium point under normal conditions; also to return to its initial stable conditions after the occurrence of different disturbances. Unacceptable voltage profiles can be the main consequence of the incapability of the system to feed the required reactive power to the load. Under normal operating conditions, the magnitude of the bus voltage boosts proportional to the increase in the injected reactive power on the same bus. However, unstable system occurs when the voltage of the bus decrease with the increase of reactive power injection; The voltage instability is a local problem; however, its effects can spread all over the system due to the relation between active power, reactive power, and bus voltage.

Solar systems are nonlinear configurations because of the discrete operation and existence of the sunlight, in addition to the switching scheme of the power electronic converters and DC-AC inverter devices. The output voltage in a solar system, the generated current, and the produced power are subject to dynamic variations at real time basis. The connection of such type of systems has its side effects on the other different components of the power system and its stability especially the power factor and voltage profile. In this thesis PV plant is integrated at bus 1 and bus 2 as shown previously.

Dynamic voltage stability simulations were carried out using the ETAP software. Simulation results demonstrate that connecting the PV to Houn substation increases the voltage profile at the particular bus bar. Thus, integrating of a PV system into a distribution network improves the system voltage stability.

In transient stability we studied about the behavior of the system under consideration during the disturbance for large interval in both cases. The results are shown in Figure 6.6 and Figure 6.7. The complete reports of the study for both cases are depicted in the Appendixes 12 and 13. Figure 6.6 shows the transient voltage that follows a three phase fault applied to bus 1 and bus 5 with PV disconnected. It demonstrates a voltage change of up to 200 % in bus 1 voltage. After the connection of PV plant, the same fault was executed and results were shown in Figure 6.7. The transient voltage has decreased to 140

% and the time of transient was also decreased. These two figures show that the connection of PV plant help stabilizing the power system and reducing the transient effects.




Figure 6.6: Percentage of bus nominal (kV) without PV connection




Figure 6.7: Percentage of bus nominal (kV) with PV connection

CHAPTER 7

CONCLUSION AND FUTURE WORK

7.1 Conclusion

Libya is very wealthy in the solar energy and gains a huge prospective for solar power generation plants. Solar energy is variable in the nature and depends on the site. The unpredictable nature of this energy source has its great impact on the power system operation and planning. The aim of this specific work is to evaluate the effect of the integration of solar power generator in the city of Houn distribution station in Libya. This aim was achieved by developing the design of PV system to be implemented in Houn substation 220 KV. Sizing of PV system, inverters and cables were obtained.

In order to verify the design validity, different simulation models using MATLAB and ETAP programs have been built and carried out. Real load and solar energy data were used in the simulation to achieve more realistic results that can help for future analysis and planning processes.

Investigation of the impact of 14 MW PV plant on Houn distribution power system in this thesis was carried out and some analyses were established. The first study was concerned by the slow variations in the common coupling point's voltage. The second study was concentrated on the study of short circuit faults at the coupling point of Houn power station. These studies were performed in order to verify whether the Houn substation is capable to hold the planned generation plant. After those studies were performed, another analysis of the voltage stability on Houn station before and after the consideration of the solar plant was carried out. Finally, the effect of PV system on the power quality at the coupling point was studied by using the harmonic analysis tools.

The obtained results from the load flow analysis show that the implementation of PV solar generation station at Houn power distribution station develops the voltage profile and increase the stability of the system. Distribution lines' losses are found to be decreased as an effect of the implementation of the solar system. The applied analyses have shown that the power station of Houn is in good status and its voltage profile is healthy before and after the use of PV generation system.

The implementation of PV plant connected to the station of Houn has shown capability of decreasing the transient effects of buses faults. This means an increased stability compared with the high transient when the PV plant is not connected. The connection of the PV plant has caused the injection of some voltage harmonics that started to spread over the network. However, the amount of generated harmonics was within the international limits stated by different standards. Tuned filters for the dominant harmonics were installed on the connection buses to cancel these harmonics. Analyses have shown that these filters were able to reduce the harmonics significantly.

From the work done in this thesis it can be concluded that the addition of support PV power generation of 14 MW increases the efficiency of the Houn power station and improves the voltage profile of all station buses. After applying a fault at 66 kV and 11 kV busses, it's found that the PV system is capable to develop the voltage steady and dynamic state stability of Houn power distribution station. The PV system responded to the faults by sharing in the voltage recovery during the fault and after it. No system tripping was detected throughout or after the disturbance.

7.2 Future Work

Any scientific research can't cover all aspects and investigates all important points at once; some points need to be reinvestigated and studied in future works. Separately from the studies applied in the course of this thesis work; that seems to be of the highest importance, further studies of the impact of the solar systems on the connected power systems and distribution stations needs to be penetrated. After the integration of DG stations, power flow becomes bi-directional. In this case, different protection and interruption systems need to be studied and introduced into the stations. Future works that are recommended in other stages of this work are:

- 1- The reliability analysis on the distribution station of the security and adequacy of the proposed system especially keeping in mind the intermittent function of PV stations.
- 2- Further studies on the protection profile after the injection of PV generators.
- 3- The frequency stability of the power station under the effects of PV systems.

REFERENCES

- ABB. (2014, Jul). Central Inverters. Retrieved Mar 2016, from Central inverters: https://library.e.abb.com/public/e2508291cc16d124c1257d490049abe5/17237_PV_S800_central%20inverters%20flyer%20EN_3AUA0000057380_RevL_lowres.pdf
- Abdulkadir, M., Samosir, A. S., & Yatim, A. H. (2012). Modeling And Simulatio Based Approach of Photovoltaic System in Simulink Model. *ARPN Journal of Engineering and Applied Sciences*, 7(5), (pp. 616-623).
- Al-Jadi, I. M., EK.hlat,M.A., & Krema, N. M. (2012). Photovoltaic in Libya applications and evaluation. *In the Proceedings of the International Conference on Renewable Energy for Developing Countries.* IEEE. Retrieved Feb 2016 from <http://www.udc.edu/docs/cere/PHOTOVOLTAIC%20IN%20LIBYA.pdf>
- Angelim, J. H., & Affonso, C. M. (2016). Impact of distributed generation technology and location on power system voltage stability. *In the Proceedings of the IEEE Latin America Transactions* (pp. 1758- 1765). IEEE. doi:10.1109/LA.2016.7483512
- Ault, G. W., McDonald, J. R., & Burt, G. M. (2003). Strategic analysis framework for evaluating distributed generation and utility strategies. *In the roceedings of the Generation, Transmission and Distribution* (pp. 475-481). IET. doi:10.1049/ip-gtd:20030374
- Cenergypower. (2014, Sep 1). *String vs. central inverter.* Retrieved Jun 2016, from <http://cenergypower.com/blog/string-vs-central-inverters-choosing-right-inverter/>
- Condon, J. C. (2004). *Distributed Generation as a Potential Solution to United States Electricity Transmission Bottlenecks.* University of Arizona. Retrieved Apr 2016, from <http://www.wise-intern.org/journal/2004/WISE2004.ClayCondon.CompleteDraft.pdf>
- Coster, E., Myrzik, J., Kruimer, B., & Kling, W. (2011). Integration Issues of Distributed Generation in Distribution Grids. *In the Proceedings of the IEEE 99(1)*, (pp. 28-39). IEEE. doi:10.1109/JPROC.2010.2052776
- Cutsem, T. V., & Vournas, C. (1998). *Voltage Stability of Electric Power Systems.* Kluwer Academic Publishers.
- Daley, J. M., ASCO Power Technol., F. P., & Siciliano, R. L. (2003). Application of emergency and standby generation for distributed generation. I. Concepts and hypotheses. *IEEE Transactions on Industry Applications*, doi:10.1109/TIA.2003.813742

Dang, K., Yu, J., Dang, T., & Han, B. (2011). Benefit of distributed generation on line loss reduction. In the Proceedings of the International Conference on Electrical and Control Engineering (pp. 2042-2045). Yichang. doi:10.1109/ICECENG.2011.6057911

Davis, M. W. (2002). Mini gas turbines and high speed generators a preferred choice for serving large commercial customers and micro grids Generating system. In the Proceedings of the Power Engineering Society Summer Meeting (pp. 669-676). IEEE.

Deendayal, U. P. (n.d.). *Advantages and Disadvantages of Photovoltaics*. Retrieved May 2016, from <http://www.sse.pdpu.ac.in/aboutsolar.html>

Dorian, J. P., Franssen, H. T., & Simbeck, D. R. (2006). Global challenges in energy. *Energy Policy*, (pp. 1984-1991).

ETAP. (2016). *Short Circuit Analysis*. Retrieved Apr 5, 2016, from <http://etap.com/short-circuit-analysis/short-circuit-analysis-software.htm>

Hamlyn, A., Cheung, H., Lin, W., Cungang, Y., & Cheung, R. (2008); Distributed monitoring and centralized forecasting network for DG-connected distribution systems. In the Proceedings of the Conversion and Delivery of Electrical Energy in the 21st Century conference (pp. 1-7). IEEE.

Hassan, A. A., Nafeh, A. E.-S., H.Fahmy, F., & El-Sayed, M. A. (2010). Stand-Alone Photovoltaic System for an Emergency Health Clinic. *The Paper Presented at the International Conference on Renewable Energies and Power Quality*. Granada, Spain: ICREPQ.

Hughes, T. P. (1993). *Networks of power: Electrification in Western Society, 1880-1930*. Baltimore: Johns Hopkins University Press.

Ibrahim, I. M., & Khalifa, B. (2003). The role of using PV system in changing the infrastructure of power generation in Libyan Communication network. *The paper Presented at the Second Engineering Conference, Benghazi*. Benghazi, Libya. Retreived May 6, 2016, from: <http://www.udc.edu/docs/cere/PHOTOVOLTAIC%20IN%20LIBYA.pdf>

Lin, W., Hamlyn, A., Cheung, H., Yasin, R., Li, C., & Cheung, R. (2009). Network-aided strategy and breaker impacts on voltage instability corrective actions for power systems with DGs. In the Proceedings of the Power & Energy Society General Meeting (pp. 1-7). IEEE.

Liu, J., Zhang, W., Zhou, R., & Zhong, J. (2012). Impacts of distributed renewable energy generations on smart grid operation and dispatch. In the Proceedings of the IEEE Power and Energy Society General Meeting (pp. 1-5). San Diego, CA: IEEE. doi:10.1109/PESGM.2012.6344997

- Luque, 'A. (2011). WiH we exceed 50% efficiency in photovoltaic. *Journal of Applied Physics*, 31301-31319.
- MathWorks. (2016). *SIMULINK*. Retrieved Aug 4, 2016, from MathWorks: <http://uk.mathworks.com/products/simulink/>
- Mondal, A. H., & Denich, M. (2009). Hybrid systems for decentralized power generation in Bangladesh. *Energy/or Sustainable Development*, 14(1). (pp. 48-55).
- Nazari, M. H., & Ilic, M. (2008). Potential Problems and Solutions Associated with Distributed Generation. *Paper Presented at the 4th Carnegie Mellon Electricity Industry Conference*. Pittsburgh, US. Retrieved Apr 10, 2016, from: https://www.ece.cmu.edu/~electricconf/2008/PDFs/Nazari_Ilic_CEIC%20paper.pdf
- Nishida, Y., Nakamura, S., Aikawa, N., Sumiyoshi, S., Yamashita, H., & Omori, H. (2003). A novel type of utility-interactive inverter for photovoltaic system. In the *Proceedings of the 29th Annual Conference in Industrial Electronic Society* (pp. 2338-2343). IEEE.
- Olulope, P. K., Folly, K. A., & Venayagamoorthy, G. K. (2013). Modeling and simulation of hybrid-distributed generation and its impact on transient stability of power system. In the *Proceedings of the IEEE International Conference on Industrial Technology* (pp. 1757-1762). Cape Town.doi:10.1109/ICIT.2013.6505941
- Paolone, M., & Cherkaoui, R. (n.d.). *Distributed electrical systems laboratory*. Retrieved Jun 2016, from <http://desl-pwrs.epfl.ch/>
- Pilavachi, P. (2002). Mini- and micro-gas turbines for combined heat and power. *Applied Thermal Engineering*, :2003-2014.
- Rashid, M. H. (2001). *Power Electronics Handbook*. Academic Press.
- Saadat, H. (2010). *Power System Analysis*. NewYork, USA: PSA Publishing.
- Saleh, I. M. (2006). Prospects of renewable energy in Libya. In the *Proceedings of the International Symposium on Solar Physics and Solar Eclipses*, (pp. 153-161).
- Solargis. (2016). *Solar map in Libya*. Retrieved May 2016, from Solargis: <http://solargis.com/products/maps-and-gis-data/free/overview/>
- Spera, D. A. (2009). *Wind Turbine Technology: Fundamental Concepts in Wind Turbine Engineering*. ASME.
- Steffel, S. J., Caroselli, P. R., Dinkel, A. M., Liu, J. Q., Sackey, R. N., & Vadhar, N. R. (2012). Integrating Solar Generation on the Electric Distribution Grid. In the *Proceedings o/the IEEE Transactions on Smart Grid*. IEEE (pp. 878- 886).

- Suniva. (2010, Jun). *ART245-60 datasheet*. Retrieved Aug 2, 2016, from Suniva: <http://www.suniva.com/documents/suniva ART245-60-3%2006091O.pdf>
- The grid as it is today. (2016, Mar). Retrieved May 2016, from altenergymag: <http://www.altenergymag.com/stream/articles/>
- Therien, S. G. (2010). *Distributed Generation: Issues Concerning a Changing Power Grid Paradigm. Master Thesis*. San Luis Obispo: California Polytechnic State University.
- Taorin, L. (2006). *Combining wind and solar energy to meet demands in the built environment. Master Thesis*. Glasgow, Scotland: Strathclyde University.
- UNFCCC. (2012, Nov). *Hun 14 MW Photovoltaic Power Plant by REAOL, Libya*. Retrieved Mar 2016, from <http://cdm.unfccc.int/Projects/DB/RWTUV1356073216.09/view>
- Williamson, R. H., & Ogden, J. M. (1989). *Solar hydrogen: Moving beyond fossil fuels*. World Resources Institute.
- Yadav, A., & Srivastava, L. (2014). Optimal placement of distributed generation: An overview and key issues. In the *Proceedings of the 2014 International Conference on Power Signals Control and Computations* (pp. 1-6). Thrissur: IEEE. doi:10.1109/EPSCICON.2014.6887517
- Yusof, Y. (2004). Modeling and Simulation of maximum power point tracker for Photovoltaic system. In the *Proceedings of the National Power and Energy Conference* (pp. 88-93). Kuala Lumpur, Malaysia.
- Zhao, D., Li, Y., & Liu, Y. (2014). Optimal design and sensitive analysis of distributed generation system with renewable energy sources. In the *Proceedings of the China International Conference on Electricity Distribution* (pp. 456-460). Shenzhen. doi:10.1109/CICED.2014.6991749

APPENDICES

APPENDIX 1
HOUN SUBSTATION LOADS

MEDIUM VOLTAGE NETWORK MANAGEMENT CONSOLE

DETECTING LOADS TRANSFORMERS (66/30/11 kV)

	SUB STATION	NUMBER	VOLTAGE	CAPACITY MVA	MW	TOTAL
1	HOUN	1	66/11	20	7	9
		2	66/11	20	2	
2	ALKADEA	1	66/11	20	5	16
		2	66/11	20	11	
3	WEDDAN	1	66/11	20	3.5	9
		2	66/11	20	5.5	
4	ALFORJAN	1	66/11	15	6	12
		2	66/11	15	6	
5	ALKASEER	1	66/11	20	3	3
		2	66/11	20	0	
6	ZALLA	1	66/11	10	5	7
		2	66/11	10	2	
7	ZALLA ROAD TRANSFORMER	1	66/11	10	6	6
8	HOUN 220	1	66/11	10	0	0

APPENQIX2

MODULE DATASHEET

Suniva® ART245-60 Monocrystalline Solar Modules

ELECTRICAL DATA (NOMINAL)

The electrical data apply to standard test conditions (STC): Irradiance of 1000 W/m² with AM 1.5 spectra at 25°C.

Power Classification (Max.)	Pmax (W)	235	240	245
Voltage at Max. Power Point	Vmp (V)	30.00	30.40	30.90
Current at Max. Power Point	Imp (A)	7.84	7.89	7.95
Open Circuit Voltage	Voc (V)	37.30	37.30	37.40
Short Circuit Current	Isc (A)	8.38	8.44	8.49

The rated power may only vary by -0/+4.99 Wp and all other electrical parameters by ± 5%.

DIMENSIONS AND WEIGHTS

Cells / Module	60
Module Dimensions	1657 x 987 mm; 65.24 x 38.86 in.
Mounting Holes (Depth)	42 mm; 1.65 in.
Approximate Weight	19 kg; 42 lbs.

CHARACTERISTIC DATA

Type of Solar Cell	High-efficiency Suniva® 3 busbar monocrystalline cells of 156 x 156 mm
Frame	Silver anodized aluminum alloy
Glass	Anti-reflective coating; tempered & low-iron
Junction Box	IP67 rated; IEC & UL listed; with internal bypass diodes
Cable & Connectors	4 mm ² cable with MC4 connectors; cable length approximately 1 m

TEMPERATURE COEFFICIENTS

Voltage	β_v ; Voc (%/°C)	-0.332
Current	α_i ; Isc (%/°C)	+0.036
Power	γ_p ; Pmax (%/°C)	-0.460

LIMITS

Max. System Voltage	1000 VDC
Operating Module Temperature	-40°C to +90°C
Storm Resistance	Tested to IEC 61215 for wind loads of 5400 Pa (204 mph)

SUNIVA® reserves the right to change the data at any time.



10/06/10


APPENDIX3

ABB CENTRAL INVERTER

ABB central inverters

PVS800

100 to 1000 kW



Technical data and types

Type designation	-0100kW-A	-0250kW-A	-0315kW-B	-0500kW-A	-0630kW-B	-0975kW-B	-1000kW-C
PVS800-57	100 kW	250 kW	315 kW	500 kW	630 kW	875 kW	1000 kW
(Input (DC))							
Maximum input power ($P_{DC,max}$) ^{a)}	120 kWp	300 kWp	378 kWp	600 kWp	756 kWp	1050 kWp	1200 kWp
DC voltage range, mpp ($U_{DC,mpp}$)	450 to 825 V	450 to 825 V	525 to 825 V	450 to 825 V	525 to 825 V	525 to 825 V	600 to 850 V
Maximum DC voltage ($U_{DC,max}$)	1000 V	1000 V	1000 V	1100 V	1100 V	1100 V	1100 V
Maximum DC current ($I_{DC,max}$)	245 A	600 A	615 A	1145 A	1230 A	1710 A	1710 A
Number of protected DC inputs	1 (+/-) / 2	2, 4, 8 (+/-)	2, 4, 8 (+/-)	4 to 15 (+/-)	4 to 15 (+/-)	8 to 20 (+/-)	8 to 20 (+/-)
(Output (AC))							
Nominal power (P_{AC}) ^{b)}	100 kW	250 kW	315 kW	500 kW	630 kW	875 kW	1000 kW
Maximum output power ^{c)}	100 kW	250 kW	345 kW	600 kW	700 kW	1050 kW	1200 kW
Power at cosφ = 0.95 ^{d)}	95 kW	240 kW	300 kW	475 kW	600 kW	830 kW	850 kW
Nominal AC current (I_{AC})	165 A	485 A	520 A	965 A	1040 A	1445 A	1445 A
Nominal output voltage (U_{AC}) ^{e)}	300 V	300 V	350 V	300 V	350 V	350 V	400 V
Output frequency	50/60 Hz						
Harmonic distortion, current ^{f)}	< 3%	< 3%	< 3%	< 3%	< 3%	< 3%	< 3%
Distribution network type ^{g)}	TN and IT						
Efficiency							
Maximum ^{h)}	90.0%	90.0%	90.0%	90.6%	90.6%	90.7%	90.8%
Euro-ela ⁱ⁾	97.5%	97.5%	99.3%	90.2%	90.4%	99.5%	99.6%
Power consumption							
Own consumption in operation	310 W	310 W	310 W	490 W	490 W	650 W	650 W
Standby operation consumption	60 W	60 W	60 W	65 W	65 W	65 W	65 W
External auxiliary voltage ^{j)}	230 V, 50 Hz						
Dimensions and weight							
Width/Height/Depth, mm (W/H/D)	1030/2130/690	1830/2130/690	1830/2130/680	2630/2130/708	2630/2130/708	3530/2130/708	3630/2130/708
Weight appr. ^{k)}	550	1100	1100	1800	1800	2320	2320

^{a)} RecoinOOClOO imitin.mlip.l pc.t,w

" il- 101"

^{b)} Forline~ ~ or ptole:fei Inputs.

~ 08>tunl MCS irp..ii:0.0 A lrlpIS

" Al nomruipower

500 t.u.i iFA! mil.matioc dola.us.

:1 looarai2sov...voonsa4o;c. aisuunti


" ivienet Sldl rmis bl Ilyp-0

ese K/tat 4S ~c, sco, im; aici 100.0 ~W al so "C

" wiinout arionuy p<Harix,nimwmpional min u.,,

" Af:is•c.soo1oomEtmurri:u;toi~

" 11s V. so Hi opt:na



APPENDIX4

LQAI> FLOW ANALYSIS WITHOUT PV

Project: IMAST.ERTHESIS
 Location: HOUN CITY >LIBYA
 Contract: NEAR EAST UNIVERSITY, EEE Department
 Engineer: SAND~fiSTAFAAL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP

12.6.0H

Study Case: LF

Page: 1

Date: 28-06-2016

Stl:

Roslon: Base

Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Electrical Transient Analyzer Program

Load Flow Analysis (Without PV)

Loading Category (1)---Design

Geographical Category (1): Design

Load Diversity Factor: None

	String	V-Control	Load	Total
Number of Buses:	3	0	26	29

	XFLIR.2	XFLIR3	Reactor	Line/Cable	Impedance	Tie PD	Total
Number of Branches:	15	0	0	14	0	0	29

Method of Solution: Adaptive Newton-Raphson Method

Maximum No. of Iterations: 99

Precision of Solution: 0.0001000

System Frequency: 50.00Hz

Unit System: Metric

Project: MASTER THESIS
Location: HOUN CITY - LIBYA
Contract: I\EAR E,OSTUNI\VERSITY -EEE Department
Engin ** r: SA'IDI\USTAFAAL-REFAI
Filename: HOUN SUBSTATION 220kV

ETAP
12.6.0H

Study Case: LF

Page: 2
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

<u>Adjustments</u>		Apply	Individual	Percent
Tolerance	Adj~			
Transformer Impedance:	Y<S	IndMdu,1		
Reactor Impedance:	Yt	Indhidunl		
0\el'lona Heater Resistance:	No			
Transmission Line Length:	No			
Cable Length:	No			
		Apply	Individual	Percent
Teiperanire Col'rection		Adj~	/Global	~
Transmission Line Resistance:	Yts	Indhidunl		
Cable Resistance:	Yts	Indhidu,1		

Project: MASTER1HES1S ETAP
 Location: HOUNCITY LIBYA 12.6.0H
 Contract: NEAR.EASTUNIVERSITI-EEE D.department
 Engineer: SANI>I>IUSTAI'AAL-REFA,I Study Case: LF
 Filename: HOUNSUBSTATION20kV Rel'isou: Base
 Config: Normal

DESIGN OF ALARCESCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION TO LIBYAN POWER GRID

Bus Input Data

Bus	ID	kV	Sub-sys	Initial Voltage		Com.1mttkYA		Com.Hanz.		Comantl		Gt'ueric	
				%Mag.	Ang.	MW	Mn,r	MW	Mvar	MW	Mvar	MW	~fr. If'
Bus1		66.000	1	~	~								
Bus2		66.000	1	99.1	-1.1								
Bus3		210.000	1	100.0	0.0								
Bus4		220.000	3	100.0	0.0								
Bus5		220.000	1	100.0	ae								
Bus6		11.000	1	95.3	-1.2	0.000	0.995	0.000	0.000				
Bus7		66.000	1	99.0	-1.2								
Bus8		66.000	1	99.3	-4.3								
Bus9		11.000	1	95.4	-1.8	1.600	0.992	0.400	0.000				
Bus10		11.000	1	98.0	-6.3	5.600	3.471	1.400	0.568				
Bus13		66.000	1	96.6	-4.7								
Bus14		66.000	2	98.1	-1.7								
Bus15		11.000	1	99.0	-7.6	4.800	1.111	1.200	0.744				
Bus16		11.000	2	98.6	-4.7	4.800	2.975	1.200	0.744				
Bus17		66.000	1	99.2	-5.9								
Bus18		66.000	1	99.0	-1.6								
Bus19		11.000	1	99.0	-7.5	4.400	0.000	1.100	0.000				
Bus20		11.000	1	98.9	-2.6	1.800	0.000	0.700	0.000				
Bus21		66.000	1	99.1	-6.5								
Bus22		11.000	1	98.1	-9.4	4.800	0.000	1.200	0.000				
Bus23		66.000	1	99.5	-6.9								
Bus25		11.000	1	98.4	-1.9	1.600	0.991	0.400	0.000				
Bus27		66.000	1	99.1	-1.9								
Bus28		11.000	1	98.7	-5.8	2.400	1.487	0.600	0.372				
Bus29		11.000	1	98.7	-5.8	2.400	U&I	0.600	un				
Bus30		66.000	1	98.8	-4.6								
Bus31		66.000	1	98.8	-1.4								
Bus32		11.000	1	98.3	-7.8	8.800	8.455	2.200	1.364				
Bus33		11.000	1	100.7	-2.8	4.000	2.479	1.000	0.620				
Total Number of Buses:	29			41.999		23.307		12.000	5.877	0.000		0.000	0.000

Project: TUTORIAL THESIS
 Location: HOUN (JIT) - LyYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SANDALUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: LF

Page: 4
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO L1AN POWER GRID

Generation Bus				Voltage		Generation			Mvar Limits	
ID	kV	Type	Sub-sys	%Mdg.	Ang°	MW	lfran	%PF	Max	Min
Bus3	220.000	Smug	1	100.0	0.0					
Bu-f	110.000	Smug	3	100.0	0.0					
Bu.S	220.000	Sling	2	100.0	0.0					
						0.000	0.000			

Project: IMAISIER THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR EAST UNIT:VERSITI -EEE Depal'tment
 Engineer: SA.I.-AII, SLFAAL-RF, FAI
 FilonamfCHOUN SISSTATIOHIL 120kV
 ETAP
 12.6.0H
 Page: 5
 Date: 18-06-2016
 SN:
 Revsien: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Line/Cable Properties

Ohms per Siemens/100m per Conductor (Cable) or per J.h.e (Line)

Line/Cable	ID	Lib/Type	Size	Length		T (C)	R	X	V
				Adj.(m)	% Tol				
Lin.1			674	1000.0	0.0	1	0.056003	0.374155	0.000031
Lin.1			674	1000.0	0.0	1	0.056001	0.341069	0.000034
Lin.3			674	23000.0	0.0	1	0.056001	0.342069	0.000034
Lin.4			674	15000.0	M	1	0.056001	0.342069	0.000034
Lin.5			674	8000.0	0.0	1	0.056001	0.341069	0.000034
Lin.6			674	4000.0	0.0	1	0.056001	0.342069	0.000034
Line7			674	4000.0	0.0	1	0.056001	0.341069	0.000034
Line8			674	4000.0	0.0	1	0.056001	0.341069	0.000034
Lin.9			674	4000.0	M	1	0.056001	0.341069	0.000034
Lind.0			674	8000.0	0.0	1	0.056001	0.341069	0.000034
Lindi			674	8000.0	0.0	1	0.056001	0.341069	0.000034
Line12			674	11000.0	0.0	1	0.056001	0.341069	0.000034
Lin.13			674	16100.0	0.0	1	0.056001	0.342069	0.000034
LineU			674	140000.0	0.0	1	0.056001	0.341069	0.000034

Line-Cable resistances are listed at the specified temperatures.

Proj<ct: MASTER.THESES
 Location: HOUNCITY-LIBYA
 Contrct: NEAREASTUNIVERSITY-EEE Department
 Enginutr: SANDmisTAFAL-REFAI
 Filenam: HOUNSUBSTATION20kV

ETAP

12.6.0H

Page: 6
 Date: 28-06-2016
 SN:
 Rtiisou: Base
 Nomftg: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT Al-YYSISOF ITS:Nil.GR.ATIONNil.YTO UBVANPOWER GRID

2-'''indJug Trausfonner Imm-ID.-ta

Trmu,funnei-	ID	Phfa	!IVVA	Rating			ZVariation		%Tap.Setting		AdjuSted		Phase Shift			
				Prim.ev	Stt.kV	%ZI	XJIIU	±%	\$.%	,Tol,	Prim.	see,	% Z	Tint	Angle	
T1	J.J>Jns,	63.000	710,000	66.000	12.50	45.66	~	~	0	~	~	~	3.7;0	11.5000,	D>JII	0.000
TS	3.phau,	63.000	220,000	-~.000	12.50	~.800	0	0	0	0	0	0	0.61-	12.5000	Dyu	0.000
T4	J-Phs,	10.000	66.000	il.ODO	8.3\$	U.00	0	0	0	0	0	0	0	8.3500	Di-u	0.000
TS	3.pi.,	10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	0	0	10.0000	Di.II	0.000
T6	J.rh.,	10.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	1.2so	10.0000	Di.II	0.000
T9	J.pJin,	10.000	66.000	11.000	8.15	13.00	0	0	0	0	0	0	4.375	8.3500	D>u	0.000
TIO	3-Ph.int	10.000	66.000	11.000	8.15	U.00	0	0	0	0	0	0	4.7\$	8.3500	Dyn	0.000
TU	3-Ph.m	20.000	66.000	IJ.000	10.00	20.00	0	0	0	0	0	0	0	10.0000	D>JII	0.000
ria	3-Plns,	10.000	66.000	J1.000	10.00	20.00	0	0	0	0	0	0	0	IMO00	Di-u	0.000
T13	3-Pb•,	10.000	66.000	11.000	8.35	IMO	0	0	0	0	0	0	0	8.3500	Di.II	0.000
T14	i.rumu	10.000	66.000	11.000	8.35	I.100	0	0	0	0	0	0	0	8.1500	Dyn	0.000
T16	3-Ph><	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	0.615	10.0000	D>JII	0.000
T17	3-Plns,	10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	0	0.625	10.0000	D>u	0.000
TJ8	3.Plnse	20.000	66.000	il.ODO	10.00	10.00	0	0	0	0	0	0	3.750	10.0000	Di.I	0.000
T19	3-Ph>st	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	3.750	10.0000	Dyn	0.000

Project: MASTER THESIS
 Location: HOUN GUY-LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SANDJIUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: LF

Page: 7
 Date: 28-06-2016
 -SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Branch Connections

Ckt/Branch	ID	Tip,	Connected Bus ID		% Impedance, Pos. Seq., 100 MVA Base			
			From Bus	To Bus	R	X	Z	y
T1		2wmm	Bus3	Bus4	0.46	20.58	20.99	
T3		IWXI'IIR	Bus5	Bus1	0.44	19.96	19.97	
T4		2wmm	Bus1	Bus6	6.40	83.25	83.50	
TS		2WXI'IIR	Bus7	Bus9	2.50	49.94	50.00	
T6		2WXIIIIR	Bus5	Bus10	1.S3	50.56	50.63	
T9		2wxnm	Bus12	Bus15	6.68	86.90	87.15	
T10		2WXIIIIR	Bus4	Bus16	6.68	86.90	87.15	
T11		I\X'I'IIR	Bus7	Bus19	2.S0	49.94	50.00	
T12		-WXFAIR	Bus8	Bus110	2.50	49.94	50.00	
T13		2WXI'IIR	BusU	Bus22	6.40	83.25	83.50	
T14		ZWXI'IIR	Bus3	Bus5	6.40	S3.25	83.50	
T16		ZWXEMR	Bus27	Bus28	2.81	50.25	50.31	
T17		2wmm	Bus27	Bus29	2.51	\$0.25	50.31	
T18		IWXThfR	Bus<0>	Bus13?	2.59	51.81	51.88	
T19		2wmm	Bus31	Bus33	2.59	51.81	S1.88	
Line1		Lhe	Bus2	Bus14	2.48	16.58	16.77	0.2607629
Line2		U..	Bus1	Bus3	2.48	15.16	15.16	0.2842267
Line3		Lin.	Bus1	Bus18	2.96	18.06	18.10	0.1387157
Line4		Lin	Bus27	Bus<17	1.91	11.78	11.94	0.2709015
Line5		Lin.	Bus1	Bus17	1.03	6.28	6.37	0.1178142
Lin.6		Lin.	Bus1	Bus7	0.81	3.11	3.18	0.0589071
Line7		U..	Bus1	Bus5	0.51	3.14	3.18	0.0589071
Line8		Lin.	Bus1	Bus7	0.51	3.14	3.18	0.0589071
Lin.9		U..	Bus1	Bus8	0.81	3.14	3.18	0.0589071
Line10		Lin	Bus1	Bus11	1.03	6.28	6.37	0.1178141
Line11		U..	Bus1	Bus30	1.03	6.28	6.37	0.1178142
Line12		Lin.	Bus1	Bus11	2.70	16.49	16.71	0.3092622
Line13		Lin.	Bus17	Bus23	20.70	IM.43	128.11	1.3710100
Line14		Line	Bus2	Bus<23	18.00	109.94	N1.1E	2.0617480

Project:	MASTER THESIS	ETAP	Page:	8
Lorariou:	H01.IIN CITY LIBYA	126-0H	Date:	28.06.2016
Contract:	\NAREASTUNIVERSITY-EEE Department		&N:	
Enginner:	SANDMUSTA'AAL-REFAI	StudyC., Lf.	Region:	Base
Filename:	H01.IIN SUBSTATION220kY		Config:	No'linal

DESIGN OF A LARCE SCAL SOLAR PV SYSTEM AND IMPACT OF ITS INTEGRATION INTO LIBYAN POWER GRID

LOADFLQW REPORT (Without PV)

Bus	Voltage			Generation		Load		LoadFlow			XFMR		
	ID	kV	%Mag.	Ang.	At(Y	Mvar	MW	PFrat	?AV	PFrat	Alnp	%PF	%Tap
Bu.1		66.000	9U18	-5.1	0	0	0	0	Jin'13	6.017	3.96	63.6	83.5
									Bus7	19.1S	1.1SS	172.6	99.8
									Bu'8	3.419	1.216	36.7	83.7
									Bu'8	3.419	2.216	36.1	83.7
									Bu'30	lo.979	7.688	118.3	81.9
									Bu'3	-IMN	-18.606	417.3	91.9
									Bu'6	0.001	1.Z.LI	11.0	0.1
									But4	6.009	3.9%	63.8	83.3
									Buds	3.488	-0.216	30.9	99.8
									Bu.7	0.994	MIZ	1e.1	86.7
									Bu.7	0.994	0.S7I	1e.1	86.7
									Bu'31	-SOU	J.198	SI.7	84.4
									Bu.S	-16.807	S.089	161.7	89.8
*Bus.1		210.000	100.000	0.0	43.SZ	2M66	0	0	Bu.!	43.582	23.466	I29.9	88.0
*BlhS		220.000	100.000	0.0	16.SII	8.78.1	0	0	Bu'2	16.SII	8.783	49.1	88.1
Bu.6		11.000	98.071	-<1	0	0	0.000	1.p!	Bu.3	0.000	-L234	66.0	0.0
Bu.7		66.000	98.828	-1.9	0	0	0	0	Bu.4	-ll.994	-ll.629	10.4	84.5
									Ba'2	-ll.994	-D.629	10.4	84.5
									Bu.9	1.987	1.249	20.8	84.5
Bu'8		66.000	99.027	.S.?	0	0	0	0	Bud	-3.478	-1.329	\$7.0	SJI
									Bu.1	-3.478	-2.329	37.0	83.1
									B*tIO	6.986	4.657	73.9	83.1
Bu.9		11.000	9S.U6	-1.8	0	0	1.986	1.231	Bus7	J.986	-1.%31	124.9	85.0
BusIO		11.000	97.770	-7.2	0	0	6.938	4.J0I	Bu'8	-6.938	4.301	433.2	85.0
BusI3		66.000	98.344	-M	0	0	0	0	Bu.!	5.004	-J.158	65.0	8%.1
Bu.14		66.000	98.015	-U	0	0	0	0	BusI5	6.004	4.158	65.0	BZ
									Bu'2	-5.996	-J.155	65.1	82.2
									Bu.16	5.996	4.155	65.1	82.1
Bu.1S		11.000	98.691	.S.S	0	0	S.96S	M99	Bu'13	<.968	-3.699	J7J.4	BS.0
Bud&		U.000	98.339	.S.4	0	0	S.960	3.694	Bu.U	-S.960	J.694	JU.1	85.0
BusI7		66.000	98.917	-6.8	0	0	0	0	Bum	-ll.472	2.810	121.7	-9.9
									Bu'21	6.60I	-1.319	S9.3	-98.1
									Bu.23	1.390	J.644	19.0	44.6
									Bu.19	S.480	O.ID	48.5	100.0
Ba.18		66.000	98.765	-1.8	0	0	0	0	Bu.Z	-3.484	-ll.062	J0.9	100.0
									BusIO	3.484	0.062	30.9	100.0

Project: MASTERS THESIS
 Location: HOVN CITY, LIBYA
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engineer: SAID TAWFIK AL-REFAI
 Filename: HOUN SUBSTATION 220KV

ETAP
 12.6.0H
 Study Case: LF
 Revisior: Base
 Config: Normal

Pag.: 9
 Date: 28-06-2016
 SN:
 %Tap

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus	Voltage	Generation	Load Ad			ID	Load Flow			XFMR				
			ID	kV	%Mag.	Ang.	MW	Mvar	MWhr	Mrar	Amp	%PF	%Tap	
Bus19	11.000	98.740	.8.4	0	0	0	MI	0.000	Bu,17	.5.412	0.000	290.9	100.0	
Bus20	11.000	98.661	-3.3	0	0	0	3481	0.000	Bu,18	-1.481	0.000	IS,Z	100.0	
Bus21	66.000	98.938	-7.8	0	0	0	0	0	Bu-U	-6.690	1.091	\$9,I	-98.7	
									Bus3	-MOJ	-1.198	13,S	-~9.6	
									Bus51	5.986	0.106	SM	99.9	
Bus22	11.000	98.422	-JM	0	0	0	5862	0.000	Bu,11	.5.862	0.000	SIS,e	100.0	
Bus23	66.000	99.161	.7.9	0	0	0	0	0	Bu,17	-1.1SS	-0.656	13.5	90.4	
									Bu,11	-M03	-M7I	7.6	69.6	
									Bu-S	1.988	1.M	IU	SU	
Bus25	11.000	98.077	.8.	0	0	0	1.984	1.130	Bu,H	-1.884	1.110	II4&	85.0	
Bus27	66.000	98.847	.8.	0	0	0	0	0	Bus2	13.709	-1.797	11.1	-91.9	
									Bus1	-19.418	-1.026	17M	99.9	
									Bus3	2984	1.911	3L,I	84.2	
									Bm9	2884	1.912	3U	84.1	
Bus28	11.000	98.428	-6.1	0	0	0	2.981	LS-18	Bu,17	-2JS1	4.81S	187.0	85.0	0.625
Bus29	11.000	98.428	-6.7	0	0	0	1.981	LS-18	Bu,27	-2881	-1.848	[87.0	85.0	0.625
Bus30	66.000	98.81\$	-\$	0	0	0	0	0	Bus1	-10\$61	-7.688	US&	81.9	
									Bus,31	10&61	7.688	118.9	81&	
Bus31	66.000	98.594	.1.1	0	0	0	0	0	Bus1	-M19	-3.190	53.I	SM	
									8*33	S.019	3.190	53.I	83.6	
Bus32	11.000	98.036	.S.7	0	0	0	1asU	6.768	Bus,0	-IO&U	-6.768	68LS	85.0	3.750
Bus33	11.000	100.463	.),5	0	0	0	5.009	s.es	Bl>31	-5.009	-3.105	307.9	81.0	...0

* Indicates a voltage regulated bus (voltage controlled or swing type machine connected to it)

indicates a bus with a load mismatch of more than 0.1 MVA

Project:	MASTER THESIS	ETAP	Page:	10
Location:	HOUN CITY - LIBYA	12.6.0H	Date:	28-06-2016
Contract:	NEAR EAST UNIVERSITY - EEE Department		SN:	
Engineer:	SAND MUSTAFA AL-REFAI	Study Case: LF	Revision:	Base
Filename:	HOUN SUBSTATION 220kV		Config:	Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus	ID	kV	Rattd Amp	Daily Converged Load								Total Bus Load		
				Cont-ndly		C _{onstant}		Com-mu		Gtun:		MVA	% PF	Amp
				An	Mnrr	i(f)	lh-ar	InV	Not	AIW	lf wir			
Bus.1		10.000										0	0.0	
Bus1		66.000	0	0	0	0	0	0	0	0	0	47.188	91.9	4174
Bus1		66.000	0	0	0	0	0	0	0	0	0	18.491	89.3	163.6
Bus3		110.000	0	0	0	0	0	0	0	0	0	49.498	88.0	129.9
Bus5		210.000	0	0	0	0	0	0	0	0	0	18.711	88.3	49.1
Bus6		11.000	0	0.995	0	0.239	0	0	0	0	0	1.234	0.0	66.0
Bu.7		66.000	0	0	0	0	0	0	0	0	0	1.332	84.5	10.8
Bus8		66.000	0	0	0	0	0	0	0	0	0	1.371	83.1	73.9
Bus9		11.000	UOO	0.997	0.185	0.119	0	0	0	0	0	1.336	85.0	114.9
Bus10		11.000	S.600	3.471	1.338	0.830	0	0	0	0	0	8.163	SS.0	4.18.1
Bud.1		66.000	0	0	0	0	0	0	0	0	0	7.403	82.1	65.0
Bu.11		66.000	0	0	0	0	0	0	0	0	0	7.294	82.2	65.1
Bu.15		11.000	4.000	2.975	LitiF	0.724	0	0	0	0	0	7.011	85.0	373.4
Bus16		11.000	4.000	2.975	J.160	0.719	0	0	0	0	0	7.012	85.0	374.1
Bu.17		66.000	0	0	0	0	0	0	0	0	0	13.794	97.7	12M
Bus18		66.000	0	0	0	0	0	0	0	0	0	3.485	100.0	36.9
Bu.19		11.000	4.400	0	1.071	0	0	0	0	0	0	1.771	100.0	190.9
Bus20		11.000	1.800	0	0.681	0	0	0	0	0	0	3.481	100.0	185.1
Bus21		66.000	0	0	0	0	0	0	0	0	0	6.736	97.8	59.6
Bu.22		11.000	4.000	0	1.162	0	0	0	0	0	0	5.962	100.0	318.6
Bus23		66.000	0	0	0	0	0	0	0	0	0	2.363	84.1	20.8
Bus24		11.000	1.600	0.991	0.38;	0.238	0	0	0	0	0	2.134	85.0	124.9
Bus27		66.000	0	0	0	0	0	0	0	0	0	19.880	98.1	175.7
Bu.28		11.000	2.100	1.487	0.381	0.360	0	0	0	0	0	3.107	85.0	187.0
Bum		11.000	1.400	US,	essi	0.60	0	0	0	0	0	3.80	SS.0	181.8
Bus30		66.000	0	0	0	0	0	0	0	0	0	13.388	SU	118.9
Bus31		66.000	0	0	0	0	0	0	0	0	0	d.001	83.6	SJ.?
Bus31		11.000	UOO	5.455	Z.IU	1.111	0	0	0	0	0	11.841	85.0	687.8
Bus33		11.000	4.000	2.479	1.009	0.626	0	0	0	0	0	8.893	SS.0	307.9

" Indikatt.soprtingload on bus esceeds die bu critftlimit(100.0)9.orht Cam:inuousAmpftrating)-# in dirn.tts. operatingload of f bus esceeds the bu marginal limit (95.0% of the CofinuousAmpftrating);

Project: JIASIER THESIS
Location: HOUN CITY - LIBYA
Contract: NEAR EAST UNIVERSITY -EEE Department
Engineer: SAID ALI STAFIA AL-REFAI
Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
Studly Case: LF
Rerisou Base
Config: Normal

Page: 11
Date: 28/06/2016
SN:

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO THE LIBYAN POWER GRID

Branch Loading Summary Report

Circuit / Branch	ID	Type	Cable & Reactor			Transformer		
			Ampacity (Amp)	Rating (Amp)	Capacity (MVA)	Rating (Input)	Rating (Output)	
T1		Transformer			63.000	49.498	18.6	47.288
T1		Transformer			63.000	18.712	29.7	18.382
T4		Transformer			10.000	U47	N.S	I.Z.L1
T5		Transformer			20.000	Z.352	I.I.S	2.336
T6		Transformer			20.000	8.371	41.9	8.163
T9		Transformer			10.000	7.303	73.0	7.021
T10		Transformer			10.000	7.294	72.9	7.001
T11		Transformer			20.000	5.482	27.4	S.472
T12		Transformer			20.000	3.485	17A	3.181
T13		Transformer			10.000	5.994	S.9.9	S.962
T14		Transformer			10.000	2.163	25.6	2.334
T16		Transformer			20.000	3.5.u	17.7	3.507
T17		Transformer			20.000	J..W	17.7	3.507
T18		Transformer			20.000	13.388	66.9	USA
T19		Transformer			20.000	6.001	J.O.0	S.893

- Indicates a branch with operating load exceeding the branch capability.

Project: MASTER THESIS ETAP
 Location: HOUN CITY - LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220KV StudrCase: LF
 Page: 12
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Brançlı Loçsifitjılı "Renov1

C'KI/Busnch	M	~	From-ToBusFlow		To-FromBusFlow		Losses		%Bu,Voltag.,		Vd % Drop in Vmag	
			M, ar	1TW	M, ar	1TW	E	L.L.I	-195.i	99.1	98.3	
Lhi.2		6.017	3.963	-6.004	-1.158							0.77
Lhi.5		19.518	1.155	-19.478	-1.026			40.0	129.1	99.1	98.8	0.27
Lhi.7		1.479	2.276	1.478	-2.329		0.9		-52.3	99.1	99.0	0.09
Lhi.9		3.479	2.276	-3.478	-2.329		0.9		-52.3	99.1	99.0	0.09
L&1.11		10.919	1.68i	10.w1	-7.65s	1ss		0.1	99.1	98.5		0.60
n		-43.m	-18.606	43.S1	-23.466	10s.0	4859.9	99.1	100.0			0.88
T4		0.001	1.247	0.000	-1.234	1.0	1.12,	99.1	98.1			1.05
11.E1		6.009	3.992	-5.996	-1.155	1AS	-162.6	98.9	98.0			0.84
Lhit3		3.488	0.Z46	J.m	0.062	3.7	JOS.?	98.9	98.8			0.09
Lint6		0.994	0.m	-0.994	-0.629	0.1	sl.1	98.9	98.8			0.02
111.S		0.994	0.m	-0.994	-0.629	0.1	sl.1	98.9	98.8			0.02
L&1.10		s.ozz	3.19s	-5.019	1.290	3.s	-91.s	98.9	98.6			0.26
T3		-16.507	-S.089	16.S1Z	8.781	15.4	69.1s	98.11	100.0			1.15
TS		1.187	1.%59	-1.986	-1.231	U	28.3	98.5	98.1			0.68
T6		6.956	4.6S7	-6.938	-4.301	17.8	356.9	99.0	97.8			1.26
T9		6.004	4.1S8	-5.968	J.699	35.3	459.1	98.3	98.1			0.35
TIO		5.996	4.155	-5.960	-1.694	35.5	461.1	98.0	98.3			0.32
Lhit4		-13.472	2.810	13.509	-1.797	37.4	12.8	98.9	98.8			0.07
Lhiell		6.602	7.1.S1S	-6.590	1.092	12.4	-126.9	98.9	98.9			0.02
Lln.13		1.390	-1.644	-1.385	-0.656	4.6	-2300.1	98.9	99.3			0.35
rn		5.480	0.153	J.m	0.000	1.1	153.4	98.9	98.7			0.18
rn		3.484	0.062	J.481	0.000	S.1	62.2	98.5	98.7			0.10
Lhd4		0.604	-1.398	-0.603	-0.m	0.9	2019.1	98.9	99.3			0.11
Tl.I		5.986	0.306	-5.962	0.000	23.5	305.5	98.11	98.4			0.52
TU		1.988	1.177	-1.984	-1.130	M	47.2	99.3	98.1			1.19
Tl6		2.984	1.91Z	-2.981	-J.S48	.12	64.2	98.8	98.4			0.42
Tl7		1.984	1.91?	-1.981	-1.848	3.2	64.2	98.8	98.4			0.42
TIS		10.961	7.688	-10.914	J.765	46.1	922.2	98.5	98.0			MS
n9		s.019	3.290	-5.009	1.1os	M	1s.,o	98.6	100.s			1.87
							464.8	3296.6				

Project: MASTER THESIS ET.4.P
 Location: HOUNCIW LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY-EEE Department
 Engineer: SANDI USTAFAAL-REFAI Study Case: LF
 Filenname: HOUN SUBSTATION 220kV Revision: Base
 Page: 13 Date: 28-06-2016
 SN: Config: Nonna!

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Alert Summary Report

<u>Loading</u>	% Alert Settings		<u>Marginal</u>
Bus	100.0	95.0	
Cable	100.0	95.0	
Reactor	100.0	95.0	
Line	100.0	95.0	
Transformer	100.0	95.0	
Panel	100.0	95.0	
Pilot Line Device	100.0	95.0	
Generator	100.0	95.0	
Inverter/Charger	100.0	95.0	
<u>Bus Voltage</u>			
Over-Voltage	105.0	101.0	
Under-Voltage	95.0	98.0	
<u>Over-Current Margin</u>			
Overloaded (Q Max.)	100.0	95.0	
Under-Extended (Q Min.)	100.0		

Final Report

DniceID	Type	Condition	Rating/Limit	Unit	Op.rating	% Optrating	PhaseType
Bus 0	Bus	Undervolt.g.	11.00	kV	10.75	97.8	3-Phm

Project: **MASTER THESIS** ETAP
 Location: **HOUN CITY - LIBYA** 12.6.0H P~ge: 14
 Contract: **NEAR EAST UNIVERSITY - EEE Department** Date: 28-06-2016
 Engineer: **SAND MUSTAFA AL-REFAI** Study Case: **LF** SN:
 Filename: **HOUN SUBSTATION 220kV** Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

TOTAL MARYO TOTAL GENERATION,LOADING & DEMAND

	erw	llfra<i>t</i>	lliva	%PF
Sour(e (Suing Buses):	60.104	32.249	68.109	88.11 Lagging
Source (Non-Suing Buses):	0.000	0.000	0.000	
Total Demand:	60.104	32.249	68.209	88.12 Lagging
Total Motor Load:	47.999	23.307	53.358	89.96 Lagging
Total Static Load:	11.640	5.646	11.937	89.97 Lagging
Total Constant I Load:	0.000	0.000	0.000	
Total GenericLoad:	0.000	0.000	0.000	
Apparent Losses:	0.465	3.297		
System mismatch:	0.000	0.000		

Number of Iterations: 2

APPENDIX5

LOAD FLOW ANALYSIS WITRPV

Project: ILLISIER THESIS
 Location: HOUN CITY-LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Depm'nneut
 Engineer: SMTD hifusta FA AL-REFAI
 Filename: HOUN SLIILSTATION 220kV

ETAP 12.6.0H

Study Case: LF
 Page: 1
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Electrical Transient Analyzer Program

Load Flow Analysis (With PV).

Loading Category (L): Design

Generation Category (G): Design

Load Diversity Factor: None

	Sing	V-Control	Load	Total
Number of Buses:	3	7	30	40

	nhm2	nhml	Beactor	hinelCable	ImReducmt	IM/I	Im!
Number of Branches:	24	0	0	16	0	0	40

Method of Solution: Adaptive Nemon-Rapson Method

Number of Iteration: 99

Precision of Solution: 0.0001000

System Frequency: 50.00Hz

Unit System: Metric

Project: IL\STER TBE~1S ETAP Page: 2
 Location: HOUN CITY-LIBYA 12.6.0H Date: 28-06-2016
 Contrat: NEAREAST UNIVERSITY -EEE Department -N:
 Engineer: SAI\& I\WSTAF A AL-REFAI Revision: Base
 Filename: HOUN Sh11STATION220kV Config: Nonna!

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Adjustments

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer: Impedance:	Yts	Individual	
Reactor Impedance:	Yts	Individual	
Overload Heater Resistance:	No		
Transmission Line Length:	No		
Cable Length:	No		

Parameter	Apply Adjustments	Individual /Global
Transmission Line Resistance:	Yts	Individual
Cable Resistance:	Yts	Individual

Project: JLSTER THESIS
Location: HOIN CM - LIBYA

ETAP

12.6.0H

Page: 3

Date: 28-06-2016

Contract: NEAREASTUNIVERSITI EEE Department
Enginuer: SA.W JIISTAFAAAL-REFAI
Filenumber: HOUN SLBSTATION 220kV

Study Case: LF

Redision: Base
Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

BUSInput Data

Bus	ID	kV	Sub-sp;	Initial Voltage		ConstrantVA		Con-stdZ		Custm.dl		Gmin	
				%Mg.	Ang.	MW	Mvar	MW	Mvar	-MW	Phar	111V	Ifra
Bus1		6MOO	I	99.1	-S.1								
Bus2		66.000	2	98.9	-1.9								
Bus0		2%0.000	1	100.0	0.0								
Bus1		210.000	3	100.0	0.0								
Bus5		120.000	I	100.0	0.0								
Bus6		11.000	I	98.1	-S.1	0.000	0.995	0.000	0.149				
Bus7		66.000	I	98.5	-1.9								
Bus8		66.000	I	99.0	.51								
Bus9		11.000	I	98.1	.2.8	1.600	0.992	0.400	CZ48				
Bus10		11.000	I	97.8	-7.2	5.600	3.471	1.400	0.868				
Bus11		66.000	I	99.1	-U								
Bus12		66.000	I	99.4	-U								
Bus13		66.000	I	98.1	-S.6								
Bus14		66.000	I	98.0	-2.4								
Bus15		11.000	I	98.1	-8.8	4.800	1.975	1.200	0.744				
Bus16		11.000	I	98.3	-SA	4.800	2.915	1.100	0.744				
Bus17		66.000	I	98.9	-6.8								
Bus18		66.000	2	98.8	-2.3								
Bus19		11.000	I	98.7	-S.4	4.400	0.000	1.100	0.000				
Bus20		11.000	2	98.7	J.3	2.800	0.000	0.700	0.000				
Bus21		66.000	I	98.9	-7.5								
Bus22		11.000	I	98.4	-IM	1.800	0.000	1.200	0.000				
Bus23		66.000	I	99.3	-7.9								
Bus24		11.000	I	98.1	-8.8	1.600	0.991	0.400	0.248				
Bus25		66.000	I	98.8	-S.8								
Bus26		11.000	I	98.4	-6.7	1.100	1.487	0.600	0.37Z				
Bus27		11.000	I	98.4	.11.1	1.400	US?	0.600	0.m				
Bus28		66.000	I	98.5	-5.5								
Bus29		66.000	I	98.1	-S.1								
Bus30		11.000	I	98.0	-5.7	8.800	5.455	1.100	LJ64				
Bus31		11.000	I	100.5	-3-<	4.000	1.479	1.000	0.610				
Bus32		0.400	I	100.0	1.1								
Bus33		0.400	I	100.0	1.1								
Bus34													
Bus35													

Project: MASTER THESIS
 Location: HOUNCIT LIBYA
 Contract: NEAREASTUNIVERSITY-EEDDepartment
 Engineer: SAIDIWSTAFAL AL-REFAI
 Filenome: HOUNSUBSTATION20kV

ETAP
 12.~.0H
 Study Case: LF

Page: 4
 Date: 28.06.2016
 SN:
 R•lslou: Base
 Config: Nol'mal

DE-1GN OF A LARGESCALE SOLAR PV SYSTEM & IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus.	ID	kV	Sub-sys	Initial Voltage		Constant kVA		Constant Z		Constant I		Generic	
				%~fig.	Ang.	MW	Mvar	MW	Mvar	MW	Mvar	MW	Mvar
Bus36	0AQ0	1		100.0	1.1								
Bus13	MOO	1		100.0	1.1								
Bu38	0.400	2		100.0	J.J								
Bu39	0.400	2		100.0	3.3								
Bu40	0.400	2		100.0	3.3								
Bus41	11.000	1		9-	-1.1								
Bm41	11.000	1		98.6	1.0								

Total Number of Buses: 40

47.999 23,307 11.000 5.827 0.000 0.000 0.000

Oeaererton Bus	ID	kV	Tip,	Voltage		Generntiou		llb/lrrLimits		
				%Mag.	Angl.	MW	Mvar	%PF	Max	Min
Bus1	220.000	Sting	1	100.0	0.0					
Bu11	220.000	Suing	3	100.0	0.0					
BmS	220.000	smug	1	100.0	0.0					
Buc,tt	0.400	V>tag" Control	1	100.0	1.1	1.960			0.899	0.000
Bus35	MOO	Voltage Control	1	100.0	1.1	1.960			0.399	0.000
Bu36	0.400	Votau Control	1	100.0	1.1	1.960			0.899	0.000
Bu37	0.400	V-fAgt Control	1	100.0	1.1	JMO			0.899	0.000
Bus38	Q.400	Voltatg ContNil	1	100.0	3.3	1.960			0.899	0.000
Bu39	0.400	Volta-gt Control	2	100.0	3.3	1.960			0.899	0.000
Bus40	0.~0	Voltatg Control	2	100.0	3.3	1.960			0.899	0.000

13.719 0.000

Project: ILISTER THESIS ETAP
 Location: HOUN CITY - LIBYA 12.6.0H
 Contract: YEAR EASTUNIVERSITY -EEE Deptalment
 Engineer: SANDIWSAFAAL-REFAI Study Case: LF
 Filename: HOJN STBSTAON 220kV Revision: Base
 Config: No-mnl

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Line/Cable Input Data

Ohms or Siemeus/1000m per conductor (Cable) per phase (Line)

Line/Cable	ID	Library	Length						R	X	Y
			Sm	Adj.(m)	%Tol	Li/Phas.	R _{CO}	g			
CblL		11MCUS3	-	100.0	0.0	1	75	0.076102	0.087400	0.0001646	
CblZ		INICISS	300	100.0	0.0	1	75	0.076102	0.087400	0.0001646	
Lint1			674	19300.0	0.0	1	75	0.056003	0.342069	0.0000031	
LintZ			674	3100.0	M	1	75	-0.056001	0.342069	0.0000034	
Lint3			674	21000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Lint4			674	15000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Line\$			6U	8000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Lin,6			674	4000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Lin,7			674	4000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Lin,S			674	4000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Lin,9			674	4000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Lint10			674	8000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Lin,11			674	8000.0	0.0	1	75	0.056001	0.342069	0.0000034	
Lint1Z			674	11000.0	0.0	1	75	MS6001	0.342069	0.0000034	
Lint13			674	161000.0	0.0	1	75	0.086001	0.342069	0.00000M	
Lint14			674	140000.0	0.0	1	75	0.086001	0.342069	0.0000034	

Line / Cable resistances are listed at the specific input files.

Project: ILLISIER THESIS
 Location: HODIN CITY LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SANDIIVSTA:FAAL-REFAI
 Filname: HOUN SUB&TATION 220kV

ETAP

12.6.0H

Page: ~
 Date: 28.06.2016
 SN:
 Revision: Base
 Config: Nominal

Study Case: Lf

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

k) Judging Transformer Input Data

Transformer	ID	Type	MVA	Prim.kV	Sek.kV	%ZI	Xl/Rl	Z Variation			%TapStrug		Adjusted	PhaseShift		
								+%	-%	%Tol	Prim.	St.				
T1	3-Ph:k-	63.000	210.000	66.000	JL\$1	45.00	5	0	0	0	0	3.7501	1.80000	Dyn	0.000	
T3	3-Ph:st	63.000	210.000	66.000	JL50	45.00	0	0	0	0	0	0.615	11.5000	Dyn	0.000	
T4	3-Ph:st	10.000	66.000	1MOO	8.35	13.00	0	0	0	0	0	0	8.3500	Dyn	0.000	
T5	3-Ph:st	10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	0	10.0000	Dyn	0.000	
T6	3-Ph:st	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000	Dyn	0.000	
T7	J-Ph:st	11.500	11.000	66.000	8.35	13.00	0	0	0	0	0	0	8.3500	VNd	0.000	
TS	3-Ph:st	11.500	11.000	66.000	8.35	13.00	0	0	0	0	0	0	8.3500	VNd	0.000	
T9	3-Ph:st	10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	0	4.375	8.1500	Dyn	0.000
TIO	3-Phas	10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	0	4.375	8.3500	Dyn	0.000
TII	3-Ph:st	20.000	66.000	JLOD	10.00	20.00	0	0	0	0	0	0	10.0000	Dyn	0.000	
T12	3-Ph:st	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000	Dyn	0.000	
T13	J-Ph:st	10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	0	8.3500	Dyn	0.000	
T14	J-Ph:st	10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	0	8.3500	Dyn	0.000	
T16	3-Ph:st	20.000	66.000	11.000	10.00	10.00	0	0	0	0	0	0	M*25	10.0000	Dyn	0.000
T17	J-Ph:st	10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	0	0.615	10.0000	Dyn	0.000
T18	3-Phas	20.000	66.000	11.000	10.00	10.00	0	0	0	0	0	0	1.750	10.0000	Dyn	0.000
T19	3-Phas	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	3.750	10.0000	Dyn	0.000
TIO	3-Phas	3.000	0.400	11.000	6.15	6.00	0	0	0	0	0	0	-1SOO	VNd	0.000	
ra	I-PhMt	3.000	0.400	11.000	6.15	6.00	0	0	0	0	0	0	**0500	VNd	0.000	
n1	J-Ph:st	3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	0	6.800	VNd	0.000	
T11	J-Ph:st	3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	0	6.1<00	VNd	0.000	
T14	J-Ph:st	3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	0	6.2500	VNd	0.000	
T15	3-Ph:st	3.000	0.400	11.000	6.15	6.00	0	0	0	0	0	0	6.2500	VNd	0.000	
T16	3-Ph:st	3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	0	6.1~	VNd	0.000	

Project: HiASTERESIS
 Location: LIBYA
 Country: LIBYA
 Institution: LIBYA
 Department: LIBYA
 Engineer: LIBYA
 File Name: LIBYA

ETAP
 12.0.0
 Study Case: LF
 RO|sion: Base
 Config: Nominal

Page: 7
 Date: 28-06-2016
 SN:
 RO|sion: Base
 Config: Nominal

DESIGN OF A LARGESCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA-POWER GRID.

Branch Connections

KT/Branch	ID	Type	Connected Bus ID	%Impedance, Pos. Seq., 100 kVABase			
				R	X	Z	y
T1	ZWXFMR	Bus3	Bus1	0.46	20.58	10.59	
T3	ZWXFMR	Bus5	Bus1	0A4	19.%	19.97	
T4	ZWXFlIR	Bud	Bu~	6.40	83.25	83.50	
TS	ZWXFlIR	Bu-7	Bu.1>	2.50	49.9-1	50.00	
T6	ZWXFlIR	But8	Bu.10	2.53	50.56	50.63	
T7	ZWXFlIR	Bus42	BuÜl	5.06	65.77	6.97	
TS	ZWXFlIR	Bus-tl	Bu.Z	5.06	65.11	~8.97	
T9	ZWXFlIR	Bud3	Bus1\$	6.68	86.90	S7.15	
T10	ZIVXF1jIR	Bu.14	Bud6	6.68	86.90	81.15	
TU	ZWXFlIR	Bu.17	Bus19	1.50	49.94	50.00	
T13	ZVXEFlIR	Bus8	Bus20	2.50	49.94	50.00	
T14	ZVXRIR	Bus21	But??	6.40	83.25	8UO	
T16	ZWXFlIR	Bm:ll	Bud\$	6.40	83.25	SS.SE	
T17	ZVXF:MR	Bm2.7	Bw.?S	1.51	50.25	50.31	
T18	1WXNM	Bus17	Bus29	2.51	80.15	50.31	
T19	ZWXFlIR	Bus30	Bus32	1.59	51.51	51.SS	
NO	ZIVXF1jIR	Bu134	Bus41	34.25	205.50	208.33	
T20	ZWXFlIR	Bu138	Bu..1l	34.25	105.50	208.33	
n2	ZWXRIR	Bm36	Bwl	34.25	205.50	208.33	
T23	ZWXFlIR	Bu.37	Bus41	34.15	205.50	208.33	
T14	ZWXFlIR	Bud8	Bu-2	34.25	205.50	208.33	
T25	ZWXRIR	Bus39	Bus12	34.25	205.50	208.31	
T16	1WXNM	Bu.40	Bus1?	34.25	205.50	208.33	
Cabt1	Cabt1	Bu.11	Bus!	0.01	0.01	0.03	0.0716998
Cabt2	Cabt2	Budz	Bus1	0.0?	0.02	0.03	0.0716998
Lht1	Lht	Bw>Z	BusU	2.48	16.58	16.77	0.2607629
Lht2	Lht	8m1	Bus13	2.48	15.16	15.36	0.84267
Lht3	Lht	Bus?	Bus18	2.96	18.06	18.30	0.33S7157
Uno-1	Un,	Bu.27	Bu.17	1.93	11.78	11.94	0.1209015
LinS	Lht	Bm1	Bus1?	J.03	.6ZS	6.37	0.1178142
Llue6	Llue	Bu.Z	Bu.7	0.SI	3.14	3.18	0.OSS9071
Un,7	Lin	Bus1	Bu.S	0.51	1.14	3.18	0.0589071
Lht.S	Lin,	Bu.?	Bu.7	0.SI	3.14	3.18	0.0589011
Lin,9	Un,	Bus1	Bu.S	0.SI	1.14	3.18	0.0589071
UndO	Un,	Bu.?	Bu.31	1.85	6.18	6.37	0.1118142
Lin,11	Lin	Bud	BuoO	1.03	6.18	6.37	0.11781.?

Project: IIL\STER THESIS
 Location: HOUN CIY -LIBYA
 Contract: NEAREASTUNIERSIIY -EEE Department
 Engineer: SAID MUSTAFA AL-REFAJ
 Filename: HOUN SUBSTATION 220KV

ETAP
 12.6.0H

Study Case: LF

Page: 8
 Date: 28-06-2016
 SfI:
 Reli,ion: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

<KTIBr-auch			Connected Bus ID		% Impedance, Pos. Seq., 100 MVABase			
ID	Typ.	From Bus	To Bus	R	X	Z	V	
LineL2	Line	Bu,17	Bu,21	2.10	16-1b	16.11	0.1092622	
LineH1	Line	Btd7	Bus23	20.70	12M3	128.U	Z-1710100	
LineU	Line	Bu21	Bu23	18.06	10M4	11.1e	2.0617480	

Project: IUSRIER THESIS
 Location: HOUN CITY LIBYA
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engineer: SANDAWSTAJAAJ...REF.U
 Username: HOUN SUBSTATION 220kV

ETAP
 12.ii.OH
 Study Case: LF

Page: 9
 Date: 18-6-10M
 SN:
 Redslon: Base-
 Config: Normal

DESIGN OF A LARG.E SCALE SOLAR PV SYSTEM AND DIP ACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

LOAD FLOW REPORT QWith P/2

Bus	ID	KV	Voltage		Generation		Load		ID	Load Flott		XFiltR		
			% Mag.	Aug.	MW	Mvar	h/HY	h-var		I/IW	Aka.	Atnp.	%PF	%Tip
Bus1		66.000	99.388	-4Z	0	0	0	0	Bm12	1.7.1	-0.376	68.	99.8	
									Bud3	6.021	1.961	63.8	81.5	
									But7	19.5.19	1.11S	172.3	99.8	
									Bu18	3.183	1.1278	~.6	83.7	
									Bu-8	3.181	1.178	3M	81.7	
									Bnt30	10.991	7.691	118.1	81.9	
									Bud	~5.161	-18.211	353.3	19.1	3.750
									But<1	0.001	uis	11.0	0.1	
Bus2		66.000	99.061	-1.2	0	0	0	0	But11	-5.821	-0.72-	51.8	99.2	
									Bud-1	6.014	3.993	63.7	83.3	
									Bud8	3.491	0.01S	30.9	99.1	
									Bu-7	0.994	0.573	10.1	86.7	
									Bu>7	0.994	0.573	1.01	86.7	
									Bu531	5.027	1.200	52.6	84.1	
									Bus5	-10.700	-7.365	14.1	81.1	0.625
*Bu-		210.000	100.000	0.0	15.844	11.694	0	0	Bud	18.8.14	21.694	110.0	85.6	
*Bus5		220.000	100.000	0.0	10.708	7.711	0	0	But2	10.708	7.711	14.6	81.1	
Bu<6		11.000	98.3-U	-4.2	0	0	0.000	1.235	Bud	0.000	1.218	65.9	0.0	
Bm7		66.000	99.036	-1.1	0	0	0	0	Bml	-0.994	0.630	10.6	84.5	
									Bus1	1.994	0.0-0	10.1	81.8	
									Bu-31	1\$89	1.160	10.8	84.5	
Bu.S		66.000	99.297	-4.3	0	0	0	0	Bud	-3.482	-2.330	36.9	83.1	
									Bud	-3.482	-1.330	36.9	81.1	
									Bu,10	6\$64	4.661	73.8	83.1	
Bu9		11.000	98.356	-1.8	0	0	1887	1.232	Bu,7	-1.-S7	-L13Z	III.1B	85.0	
Bu10		11.000	98.048	-6.3	0	0	6.946	4.305	Bu,8	-6.946	-4.305	437.S	85.0	1.18E
Bud1		66.000	519.06	-1.1	0	0	0	0	Bu-2	SSN	MSI	51.7	99.1	
									But41	-5.821	0.61	51.7	99.4	
Bnd2		66.000	99.390	-4Z	0	0	0	0	Bu11	7.751	0.306	68.1	81.9	
									Bus41	1.7.1	0.306	68.3	9M	
Bu,13		66.000	98.615	-4.7	0	0	0	0	Bud	-6.011	-4.161	64.8	81.2	
									Bud5	6.011	4.161	64.8	82.1	
BmU		~	98.m	-1.1	0	0	0	0	Buc?	-6.001	-4.157	63.0	82.2	
									Bud6	-001	U57	65.0	82.2	
Bud8		11.000	98.983	-7.6	0	0	6.915	3.703	Bud1	.915	1.10J	371.S	85.0	4.315
Bud6		11.000	98-	-4.7	0	0	3.965	M97	BuU	-8.965	-1.697	373.7	ss.o	1.375

Project: MASTER THESIS
 Location: HOUN C.I.Y • LIBYA
 Contract: NEAR EAST UNIVERSITY • EEE Department
 Engineer: SANDMUSI AFAAL-REFAI
 Filename: HOUN SUBSTATION220kV

ETAP

12.6.0H

Study Case: LF

Page: 10
 Date: 28-06-2016
 SN:
 Redion: Base
 Config: Normal

DESIGN OF A 1:1 SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus	Voltage			Generation		Load		ID	Loadflow			XFMR	
	ID	kV	%Mag	-1.0	SW	?for	MW	lfrnr	IIW	Ab-ar	Amp	%iPF	%Tnp
Bu-17		66.000	100.000	-0.9	0	0	0	0	0	13.187	L837	121.8	-97.9
										6.609	18SS	59.5	-98.0
										1.917	-1.657	1u	-4.3
										5.48*	0.188	48.4	100.0
But18		66.000	98.973	-1.6	0	0	0	0	0	JM7	-0.062	30.8	100.0
										3.481	0.061	30.S	100.0
Bud19		11.000	100.016	-7.5	0	0	5.478	0.000	Bud7	-5.478	0.000	290.1	100.0
BuZ0		11.000	98.5W	-2.6	0	0	3.484	0.000	Bu18	J.484	0.000	185.0	100.0
Bus1		66.000	99.215	~.S	0	0	0	0	Bu17	~97	1.188	S9.0	-98.6
									Bu23	0.101	J.109	11S	.39.4
									Bu18	5.992	0.304	52.9	99.9
Bu11		11.000	98.700	-9.4	0	0	S.969	0.000	Bu21	-5.969	0.000	317.4	100.0
Bu\$13		66.000	99.515	Ji.9	0	0	0	0	Bud?	J.387	-M!<	13.S	90.4
									Bus!	-0.603	.0421	7.6	69.6
									Bu18	1.190	1.275	20.8	84.1
Bus&		11.000	98.360	-1.9	0	0	1.987	1.1S1	Bus13	-1.987	-1.131	m.1	85.0
BmZ7		66.000	11.119	-1.9	0	0	0	0	Btd1	13.14	-1.816	121.9	-91.9
									Bud	-19.499	-1.001	172.3	99.9
									Bu18	1.988	1.914	31.3	84.1
Bu8		11.000	98.703	-5.8	0	0	1.984	1.850	Bu17	H.984	-1.8<0	186.7	85.0
Bu29		11.000	98.703	-8.8	0	0	1.854	1.850	Bum	-1.954	-1.850	18*.7	85.0
Bus30		66.000	98.787	-1.6	0	0	0	0	Bud	-10.973	-7.691	118.7	81.9
									Bu-1	10.973	7.692	118.7	81.9
Bm31		66.000	SIS.502	.1.4	0	0	0	0	Bu11	-.5023	-3.191	S3.1	83.6
									Bu13	S.013	3.191	S3.1	83.6
Bus32		11.000	98.126	-7.8	0	0	10.917	6.11.1	Bu30	H0.927	-6.773	686.Z	85.0
Bu33		11.000	100.681	H1.S	0	0	5.014	3.108	BuJI	-5.0U	J.105	307.5	85.0
itBu34		0.400	100.000	1.1	1.960	0.188	0	0	Bu41	1.960	0.258	28SJ.2	99.1
"Bus38		0.400	100.000	1.1	1.960	0.188	0	0	Bu<!!	1.160	0.258	28SJ.1	19.1
,Bm36		0.400	100.000	1.1	1.960	0.158	0	0	Bus41	1.960	0.188	285.U	99.1
"Bus37		0.400	100.000	1.1	1.960	0.288	0	0	Bu41	1.960	0.253	1853.1	19.1
*Bn.s38		0.400	100.000	3.3	1.960	U18	0	0	Bu11	1.960	0.378	ISS0.8	95.1
*BuQ9		0.400	100.000	11	1.960	0.378	0	0	Bu14?	1.960	0.378	ISS0.8	98.1
*BuH0		0A00	100.000	3.3	1.960	0.378	0	0	BuH1	1.960	0.378	1850.8	98.1
Bu41		11.000	98.877	-1.2	0	0	0	0	Bu12	7.786	0.711	415.0	99.6
									Bu34	-1.146	-0.178	103.8	99.6
									Bu-S	-1.946	-0.178	103.S	99.6
									Bu36	-1.946	-0.178	103.8	99.6

Project: MASTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAREASTUNIVERSID - EEE Department
 Engineer: SAND IWSTAFAL-REI'AF
 Filename: HOUN SIN1STATION 210KV

ETAP
 12.6.0H

Study Case: LF

Page: 11
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nounal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus	Voltage				Generation		Load		ID	Load Flow				XfMR
	ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar		arw	lfrar	Amp	% PF	
Bus42	11.000	98.6.10	1.0	0	0	0	0	0	Bu37	-1.946	0.178	103.8	98.9	-1.150
									Bnsll	5.518	0.7	314.3	98.9	
									Bu15	-1.946	-0.296	1e15	98.9	
									Bu-9	-1.946	-0.296	10M	98.9	
									Bw-0	-1.946	-0.296	104.11	98.9	

* indicates a floating load bus ('-t'; or 'ro-'1J') or swing type machine connected to it.
 # indicates a bus with a load mismatch of more than 0.1 MW.

Project: MASTER THESIS
 Location: HOUN CITY -LIBYA
 Cont'lact: NEAREAST UNIVERSITY - Ell Department
 Engineer: SAMI MASTAFA AL-REFAI
 ru,nailie: HOUN & SUBSTATION 220kV

ETAP
 12.6.0H
 Date: 28-06-2016
 SN:
 R-Visiön: Base
 Con fig: Nom.11

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION TO LIBYA'S POWER GRID

Bus Loading Summary Report

Bus	JD	kV	RAt,dAmp	Dinlly Connected Load						Total Bus Load			
				ConstantkVA	ConstantZ	ConstantI	Gntric	ImpA	%PF	Amp	Ptot(Ut)	Londiuc	
Bus1		210.000								0	0.0	0.0	
Bu'l		66.000		0	0	0	0	0	0	47.324	91.0	416.5	
Bus1		66.000		0	0	0	0	0	0	18.506	89.3	16.4	
Bus1		2%0.000		0	0	0	0	0	0	41.696	85.6	no.0	
BusS		110.000		0	0	0	0	0	0	13.195	81.1	M.6	
Ba'6		11.000		0	0.~8	0	0.240	0	0	0	1.151	0.0	68.9
Bus7		66.000		0	0	0	0	0	0	2.38.i	84.S	10.8	
Buss		66.000		0	0	0	0	0	0	8.3 Q	83.1	73.8	
Bu'l>		11.000	1.600	0.991	0.387	0.240	0	0	0	1.338	85.0	114.8	
Busl0		11.000	5.600	3.471	1.346	0.811	0	0	0	8.m	85.0	4n.s	
Bud!		66.000		0	0	0	0	0	0	5.857	99.4	51.7	
Busl?		66.000		0	0	0	0	0	0	7.760	99.9	68.3	
B1td3		66.000		0	0	0	0	0	0	7.310	81.1	64.8	
Bud4		66.000		0	0	0	0	0	0	7.300	81.1	65.0	
Busl5		11.000	4.800	2.975	1.176	0.729	0	0	0	7.030	85.0	J7Z.S	
Bu16		11.000	4.500	1.975	1.166	0.31?	0	0	0	7.018	85.0	373.7	
Busl7		66.000		0	0	0	0	0	0	13.814	97.6	n1.S	
Busl8		66.000		0	0	0	0	0	0	3.488	100.0	30.8	
Busl9		11.000	4.400	0	1.078	0	0	0	0	5A18	100.0	29M	
Bus20		11.000	1.900	0	0=	0	0	0	0	1.484	100.0	185.0	
Busl!		66.000		0	0	0	0	0	0	6.745	97.8	59.5	
Busl2		11.000	4.800	0	1.169	0	0	0	0	~69	100.0	m.4	
Busl3		66.000		0	0	0	0	0	0	2365	8U	10.8	
Bus23		11.000	1.600	0.991	0.387	0.10	0	0	0	2.337	85.0	124.7	
Busl?		66.000		0	0	0	0	0	0	19.871	98.1	178.4	
Bin28		11.000	?AO0	1.487	0.785	0.m	0	0	0	asn.	85.0	186.7	
Bus29		11.000	UQ0	1.487	0.585	0.36!	0	0	0	3.511	85.0	186.7	
Bus.10		66.000		0	0	0	0	0	0	13.400	SU	I18.7	
Bu.dl		66.000		0	0	0	0	0	0	6.006	SJ.6	S1.Z	
Busl!		11.000	8.800	5.455	U27	1.318	0	0	0	ll.856	85.0	686.i	
Bus3l		11.000	4.000	:U79	10U	0.618	0	0	0	5.899	85.0	307.S	
Bm.34		0.400		0	0	0	0	0	0	1.977	99.1	2a53.i	
Bus.lS		0.400		0	0	0	0	0	0	1.977	99.1	2853.1	
Busl6		0.400		0	0	0	0	0	0	1.977	99.1	2853.1	
Bum		0.400		0	0	0	0	0	0	1.m	99.1	1853.1	
Bus.lS		0.400		0	0	0	0	0	0	1.996	98.2	ZSS0.8	

Project: AL\SI"ER . THESIS
 Location: LIOUN CITY LIBYA
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engineer: SAID MUSTAFA AL-REFAI
 Filename: HOUN SUBSTAON220kV

ETAP

Pgno: 13
 Date: 28.06.1016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LYAN POWER GRID

Bus	ID	kV	R>t&Amp	Directly Connected Load								Total Bus Load		
				ConstrntkVA		CommtkZ		CommtkI		Generic		MVA	%FF	Amp
				MW	Mvar	MW	Mvar	MW	Mvar	MW	Mvar			
Bin39		MOO		0	0	0	0	0	0	0	0	1.9%	98.1	1880.8
Bus40		0.400		0	0	0	0	0	0	0	0	1.9%	98.2	2880.8
BU,H		11.000		0	0	0	0	0	0	0	0	1.818	99.6	415.0
Bus42		11.000		0	0	0	0	0	0	0	0	5.906	98.9	314

* Indicate scope of load on bus exceeds the budget limit (1.0% of total continuous ampacity).

indicates operating load at a bus exceeds the basic marginal limit (95.0% of total continuous ampacity).

Project: HUSIER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND MUSTAFA AL-REFAT
 Filename: HOUN SUBSTATION 220kV

ETAP
12.6.0H
Study Case: LF

Pg.: 1.f
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nol'mal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND ThPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Branch Loading Summary Report

CST /Branch		Cable & Reactor			Transformer		
ID	Type	Ampacity (Amp)	Loading Amp	%	Capability (MVA)	Loading (input) MVA	Loading (output) If A %
Cabl.1	Cable	413.67	51.50	12.23			
Cable1	Cable	423.67	68.33	16.13			
T1	Transformer				13.000	41.898	66.5 40.136 63.7
T.I	Transformer				6MOO	13.195	20.9 12.990 20.6
T4	Transformer				10.000	1.148	11.S 1.23S 12.4
TS	Transformer				20.000	2.354	11.8 2."8 11.7
T6	Transformer				20.000	8.80	41\$ 5.m 40.9
T7	Transformer				12.500	5.906	47.1 5.851 46.9
TS	Transformer				12.500	7.818	62.5 7.760 61.1
T9	Transformer				10.000	7.310	73.1 7.030 70.3
T10	Transformer				10.000	7.300	73.0 7.018 70.2
II1	Transformer				20.000	5.488	27.4 5.418 17.I
II2	Transformer				10.000	3.488	17.4 3.484 17.1
TI3	Transformer				10.000	6.000	60.0 5.%9 59.7
TU	Transformer				10.000	2.465	23.7 1.337 13.4
Tl6	Transformer				20.000	3.548	17.7 3.\$11 IM
T17	Transformer				20.000	3.548	17.7 3.\$11 17.6
TIS	Transformer				20.000	13.400	67.0 12.856 61.3
T19	Transformer				20.000	6.006	10.0 8.899 29.5
NO	Transformer				1.000	1.977	65.9 1.955 65.1
II1	Transformer				1.000	1.977	65.9 1.955 ~.?
II1	Transformer				1.000	1.977	65.9 1.955 65.1
II1	Transformer				3.000	1.977	65.9 1.955 65.2
T24	Transformer				3.000	1.996	66.5 1.969 65.6
T15	Transformer				3.000	1.996	66.5 1.969 ~.6
TM	Transformer				3.000	1.996	66.5 1.969 ~.6

* Indicating a branch with exceeding load exceeding the branch capability

Project: IIASTER THESIS
 Location: HOVN CITY -LIBYA
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engiu-i: S. Jil>IESTAFAAL-REFAI
 Filename: HOVN SUBSTAON 220kV

ETAP 12.6.0H
 Study Case: LF
 Rerisou: Base
 Config: Normal

Page: 15
 Date: 28-06-2016.
 SN:

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND PACTANYSIS OF ITS INTEGRATION INTO LIBYA POWER GRID

Bran~L<sm fümin~TReeng rt

CICT Branch	From, To Bus Flow		To, From Bus Flow		Losses		% Bus Voltage		Yd % Drop in Vmag	
	ID	MW	MVA	XfW	Jifrac	kW	kVar	From	To	
Cable:2		-7.754	-0.376	7.714	0.306	0.1	-70.7	99.4	99.4	0.00
Line:2		6.024	3.964	-SN11	-1.161	13.3	-31.1	99.4	98.6	0.77
Lin5		19.819	1.129	-19.499	-1.001	39.9	127.6	99.1	99.1	0.27
Lin7		3.483	1.278	-3.m	-2.330	0.9	-51.6	99.4	99.3	0.09
Lin9		3.483	2.278	-1.482	-2.330	0.9	.82.6	99.4	99.3	0.09
Lin,11		10.992	7.691	-10.973	-7.692	18.8	-6.6	99.4	98.5	0.60
Tl		-35.161	-15.111	35.84-1	11.694	77.4	3482.1	99.4	100.0	0.61
T4		0.001	1.248	0.000	-1.235	1.0	13.1	99.4	98.3	1.08
Cabid		-5.821	-0.725	5.811	0.61	0.1	-70.3	90.1	99.1	0.00
Lin!		6.014	3.993	-MO!	-1.157	13.4	-163.9	99.1	98.1	0.84
Un,3		3.491	-0.248	-3.487	-0.062	3.7	-109.6	99.1	99.0	0.09
Lin,6		0.994	asIS	-0.994	-0.630	0.1	-57.4	99.1	99.0	0.01
UnitS.		0.994	0.73	-0.994	-0.630	0.1	-57.4	99.1	99.0	0.02
Line10		5.027	3.200	-S.023	-3.291	3.8	.92.3	99.1	98.8	0.26
T3		-10.700	-7.365	10.708	7.711	7.7	345.4	99.1	100.0	0.94
TS		1.989	1.660	-1.957	-1.2,2	U	.28.2	99.0	98.4	0.68
T6		6.964	4.661	-6.946	-1.305	17.8	.55.6	99.3	98.0	1.15
T7		SSN	-0.654	5.838	0.887	17.9	232.8	99.1	98.6	0.13
TS		-7.751	-0.306	7.786	O.m	31.2	406.1	99.4	98.9	0.81
T9		6.011	4.161	-5.975	-3.703	35.2	451.8	98.6	99.0	0.37
NO		6.001	4.157	-5.965	-3.697	35.4	459.8	98.2	98.6	0.34
Unit4		-13.487	2.837	13.524	-2.826	37.1	11.0	99.2	99.1	0.0
Line11		M09	-1.33.1	-6.597	1.104	11.4	-2.28.8	99.2	99.1	0.01
Un,B		1.SSI	-1.657	-1.387	-0.656	4.6	-2313.2	99.1	99.5	0.35
TU		5.486	0.153	-5.478	0.000	7.6	152.9	99.2	99.0	0.18
TIZ		3.487	0.062	-3.484	0.000	3.1	62.0	99.0	98.9	0.10
Lin,14		0.604	-1.409	-0.601	-0.622	1.0	-2030.5	99.2	99.5	0.13
TJ		5.991	0.304	-5.969	0.000	23.4	304.5	99.2	98.1	0.52
TU		1.990	1Z78	-1.987	-1.231	3.6	47.0	99.5	98.4	1.18
T6		2.988	1.91,1	-2.984	-1.850	3.2	64.0	99.1	98.1	0.42
T7		Z.985	1.914	-2.984	-1.850	3.2	64.0	99.1	98.7	0.42
TIS		10.973	7.692	-10.927	-6.773	45.9	918.9	98.8	98.3	0.46
T19		5.023	3.292	-5.014	-3.108	9.2	184.5	98.8	100.7	1.88
no		1.960	0.158	-1.946	-0.178	13.4	80.1	100.0	98.9	1.12
ni		1.960	0.258	-1.946	-0.178	13.4	80.3	100.0	98.9	1.12

Project: JilASTER THESIS ETAP Page: 16
 Location: HOUN CITY-LIBYA 12.6.0H Date: ZS-06-2016
 Contract: NEAR EAST UNIY:ERSIIY -EEE Department SN:
 Engineer: SAND HUSTAFAAL-REFAI Revision: Base
 Filename: HOUN SUBSTATION 220KV Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Cl<TT/BrAnch	From-T0eBu Flow		To-From Bus Flew		Losses		@0 Bus Volta.gt		Yd % Drop inVmug	
	ID	MW	lfrar	lfrar	lfrar	kW	l,TF	From	To	
T22		1.960	0.258	-1.946	-0.178	13.4	80.3	100.0	98.9	1.11
TI3		1.960	0.258	-1.946	-0.178	13.4	80.3	100.0	98.9	1.11
TI4		1.960	0.378	-1.946	-0.296	13.6	81.9	100.0	98.6	1.37
ns		1.960	0.378	-1.946	-0.196	IM	81.9	100.0	98.6	1.37
TI6		1.960	0.378	-1.946	-M96	IM	81.9	100.0	98.6	1.37
						569.1		1586.5		

Project: It-SIER 11fSIS
Location: HOUN CITY- LIBYA
Contract: NEAR EAST UNIVERSITY - EEE Department
Engineer: SANDIUSTAFA •L-REFAJ
Filename: HOUN SUBSTATION 220kV

ETAP
12.6.0H

Study Case: LF

Page: 17
Date: 28-06-2016
SN:
Revisiou: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Alert Summary Report

% Alert Settings

Critical Marginal

<u>12.6.0H</u>	<u>Critical</u>	<u>Marginal</u>
Bus	100.0	95.0
Cable	100.0	95.0
Reactor	100.0	95.0
Line	100.0	95.0
Tunisfonntr	100.0	95.0
Panel	100.0	98.0
P'Otecth-eDelice	100.0	95.0
Generator	100.0	95.0
InverterCharger	100.0	95.0
<u>Bus Voltage</u>		
OverVoltage	105.0	102.0
UnderVoltage	95.0	98.0
<u>Generator Excitation</u>		
Overexcited (Q/HAX.)	100.0	95.0
Under-excited (Q/Min.)	100.0	

Project: MASTER THESIS
 Location: HOUN Cin' -LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND utUSLU' AAL4UcFAI
 Filename: HOUN SUBSTATION Z20kV

ETAP
12.6.0H

Study Case: LF

Page: 18
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

SUMMARY OF TOTAL GENERATION, LOADING & DEMAND

	MW	Jlfnri	MVA	%PF
Source (Sning Buses):	46.552	29.404	55.061	84.88 Lagging
Source (Non-Swing Buses):	13.719	2.166	13.889	98.78 Lagging
Total Demand:	60.271	31.570	68.039	88.58 Lagging
Total Motor Load:	47.999	23.307	53.358	89.96 Lagging
Total Static Load:	11.703	5.677	13.007	89.97 Lagging
Total Constant Load:	0.000	0.000	0.000	
Total Generic Load:	0.000	0.000	0.000	
Apparent Losses:	0.569	2.587		
System Infronot:	0.000	0.000		

Number of Iterations: 3

APPENDIX6

SHORT CIRCUIT ANALYSIS WITHOUT PV

Project: MASTERTBISIS ETAP Page: 1
 Location: HOUNCITY-LIBYA 12.60H Date: 28-06-2016
 Contract: NEAREASTTU"UNIVERSITY-EEE Department SN:
 Engineer: SA'ID .fJSTAFAAI-R.EFAI R<ision: Base
 Filename: HOTIN SUBSTATION20kV Config: Normal

DESIGNOF A LARGESC\LE SOLARPV SYSTEMM'D IMPACT ANALYSIS OF TS INTEGRATIONINTOLIBYANPOWER GRID

Electrical Transient Analyzer Program

Short-Circuit Analysis QWithout.PY]

IEC 60909 Standard
3-Phas<>Fault Currents

	Suing	V-Conn-ol	Load	Total
Number of Buses:	3	0	26	29

	XF1\IR2	XF1\IR3	Re-acror	Line\Cable	Impedance	Tkf1!	To!!ll
Number of Branches:	15	0	0	U	0	0	29

	Synchronous Generator	Power Grid	Synchronous Motor	Induction Machines	Lumped Load	Total
Number of Machines:	0	3	0	0	13	16

System Frequency: 50.00Hz
 Unit System: Menir

Project:	MASTER THESIS	ETAP	Page:	2
Location:	HOUN CITY -LIBYA	12.6.0H	Date:	28-06-2016
Contract:	J'EAR EAST U1\IVERSITY - EEE Departuient		SN:	
Engineer:	SAIW iID5TAF A AL-REFAI	Study Case:	SC	Revision: Base
Filename:	HOUN SUBSTATION 220kV		Config:	Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Adjustments		Apply Adjustments	Individual /Global	Preset
Tolerance				
Ti-ansfonner Impedance:	Vos		Individu.l	
Reactor Impedance:	Vts		Individua.I	
Overlead Heater Resistance:	No			
Transmission Line Length:	No			
Cable Length:	No			

Temperature Correction		Apply Adjustments	Individual /Global	Neg...c
Transmission Line Resistance:	Cable Resistance:			
Yet	Yrs		IndividUAI	
			Individw	

Project: MASTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAR EASTUNIVERSITY EEE Department
 Engineer: SAIDI fU5T FAAL-REFAI
 Filetame: HOUN SUBSTATION220kV

ETAP
 12.0.OH
 Study Case: SC

Page: 3
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM INTEGRATION INTO LIBYAN POWER GRID

Bus Input Data

ID	Typ	Bus			Initial Voltage	
		Nom.kV	Bus kV	Sub-Sys	%M.ag	Ang.
Bu.1	Load	66.000	6M75	1	99.11	-5.13
Bu.2	L+d	66.000	66.11.1	1	98.85	-1.89
Bu.3	SWNG	110.000	220.000	1	100.00	MO
Bu.4	SWNG	120.000	210.000	3	100.00	0.00
Bu.5	SWNG	110.000	110.000	1	100.00	0.00
Bu.6	Load	11.000	11.413	1	98.07	-5.08
Bu.7	Load	66.000	66.413	1	98.81	-1.91
Bu.8	Load	66.000	68.475	1	99.01	-5.19
Bu.9	Load	11.000	11.069	1	98.18	-2.1
Bu.10	L+d	11.000	11.888	1	97.77	-7.10
Bu.13	Load	66.000	68.415	1	98.4	-5.61
Bu.14	Load	66.000	66.415	1	98.01	-2.32
Bu.15	Load	11.000	11.912	1	98.69	-5.52
Bu.16	Load	11.000	11.553	?	98.4	-5.35
Bu.17	Load	66.000	68.475	1	98.91	-6.80
Bu.18	Load	66.000	66.413	1	98.16	-1.16
Bu.19	Load	11.000	11.413	1	98.14	-8.41
Bu.20	Load	11.000	11.069	2	98.66	.11S
Bu.21	Load	66.000	68.475	1	98.94	-7.46
Bu.22	Load	11.000	11.413	1	98.42	-10.38
Bu.23	Load	66.000	68.475	1	99.16	-1.89
Bu.25	Load	11.000	11.413	1	98.08	-5.51
Bu.17	Load	66.000	68.475	1	98.85	-5.51
Bu.18	Load	11.000	1us.r	1	98.41	-6.69
Bu.29	Load	11.000	IUS4	1	98.43	-6.69
Bu.30	Load	66.000	68.415	1	98.12	-4.49
Bu.31	Load	66.000	66.413	2	98.39	-1.06
Bu.53	Load	11.000	11.840	1	98.04	-5.74
Bu.33	L+d	11.000	1us.r	2	100.46	-MI

29Bu-Total

All voltages reported by ETAP are in % of nominal voltage.
 Bus = kV, buses = rated and used normally by ETAP.

Project: iASTER THESIS
 Location: HOUNCITY-LIBYA
 Contract: NEAR EAST UNIVERSITY-EEE Department
 Engineer: SAID JUSTAFAAL-REFAI
 Filename: HOUNSIBSTATION220kV

ETAP

12.60H

Page: 4

Date: 28-06-2016

SN:

Refliou: Base

Config: Nolmnl

Study Case: SC

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Line/Cable Input Data

Ohms or Siemens/1000m per Condn(tor (Cable) or per Phase (Line)

Line/Cable	ID	Library	Stat	Length		#Phas	T(°C)	R	X	y
				Adj.(m)	% Tot					
Llue1	6/4		19100.0	0	1	15	0.05600	0.3N25	0.0000031	
Lln,2	614		19300.0	0	1	15	0.05600	0.34207	0.0000034	
Llu3	674		23000.0	0	1	15	0.05600	0.34207	0.0000034	
Llu..1	674		15000.0	0	1	75	0.05600	0.34207	0.0000034	
LlueS	614		8000.0	0	1	75	0.05600	0.34207	0.0000034	
Llu,6	614		4000.0	0	1	15	0.05600	0.34207	0.0000034	
Llu,7	614		4000.0	0	1	15	0.05600	0.34201	0.0000034	
Llu,S	674		4000.0	0	1	15	0.05600	0.34207	0.0000034	
Llu,9	674		4000.0	0	1	75	0.05600	0.34207	0.0000034	
Llue!O	674		8000.0	0	1	75	0.05600	0.34207	0.0000034	
LluelL	674		8000.0	0	1	75	0.05600	0.34207	0.0000034	
LiudL	614		21000.0	0	1	75	0.05600	0.34207	0.0000034	
Lieu3	614		161000.0	0	1	75	0.05600	0.34207	0.0000034	
Llul,u	674		140000.0	0	1	75	0.05600	0.14207	0.0000034	

Line / Cable resistances are listed at first splitting point.

Proj&: IMASTER THESIS
 Location: HOUN CITY- LIBYA
 Commi: IEAR EA~T UNIVERSITY EEE Department
 Engineer: SAAD MUSTAFA AL-REFAI
 Filenamo: HOUN SUBSTATION220kV

ETAP
 12.6.0H
 Date: 28-06-2016
 SN:
 Re-lsion: Base
 Config: Nomal

DESIGN OF A LARGE SCHE SOLAR SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWERGRID

2-Viudino Tran former Input pata

Transformer	ID	R.Iting				ZVariation			%TnpSetng		Adjusted	
		Imp.A	Prim.kV	S~kV	%Z	XIR	H~	,5%	%Tol.	Prim.	Ste.	%Z
T1		63.000	220.000	~000	12.50	45.00	0	0	●0	●0	J.150	±5000
T3		63.000	110.000	66.000	12.50	45.00	0	0	0	0	MIS	12.5000
T1		10.000	66.000	11.000	8.35	IMO	0	0	0	0	0	8.3500
TS		10.000	66.000	11000	10.00	10.00	0	0	0	0	0	10.0000
TS		10.000	66.000	11.000	10.00	20.00	0	0	0	0	I2SO	10.0000
T9		10.000	66.000	11000	8.35	13.00	0	0	0	0	4.375	8.3500
TIO		10.000	66.000	11.000	8.35	13.00	0	0	0	0	4.375	8.3500
TII		10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000
TU		10.000	66.000	11000	10.00	20.00	0	0	0	0	0	10.0000
TIJ		10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	8.3500
TU		10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	8.3500
TI6		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0.625	10.0000
TI7		20.000	66.000	11.000	10.00	20.00	0	0	0	0	M25	10.0000
TIS		20.000	66.000	11.000	10.00	20.00	0	0	0	0	3.750	10.0000
TI9		10.000	66.000	11.000	10.00	20.00	0	0	0	0	3.150	10.0000

Project: MASTER THESIS
 Location: HOUN CIIT-LIBYA
 Contract: JI.EAREASTU1'IVERSIY - EEE Department
 Engineer: SA'ID MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 IM.OH

Page: 6
 Date: 28-06-2016
 SN:
 Revision: Bas•
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO UBYANPOWER GRID

Brallfr.fr Collectedops

Circuit Breaker		Connected Bus ID		% Impedance, Pos. Seq., 100 MVA			
ID	Type	From	To	R	X	Z	Y
T1	2WXHMR	Bus3	Bus1	M3	1Y.18	19.29	
T3	IWXFMR	Buči	Bu7	0.13	19.28	19.29	
T4	ZWXNM	Bu1	Bu6	M1	16.98	77.Z1	
TS	IWXfMR	Bu7	Bus9	1.43	48.62	48.61	
T6	IWXFhR	Bu8	Bu10	1.29	45.14	45.80	
T9	IWXFMR	Bu13	Bu15	3.91	16.98	77.I1	
TIO	2WXFMR	Bus4	Bu16	6.30	BU.1	SZ.08	
T11	IWXFMR	Bu17	Bu19	2.19	45.74	45.80	
T12	2WXFMR	Bus8	Bu20	Z.43	48.67	48.69	
TU	IWXfAIR	Bus11	Bu22	3.92	76.98	77.21	
TU	IWXFMR	Bus13	Bu15	5.92	76.98	77.U	
T16	IWXFhR	Bus27	Bu28	1.19	45.74	45.80	
T17	IWXFMR	Bu27	Bu29	Z.29	45.74	45.80	
TIS	1, YXNM	Bus30	Bus32	W	45.74	45.80	
T19	IWXFMR	Bu31	Bus33	1.13	48.62	48.69	
Lind	Lin	Bu1	Bu14	Z.18	16.38	16.56	
LintZ	Lint	Bu1	Bu13	1.31	U.08	14.27	
Lin3	Lint	Bus1	Bus5	2.92	17.8-1	18.08	
Lln4	Lin	Bus2	Bu17	1.79	10.94	11.09	
Lin5	Lin	Bus1	Bus2	0.96	5.8-1	*.91	
Lint6	Lin	Bu~	Bu7	O.Si	3.10	3.14	
Line?	Lin	Bm1	Bu5	0.48	2.91	2.96	
Lin8	Line	Bu2	Bu7	0.51	3.10	3.14	
Lln9	Int	Bu1	Bu2	0.18	2.92	1.96	
LndO	Line	Bu12	Bus31	1.02	6.20	6.29	
Lndl	Lin	Bus1	Bu30	0.96	S.84	5.91	
Lndl	Line	Bu17	Bu21	2.51	15.32	15.52	
Liud3	Lin	Bu17	Bu23	19.23	III.16	119.0Z	
LintU	Lin	Bu21	Bu23	16.21	102.u	103.50	

Project.t: MASIER THESIS ETAP Page: 7
 Location: HOUN CITY - LIBYA 12.6.0H Date: 28-06-2016
 Contract: MEAREAST UNIVERSITY - EEE Department SN:
 Engineer: SAID STAFAL-REFAI Study Case: SC Rerisien: Base
 Filename: HOUN SUBSTATION 220kV Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIVYAN TOWER GRID

power Grid Input Data

Power-Grid	Connected Bus	Rating		% Impedance		
		LineAsc;	kV	R	X"	RIx
IN	Bu.J	22.101	210.000	45.02233	450.22330	0.10
U2	B..1	22.101	220.000	48.02n1	480.22330	ate
U3	Bu.5	21.101	220.000	45.022.13	450.22330	0.10

Totalc.mnndP<>r.rGrldt(;;3ii-1; jjj)lVA

Project: nL\STER nri:SIS ETAP Page: 8
 Location: HOUN CITY -LIBYA 12.6.0H Date: 28-06-2016
 Contract: I'EER EAST UU\ER.Sm' SN:
 Engineer: SANDnroST.U'AAL-RUAI StudyCase: SC Revision: Base
 File-Name: HOUN SUBSTATION220KY Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Lumped Load Input Data

Lumped Load ID	Couacred Bus m	Lumped Lead						Motol'Loads					
		kVA	kV	Amp	%PF	MTR	STAT	kW	mr	R	X'	RIX"	MW/PP
Lump1	Bu:ni	1UU	11.000	65.25	0.01	80	10	0.1	994.6	1.73	1S;I	0.1S	0.00
Lump2	Ba'9	13S3.S	11.000	123.53	81.00	80	10	1600.4	991.S	1.S3	1S.31	0.10	1.60
Lump3	Bu,10-	sm.1	11.000	431.26	85.00	80	20	5600.0	3471.1	1.S3	1.S.S1	0.1E	5.60
Lump4	Bns:15	7058.4	11.000	370.42	85.00	80	20	4799.7	2974.6	1.SS	1S.31	0.10	4.00
Lump5	Bu,16	7058.4	11.000	370.47	85.00	80	20	4799.7	2974.6	1.53	1S.31	0.10	4.00
Lump6	Bu:9	SS00.0	11.000	288.68	100.00	80	20	4400.0	0.0	1.S3	15.31	0.10	4.40
Lump7	Bu,,20	.1500.0	11.000	183.70	100.00	80	20	2800.0	0.0	1.73	15.31	0.10	2.80
Lump8	Bu,al	6000.0	11.000	314.91	100.00	80	10	4800.0	0.0	1.S3	15.31	0.10	4.80
Lump9	Bu,25	2351.4	11.000	123.47	85.00	00	20	1599.6	99U	1.S3	1S.31	0.10	1.60
Lump11	Bu'28	3519-Z	11.000	m.ZJ	SS.00	80	20	2399.8	1487.3	1.SS	15.31	0.10	2.40
Lump12	Bu'29	3829.I	11.000	185.13	SS.00	80	10	1,99S	1,187.3	1.S3	1.S.S1	0.10	1.40
Lump13	Bu,S3I	12941.9	11.000	679.17	85.00	80	10	8800.0	5454.8	1.S3	15.31	0.10	8.80
Lump14	BwJd	\$882.S	11.000	30B.7S	85.00	60	10	4000.0	1419.2	1.53	1SS1	0.10	4.00

Total Connected Lumped Loads (• 13), 69184.3kVA

Project: MUNSTER THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR EAST UNIV:ERSITY - EEE Department
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUII\$STATION220kV

ETAP
 12.6.0H
 Page: 9
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nonna I

DESIGN OF A LARGE SCALE SOURCE SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

SHORT-CIRCUIT REPORT QV without PV)

3-Phase fault at bus: Bus1

Nominal kV = 66.000
 Voltage c Factor = 1.0 (User-Defined)
 Peak Value = 3.352 kA MethodC
 Steady State = 0.173 kAmps

From Bus m	ToBus, m	Contribution FlonBus	Voltage & Initial Symmetrical Current (kA)			Current (kA)
			% V	kA	kA	
Bus1	Total		0.00	0.211	-2.151	10.2
Bu'13	Bus1		4.41	0.027	-0.175	10.3
Bus27	Bus1		5.37	0.081	-0.807	9.7
Bu,S	Bus1		0.57	0.016	-0.172	10.9
Bu,S	Bus1		0.57	0.016	-0.72	10.9
BuS,O	Bus1		1.29	0.044	-0.495	11.1
BuJ	Bus1		3.60	0.017	-0.172	10.3
Bus6	Bus1		5.10	0.009	-0.058	6.8
BuJS	Bu'13		29.48	0.027	-0.275	10.3
Bu'17	Bus1		11.58	0.052	-0.498	9.5
Bu,28	Bus27		11.17	0.015	-0.154	10.1
Bus29	Bu,27		13.37	0.015	-0.154	10.1
Bus10	Bus1		18.49	0.031	-0.344	10.9
Bus31	Bus30		29.80	0.044	-0.495	11.1
U1	Bu,J		96.39	0.005	-0.054	10.3
Lump1	Bus6		100.00	0.051	-0.351	6.8

Breakdown and DC Fault Current (A) Based on Total Bus Fault Current

TD (S)	Ib sym	Ibasym	Ide
0.01	2.0W	3.029	2.249
0.02	1.996	2.595	1.658
0.03	1.960	2.309	1.221
0.04	1SN	2.m	6.900
0.05	1.837	1.954	0.666
0.06	1.784	1.850	0.91
0.07	1.m	1.759	0.362
0.08	1.657	1.678	0.167

Project: MASTER THESIS
 Location: HOTN CITY - LIBYA
 Contract: NEAR-EAST UNIVERSITY - EEE Department
 Engineer: SAID WST AF A AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
12.6.0H

Study Case: SC

Page: 10
Date: 28-06-2016
SN:
ReIslon: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM IMPACT ANALYSIS OF ITS INTEGRATION TO LIBYAN POWER GRID

(Cont.)

3-Phase fault at bus: Bus1

Nominal kV	= 66.000
Voltage c Factor	= 1.10
Peak Value	= 5.352
StMdyState	= 0.173
(User-defined)	
kA	MEtbot C
kAms	

Bi-enkum and DC Fault Characteristics

Based on Total Bus Fault Count

TD(S)	Iu ym	Ibasym	Id
0.09	1.591	1.606	0.197
0.10	1.531	1.539	0.147
0.15	1.388	1.389	0.032
0.10	1.250	1.250	0.007
0.25	1.118	1.118	0.001
0.00	1.106	1.106	0.000

Project: MASTER THESIS
Location: HOI'N CITY - LIBYA
Contract: EUREAST UNIVERSITY - EEE Department
Engineer: SMD' IYSTAFA AL-REFAI
Filename: HOUN SUBSTATION 220kV

ETAP
12.6.0H

Page: ||
Date: :iS-06-2016
SN: .
Re\ision: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND WPACT A:YSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

3-Phase fault nt bus: Busl

Nominal kV = 66.000
Voltage c Factor = 1.10 (User-Defined)
Peak Value = 2.464 kA l'fethodC
Steady State = 0.184 M.nus

Contribution		Voltage & Initial Syminencl		Current (rms)	
From Bus ID	To Bus ID	% V	kA	kA	XIR kA
Bu-2	Total	0.00	0.095	-0.989	10.4 0.993
Bm1-	Bus1	4.79	0.027	-0.274	10.3 0.275
Bu,18	Bus?	2.97	0.015	-0.155	10.1 0.156
Biu7	BusZ	0.18	0.005	-0.055	10.3 0.055
Bus7	Bm2	0.18	0.005	-0.055	10.3 0.055
Bus,11	Bus1	1.77	0.025	0.167	IM 0.168
Bus\$5	Bus1	3.71	0.018	-0.151	10.3 0.151
Busl6	Bus14	29.78	0.017	-0.174	10.3 0.275
Bu,20	Bus1S	10.94	0.015	-0.155	10.? 0.156
Bu,9	Bus7	5.86	0.011	-0.111	10.3 0.111
BusJ3	Bus31	16.06	0.015	-0.167	10.6 0.168
us	Bus\$	99.38	0.005	-0.055	10.3 0.055

Bast~ on: lo,hil: Busfa.ult Currntut

TD(S)	Ibsym	Ib asym	Ide
0.01	0.952	1.408	1.038
0.01	0.1137	1.211	0.767
0.03	0.910	1.080	0.566
0.04	0.894	0.987	0.418
0.05	0.848	0.902	0.309
0.06	0.817	0.849	0.128
0.07	0.788	0.806	0.169
0.08	0.759	0.769	0.11S
0.09	0.730	0.736	0.092
0.10	0.701	0.701	0.008
e.1s	0.638	0.638	0.015
0.20	0.577	0.577	0.003
0.25	0.518	0.518	0.001
0.30	0.411	0.51%	0.000

Project: MASTER THESIS
 Location: HOUN CIIT -LIBYA
 Contract: JI'EAR EAST UNIVERSITY EEE Department
 Engineer: SAND ~WSTAF A AL-REF AI
 Filename: HOHN SUBSTATION 220kV

ETAP

12.6.0H

Page: 12
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND THIPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

3-Phas, fault at bus: Bus9

Nominal kV = 11.000
 Voltage c Factor = 1.10 (User-Defined)
 Peak Value = 10.860 kA MethodC
 Steady State = 1.005 kAms

From Bus ID	To Bus ID	Contribution		Voltage & Initial Symmetrical Current (rms)	
		% V	kA	kA	XIR
BusY	Total	0.00	0.368	0.11m	11.7 4.318
Bu-7	Bus7	30.83	0.291	-3.899	11.1 3.611
Luimpl	Bus7	100.00	0.010	-0.701	10.0 0.70?
Bus1	Bus7	31.8%	0.025	-0.300	11.1 0.301
Bus1	Bu-7	31.82	0.025	-0.300	12.1 0.301

Breakers and Line Fault Current

Based on Telco Bus Fault Current

TD(\$)	Th,ym	Ib: asym	Id<
0.01	4.09	6.256	4.669
0.01	4.173	5.494	3.514
0.03	4.131	4.154	2.134
0.04	4.038	4.415	2.092
0.05	3.880	4.199	1.605
0.06	3.780	3.4175	11.29
0.07	3.682	3.800	0.941
0.08	3.584	3.655	0.720
0.09	3.487	3.530	0.551
0.10	3.392	3.418	0.424
0.15	3.167	3.169	0.11m
0.10	2.1148	Z.948	0.029
0.25	2.736	1.736	0.008
0.30	1.1w	2.1:0	0.00?

Project: IIASTER THESIS
 Location: HOUN CITY - LIBYA
 Contract: IYEAR EAST L.I.TIVERSITI - EEE Department
 Engineer: SAND IIUSTAFA AL-REF AI
 Filename: HOIJN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: SC

Page: 13
 Date: 28-06-2016
 SN:
Re-sian; Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

3-Phase fault at bus: Bus10

NominalV = 11.000
 Voltage c Factor = 1.10 (User-Defined)
 Peak Value = 19.898 kA MethodC
 Steady State = 0.927 kAans

FromBu, ID	ToBu, ID	Contribution	Voltage	& Initial	Symmetrical	Current	(Ams)
			FromB~	M.	kA	XiR.	Iaguidut
Bu,10	To:1		0.00	Mt1	-1.868	11.9	7.896
Bu,i	Bu,10		46.89	MIS	-MOS	II,O	5A4
Lump3	B11'10		100.00	O.Z46	-4.460	10.0	Z.m
Bud	B..S		48.39	0.0~	-0.456	13.0	0.458
Bud	Bus8		48.39	0.03\$	-0.456	13.0	0.458

Building and Line Fault Currents [A]
BasNon Total Bus Fault Currnt

TD(J	Ib-in	Ib--in	Id<
0.01	7.671	n.sse	8.581
0.02	1.552	10.0-	6.6H
0.03	,m	9.046	0.099
0.04	7.367	U1S	3.926
0.05	1.110	Zas1	3.056
0.06	7.047	7.-1.1	Z-159
0.07	6.889	T.11S	1.816
0.08	6.716	6.861	0.011
0.09	6.W	6.633	0.084
0.10	6.315	U.J?	0.855
0.11	5.915	5.980	0.217
0.10	5.586	5.586	0.065
0.25	5.208	S.208	0.018
0.30	S.180	5.180	0.005

Project: II[ASTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAID STAFAAF-REFAI
 Filename: HOUN SUBSTATION220kV

ETAP
 12.6.0H

Study Case: SC

Page: 14
 Date: 28-06-2016
 SN:
 Revision: BASE
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Short-Circuit Supply Report QWithout PV)

3-Phase Fault Currents

Bus	ID	KV	District	Type	Device C*pdny (kA)				Short-Circuit Current (kA)		
					M:king	Ptak	lb sym	lb nonsym.	1~.,-ip-	lb sym	Ibasym~
Bus1		66.000	Bus1	Bus					1.161	~52	0.173
Bus2		66.100	Bus2	Bus					0.993	146.1	0.184
Bus9		11.0.00	Bu'9	Bus					4.318	10.8@	1.005
Bus 0		!MOO	Busto	Bus					1.s%	1.M9S	0.917

ip is calculated using method C.
 lb does not include de-rating of impedance due to load condition motion
 Ik is the maximum short circuit current at no load
 Ide is based on XIR (from Method C and lb are specified above)

LV CB duty determined based on service rating.

Total through current is used for device duty.

* Indicates a device with calculated duty exceeding the device capability.

#Indicates a device with unknown duty exceeding the device margin limit (95% of device device capability)

APPENDIX7

SHORT CIRCUIT ANALYSIS WITH PV

Project: MASIER IIn.'SIS
 Lecanón: HOUN GIT-LIBYA
 Contract: EAR EAST UTTERSILY EEE Department
 Engin : SA, ID JUSTAFAAL-REFAI
 Filename: HOIN SUBSTATION 220KV

ETAP
 12.6.0H
 StudyCase: SC

Page: 1
 Date: 28-06-2016
 SN:
 Vision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA POWER GRID

Electrical Transient Analyzer for the

Short-Circuit Analysis (With PV)

IEC 60909 Standard
3-Phase Fault Currents

	S"ing	V-Gontrol	Load	Total			
Number of Buses:	3	7	30	40			
	XFMR2	XFMR3	Reactor	Line/Cable	Innendue	Tie PD	Toffil
Number of Branches:	24	0	0	16	0	0	40

	Synch'OUS Generator	Powel' Grid	Syuchi-onous lifot-01-	Induction llachaines	Lumped Load	Total
Number of Machines:	0	3	0	0	13	16

System Frequency: 50.00Hz
 Unit Item: Mehic

Project: II[ASTER THESIS
 Location: HOUN CIIT-LIBYA
 Contract: NEAR EAST UNIVERSIT-EEE Department
 Engineer: SAND MUSTAFA Al.cREFAI
 Filename: HOUN SUBSTATION 220kV

ETAP

12.6.0H

Study Case: SC

Page: 2
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A URGE SCALE SOLAR PV SYSTEM A.1.1) DIIPACr ANALYSIS OF rrs INTEGRATION INTO LIBYA's POWER GRID

Adjustments

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer Impedance:	Yes	Individual	
Reactor Impedance:	Yes	Individu,J	
Overload Heater Resistance:	No		
Transmission Line Length:	No		
Cable Length:	No		
Temperature Con-ecction		Apply Adj-	Individual /Global
Transmission Line Resistance:	Yes	Individu	~eecc
Cable Resistance:	res		Individuul

Project: IIFASUR THESIS
 Location: HOUNCITY-LIBYA
 Comm-aci: I'EAST LIBERSITY-IE Deparment
 Engineer: SAND MISTAFAAI-REFAI
 Filenaine: HOUN SUBSTATION220kV

ETAP
 12.6.0H
 StudyCase: SC

Page: 3
 Date: 28-06-2016
 SN:
 Rerision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Input Data

		Bus			Initial Voltage		
	ID	Type	Nom.kV	Busflok	Sub-sys	%tag.	Ang.
	Bu,1	Load	66.000	68,415	1	99.39	-4.20
	Bu,11	Load	66.000	66,413	2	99.06	-1.12
	Bu,3	SWNG	220.000	220.000	1	100.00	0.00
	Bu,4	SWNG	220.000	Z20.000	3	100.00	0.00
	Bu,5	SWNG	220.000	220.000	2	100.00	0.00
	Bu,6	Load	11.000	11,413	1	98.34	-1.18
	Bu,7	Load	66.000	66,413	2	99.04	-1.23
	Bu,8	Lead	66.000	68,475	1	99.10	-4.26
	Bu,9	Load	11.000	11,069	2	98.16	-1.80
	Bu,10	Load	11.000	11,555	1	98.08	-6.26
	Bu,11	Load	66.000	66,413	2	9M6	-U2
	Bu,12?	Load	66.000	68,175	1	99.39	-4.20
	Bu,13	Load	66.000	68,475	1	98.62	-4.67
	Bu,14	Load	66.000	66,113	2	98.21	-1.74
	Bu,15	Load	11.000	11,912	1	98.98	-7.88
	Bu,16	Load	11.000	11,553	2	98.5*	-4.67
	Bu,17	Load	66.000	68,475	1	99.19	-5.86
	Bu,18	Load	66.000	66,113	2	98.91	-L59
	Bu,19	Load	11.000	11,413	1	99.02	-7.46
	Bu,20	Load	11.000	11,069	2	98.87	-2.61
	Bu,21	Lead	66.000	68,475	1	99.22	-6.82
	Bu,22?	Load	11.000	11,413	1	98.70	-9.43
	Bu,23	Load	66.000	68,475	1	99.4	-6.94
	Bu,25	I,,d	11.000	11,413	1	98.46	-7.87
	Bu,27	Load	66.000	68,475	1	9U2	-4.91
	Bu,28	Load	11.000	11,484	1	98.70	-S.76
	Bu,29	Load	11.000	11,113	1	98.70	-5.76
	Bu,30	Load	66.000	68,475	1	98.19	-4.56
	Bu,31	Load	66.000	66,413	2	98.80	-1.38
	Bu,32?	Load	11.000	11,840	1	98.1J	-1.19
	Bu,33	Load	11.000	1US4	2	100.68	-2.83
	Bu,34	C**	0.400	6,410	1	0.00	1.05
	Bu,35	G.n.	0.400	0.410	1	0.00	1.05
	Bu,36	C.*	0.400	M10	1	0.00	1.05
	Bu,37	G.n.	0.100	0.410	1	0.00	1es

Project: ILISTER THESIS ETAP Page: 4
 Location: HOUN CITY -LIBYA 12.6.0H Date: 28-06-2016
 Contract: EAR EAST UNIVERSITY -IIE Department SN:
 Engineer: SAND MUSTAFA AL-REFAI Rejisiou: Base
 Filename: HOUN SUBSTATION 2201.V Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM A.1> IMPACT ANALYSIS & FITS INTEGRATION INTO LIBYAN POWER GRID

m	Typ.	Norm.kV	Bus			Initial Voltage	
			Ba. _u t-Y	Sub- _u ~	% Mag.	Ang.	
Bu.38	0..	0.100	0.117	z	MO	3.28	
Bu.39	I.;.	0.400	0.m	2	0.00	1.28	
Bu.40	C.n.	MOO	0.397	2	0.00	3.28	
Buwl	Load	11.000	11.270	1	98.88	-1.13	
Bu-42	Load	11.000	10.930	?	98.63	1.01	
40BumTotal							

All voltage reported by ETAP are in % of bus Nominal kV.
 Bus kV values of buses are calculated and updated manually by ETAP.

Project: MASTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAREAST UNIVERSITY - EEE Department
 Engineer: SA'ID MUSTAFAAL-REFAI
 Filename: HOUN SUBSTATION2ZOKV

ETAP
 12.6.0H
 Page: 5
 Dater: 28-06-2016
 SN:
 Revision: Base
 Config: Nonual

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Line/Cable Input Data

Ohms or Siemens/1000 m per Conductor¹ (Cable) or per Phase (Line)

Line/Cable ID	Library	Size	Hugh				R	X	y
			Adj.(in)	% Tot.	#/Phas.	T(G)			
Caln.l	IMCUS3	300	100.0	0	1	15	0.07630	0.08740	0.0001646
CabJeZ	ILICUS3	100	100.0	0	1	15	0.07610	0.08740	0.00016-16
Lln.tl		674	19300.0	0	1	15	0.05600	0.17175	0.00000.n
Lln.2		614	19300.0	0	1	15	0.05600	0.34207	0.00000.4
Lln.3		674	23000.0	0	1	15	0.05600	0.14207	0.00000.IJ
Lln.4		674	15000.0	0	1	15	0.05600	0.31107	0.00000.IJ
Lln.s		674	8000.0	0	1	75	0.05600	0.3U07	0.1000034
Lln.6		674	4000.0	0	1	15	0.08600	0.UJ207	0.0000034
Lln.7		674	4000.0	0	1	15	0.05600	0.34107	0.00000.IJ
Lln.8		674	4000.0	0	1	15	0.05600	0.14107	0.0000034
Lln.9		674	4000.0	0	1	75	0.05600	0.34107	0.0000034
Lln.eJO		674	8000.0	0	1	15	0.05600	0.UJ207	0.0000034
Lln.dl		674	8000.0	0	1	15	0.056-0	0.34207	0.0000034
Lln.dZ		674	21000.0	0	1	75	0.05600	0.34107	0.0000034
Lln.U		674	161000.0	0	1	15	0.08600	0.UJ207	0.00000.IJ
Lln.dJ		674	140000.0	0	1	75	0.08600	0.34207	0.0000034

Line/Cable resistances are listed at the specified temperatures,

Project: ILLWTER THESIS
 Location: HOON CITY-LIBYA
 Contract: NEARE~T U\T'ERSITY • EEE Deparment
 Engineer: SMD iRiSTAFA AL-REFAI
 filename: HOON SUBSTATION220kV

ETAP
 12.6.0H
 StudyCase: SC

Page: 6
 Date: 28-06-2016
 SN:
 Re,;lon: Base
 Config: Nol'mal

DESIGNOF A LARGE SCALE SOLAR PV SYSTEMA,;D IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

1. Winding Transformer Input Data

Transformer	ID	Rating			Z Variation			% Tap Setting		Adjuster
		MVA	Pf in.;kV	S.c.kV	%Z	XIR	+5%	-5%	%Tol	
T1		63.000	120.000	6MOO	12.50	45.00	0	0	0	0
T3		61.000	220.000	66.000	12.50	4MO	0	0	0	0
T4		10.000	6MOO	11.000	8.35	13.00	0	0	0	0
T5		20.000	66.000	11.000	10.00	10.00	0	0	0	0
T6		20.000	66.000	11.000	10.00	20.00	0	0	0	125.0
T7		1%.000	11.000	66.000	8.35	13.00	0	0	0	-1.50
TS		12.500	11.000	60.000	8.35	13.00	0	0	0	0
T9		10.000	66.000	11000	8.35	13.00	0	0	0	0
T10		10.000	66.000	11.000	8.35	11.00	0	0	0	4.375
T11		20.000	66.000	11.000	10.00	20.00	0	0	0	0
TU		20.000	66.000	11.000	10.00	20.00	0	0	0	0
T13		10.000	66.000	11.000	8.35	13.00	0	0	0	0
TU		10.000	66.000	11.000	8.35	U.00	0	0	0	0
T16		10.000	66.000	11.000	10.00	20.00	0	0	0	0
T17		10.000	66.000	11.000	10.00	10.00	0	0	0	0.625
T18		10.000	66.000	11.000	10.00	20.00	0	0	0	3.750
T19		20.000	66.000	11.000	10.00	20.00	0	0	0	1.750
no		3.000	0.100	11.000	6.2s	6.00	0	0	0	0
rn		3.000	0.400	11.000	6.1s	G.00	0	0	0	0
rn		3.000	0.100	11.000	6.2s	6.00	0	0	0	0
ris		3.000	0.400	11.000	6.1s	6.00	0	0	0	0
T14		3.000	0.400	11.000	6.25	6.00	0	0	0	0
ris		J.000	0.400	11.000	6.2s	Mo	0	0	0	0
Il6		J.000	6.400	11.000	6.25	6.00	0	0	0	0

Project: MASTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: T'VEAREAST UU[VERSIIY -EEE Department
 Engineer: SA'AD MUSTAFA AL-REF AI
 Filename: HOUN SIIBSTATION20kV

ETAP 12.6.0H
 Study Case: SC
 Page: 7
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF ALARGESCALE SOLAR PV SYSTEM AND IIPACI A."ALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

B:3nch Connections

Ch./Branch	ID	Typ	Connected Bus ID	% Impedance, Pos. Seq., 100 MVAb		
				From Bus	To Bus	R
T1		2\VFMR	Bud	Bm1		0.43
n		2\VinR	Bu,1	Busl		0.43
T4		ZWXn.m	Bud	Bus6		5.92
TS		?WlinR	Bu,7	Bu,9		1.43
T6		I\VFIR	Bu,8	BuslC		2.29
T7		IWXFMR	Bu,42	Bud!		5.04
TS		2\WlinR	Bu,41	Bu,d1		4.74
T9		ZWXFMR	Bn,13	Busl:		8.9!
TIO		11\XFAIR	BnsH	Bm6		6.30
TU		?WXFMR	Bu,17	Bud9		2.29
TZ		2\XFAIR	Bud8	Bu,;?0		2.43
TJ		IWXFlIR	Btnll	Bus22		5.91
TU		?WXFLIR	Busl3	Bus25		5.92
Tl6		IWXFAIR	Bn,;17	Bus?S		Z,19
Tl7		IWXIIIIR	Bus27	Bn?9		2.29
TIS		ZWXFlIR	Bus30	Bu32		2.19
T19		?WXFAIR	Bu,31	Bu,;3		U1
no		2\XIIIIR	Bu,;3,t	Bns41		31.39
TU		rxnim	Bu,35	Bm41		31.39
T:22		IWXFAIR	Bu,36	Bm41		31.39
T23		IWXFlIR	Bus31	Bus41		31.39
T24		rxnim	Bu,38	Bu,;41		33.37
T25		IWXFlIR	Bu,39	Bus42		33.37
T26		2WXFAIR	Bn,;10	Bus42		33.37
Cobl1		C\bl	Bndl	Busl	0.02	0.12
Cabl2		Cobl,	Bus/Z	Bu,1	0.C1	0.C1
Lind		Lin	Busl	BusU	1.45	16.38
Line2		Unc	Busl	Bud}	2.31	U.08
Unt-3		Un,	Bu,;2	Bud8	2.92	17.84
i.u..1		Lin,	Bu,;27	Bud7	1.79	10.94
Line5		Lin,	Bud	Bu,27	0.96	5.84
Lin*6		Line	Busl	Bus7	0.51	3.10
Lin,7		Lin,	Bud	Bu,S	6.48	2.91
Lln,8		Lin,	Bus2	Bu,7	0.51	\$10
Un,9		Line	Bud	Bu,S	6.48	2.92
Lind 0		Lin*	Bud	Bu,J1	1.01	6.20
Lindi		Lin*	Bu,l	Bu30	0.96	5.84

Project: HIL~~STER~~ THESIS ETAP Page: 8
 Location: HOUN CITY LIBYA Date: 28-06-2016
 Contracte NAREASI ULTER-IY EEE Department SN:
 Engineer: SAID MUSI AFA AL-REF AI Reislon: Base
 Filename: HOUN SUBSTATION 220kV Study Case: SC Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWERGRID.

CKI/Brands		Connected Bus ID		% Impedance, Pos. Seq., 100 MVAb		
ID	Dp.	Frem Bus	To Bus	R	X	Z
Line12	Lin,	Bn,17	Bu11	AS1	IS.II	IS.II
Line13	Lin,	Bu,17	But23	19.Z1	II7A6	II9.02
Line14	Lin,	Bu;11	Bu,23	16.7!	M.U	10.150

Project: MASIER THESIS ETAP
 Location: HOUN CITY LIBYA 12.00
 Contract: NEAR EAST TVI RSITY EE Department
 Engineer: SANDI USTAFAL-REFAI Stud_Y Case: SC
 Filename: HOUN SUBSTATION 220kV Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

power Grid Input Data

PowerGrid	Connected Bus	Rating	% Impedance 100 MVA Base		
			MVA	kV	R
U1	Bu,3	11.101	11.101	210.000	4.021J3
U1	Bu,4	11.101	11.101	220.000	45.021J3
U3	Buss	21.101	21.101	220.000	48.02ZJ3

Total Connected Power Grids (=3): 66.303 MVA

Project: HOUNSUBSTATION20kV
 Location: HOUNSUBSTATION20kV
 Contrnct: NEEAREAST LIBYA
 Engineer: SANDMUSTAFAAL-REFAI
 Filename: HOUNSUBSTATION20kV

ETAP
12.0.0H

Page: 10
Date: 28-06-1016
SN:
Revisit: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND ITS ANALYSIS (ITS) INTEGRATION WITH AN OFF-GRID

Lumped Load Input Data

Lumped Load ID	Connected Bus ID	Lumped Load						Distributed Loads						% Lumped, < t Machine Base			m Faci. MW/PP
		kV	Amp	% Pf	MTR	STAT	kW	b-r	R	X"	JJX"						
Lump1	Bu16	12.13.1	11.000	63.25	0.01	80	20	0.1	991.6	1.35	IS.21	0.15	0.00				
Lump2	Bu19	ISJ,S	11.000	185.88	85.00	80	10	1600.4	991.8	1.35	15.31	MO	1.60				
Lump3	Bn1O	823S.7	11.000	432.16	85.00	80	10	5600.0	3471.1	1.35	15.31	0.10	S.60				
Lump4	Bu1S	7058.4	11.000	370.47	85.00	80	10	4799.7	1971.6	LS.	IS.31	OJO	4.80				
Lump5	Bu16	7058.4	11.000	370.47	85.00	80	20	4799.7	1144.6	1.35	IS.31	0.10	4.80				
Lump6	Bu19	SS00.0	11.000	288.68	100.00	80	20	4400.0	0.0	1.53	15.31	0.10	4.40				
Lump7	BnZ0	3S01.0	11.000	183.70	100.00	80	20	2800.0	0.0	1.53	15.31	0.10	1.80				
Lumps	B..Z1	6000.0	11.000	314.91	100.00	80	20	4800.0	0.0	LS3	15.31	0.10	4.80				
Lump9	Bus2S	2352A	11.000	121.47	SS.00	80	20	1899.6	991.4	JS3	15.31	0.10	1.60				
Lump11	B..ZS	3S19.2	11.000	185.13	SS.00	80	20	2399.8	1487.3	153	15.31	OJO	2.40				
Lump1?	Bu19	3S29.2	11.000	185.H	85.00	80	20	2399.8	1,187.3	1.35	15.~1	0.10	2.40				
Lump13	BusJ1	12941.9	11.000	679.27	85.00	80	20	8800.0	5454.8	1.35	15.31	0.10	8.80				
Lump14	BusJ	5882.S	11.000	308.75	85.00	80	10	4000.0	2499.2	1.53	15.31	OIC	4.00				

Total Connected Lumps (1 to 13): 69184.3kV~

Project: MASTER THESIS ETAP
 Location: HOUN CITY LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engineer: SAND I'fustaFA AL-REFAI Study Case SC
 Filename: HOUN SIJBSTAUN 220kV Re1siou: Base, Config: Nonnat

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AFFECTING THE INTEGRATION INTO LIBYAN POWER GRID

SHORT-CIRCUIT REPORT (With PV)

3-Phase fault at bus: Bus1

Nominal kV = 66.000
 Voltage Factor = 1.10 (User-defined)
 Peak Value = 5.368 kA [feet below C]
 Steady State = 0.232 kA rms

From Bus ID	To Bus ID	Contribution %	Voltage & Initial Symmetrical Current (kA)				
			Real	Imaginary	XIR	Magnitude	
Bus1	Total	0.00	0.327	-2.168	6.6	2.193	
BmU	Bud	0.00	0.117	-0.017	0.1	0.118	
Bus13	Bus1	~.41	0.027	-0.275	10.3	0.176	
Bd\$17	Bus1	5.11	0.081	-0.807	9.1	0.811	
B1118	Bus1	0.57	0.016	-0.016	10.9	0.173	
Bus8	Bus1	0.57	0.016	-0.171	10.9	0.173	
BuJO	Bus1	1.29	0.116	-0.495	11.2	0.497	
Bu3	Bus1	3.60	0.017	-0.172	10.3	0.171	
Bu6	Bu1	5.10	0.009	-0.058	6.8	0.059	
Bu~!	Bu,d1	8.06	0.117	-0.017	0.1	0.118	
Bud5	Bus1	29.48	0.011	-0.175	10.3	0.276	
Bu,17	Bu,27	11.55	0.051	-0.498	9.5	0.501	
Bu,18	BUS?7	11.17	0.015	-0.1~	10.1	0.188	
Bu-29	Bm27	13.17	0.015	-0.1~	10.1	0.188	
Bu,10	BusS	18.49	0.031	-0.111	10.9	0.315	
Bu131	B....10	79.80	0.041	-0.498	11.1	0.497	
U1	Bu3	36.18	0.005	-0.0~	10.3	0.0~	
Lump!	Bus6	100.00	0.051	-0.351	6.8	0.3~	

Breaking and DC fault Current (kA)

Based on Total Bus Fault Current

ID (\$)	Ib sym	Ib asym	Idc
acl	2.059	1.0,0	2.250
0.01	2.016	2.611	1.66~
0.13	1.990	2.334	1.119
0.04	1.9.11	U.17	0.89.1
0.05	1.8III	1.982	0.666
0.06	1.8I.I	J.878	O.~

Project: MASTER THESIS
 Location: HOUN CITY-LIBYA
 Contract: NEAREASTUNIT:R:STY EEE Deparment
 Engineer: SALID MUSTAFA AL-REF AI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: SC

Page: 12
 Date: 28-06-2016
 SN:
 Revision: Base
 Collfig: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND RIPIACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

(Cont.)

3-Phase fault at bus: Bus1

Nominal kV	= 66.000	
Voltage c Factor	= 1.10	(User-Defined)
Peak Value	= 3.368	kA IfethodC
Steady State	= 0.232	kArms

~~!!mJii!! and !!; Fan!! Cntr!! U !!; Al.
B-asd on T-U Bt;SF4ultCtuTtn~~

TD(S)	Ibsym	Iba\$ym	Id,
0.07	1.750	1.756	0.360
0.08	1ESS	1.706	0.U1
0.09	1.622	1.633	0.m
0.10	1.559	1.566	0.146
0.18	UIS	UIS	0.032
0.20	1.m	1.278	0.007
0.18	1.n	1.U1	0.001
0.10	1.119	1.U9	0.000

Project: MASTER THESIS
 Location: HOUN CM - LIBYA
 Contact: NEAR EAST UNIVERSITY-EEED Department
 Engineer: SM'D IIDS/LFA AL-REFAI
 Filename: HOUN SUBSTATION220kV

ETAP
12.6.0H

Page: 13
 Date: 28-06-2016
 SN:
 Revision: Ba~
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

3-Phase fault at bus: Bus1

Nominal kV = 66.000
 Voltage Factor = 1.10 (User-Dlined)
 Peak Value = 2.47; kA methodC
 Steady State = 0.221 kArms

From Bus ID	To Bus ID	Contribution	Voltage & Initial Symmetrical Current (ms)				
			%Y	kA	kA	XIR	kA
Bus1	Tot!		0.00	0.1S1	-1.000	5.4	1.017
Bus11	Bus1		0.00	0.088	-0.011	0.1	0.089
Bus12	Bus1		4.19	0.027	-0.274	10.3	0.275
Bus13	Bus1		2.97	0.015	-0.188	16.1	0.156
Bus7	Bus2		0.1S	0.005	-0.055	10.1	0.088
Bus17	Bus1		0.1S	0.005	-0.055	10.3	0.055
Bus18	Bus1		1.77	0.025	-0.267	10.6	0.268
Bus19	Bus2		3.71	0.01S	-0.183	10.8	0.184
Bu-2	Bus11		6.07	0.088	-0.011	0.1	0.089
Bus16	Bus1		29.78	0.027	-0.274	10.1	0.275
Bus20	Bus13		10.94	0.01S	-0.188	10.2	0.188
Bus9	Bus7		5.86	0.011	-0.110	10.3	0.111
Bu-3	Bus1		16.06	0.0M	-0.267	10.6	0.268
U3	Bus1		99.18	0.005	-0.188	10.3	0.055

Junction 2 and 10 in fault simulation

Ba.std on Total Bus Fault Current

TD(S)	Ib sin	Ibasym	Ide
0.01	0.971	1.124	1.038
0.02	0.960	1.1S1	0.771
0.03	0.943	1.099	0.64
0.04	0.917	1.006	0.51S
0.05	0.870	0.923	0.309
0.06	0.810	0.870	0.27
0.07	0.780	0.790	0.123
0.08	0.752	0.757	0.090
0.10	0.723	0.726	0.067
0.1S	0.659	0.659	0.015
0.20	0.596	0.596	0.003

Project: iMASTER THESIS
Location: HOUN CHIY • LIBYA
Contract: NSTITUTE OF EAST ASIAN UNIVERSITY EEE Department
Engineer: SAND MUSTAFA AL-REFAI
Filename: HOUN SUBSTATION 220kV

ETAP
12.li.OH

Page: 14
Date: 28-06-2016
SN:
Revision: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

(Cont.)

3-Phase fault at bus: Bm2

Nominal kV = 66.000
Voltage Factor = 1.10 (User-Defined)
Peak Value = 2.475 kA Method C
Steady State = 0.221 kArus

Breaking and DC Fault Current (kA)

Based on Total Bus Fault Current

TD (S)	Ib sym	Ib asym	Ide
0.25	0.511	0.537	0.001
0.30	0.531	0.531	0.000

Project: MASIER THESIS
 Location: HOUN CITY LIBYA
 Contract: NEAREAST UJL-1:VERSID- EEE Depal'ment
 Engineer: SAMIUD iNUSTAFAAL-REFAI
 Filenumber: HOUN SUBSTATION 20kV

ETAP 12.6.0H
 Page: 1S
 Date: 28-06-2016
 SN:
 Study Case: SC Revision: Base
 Config: Nonna!

DESIGN OF A LARGE SC, IESOLAR PV SYSTEM AND DIP ACT ANALYSIS OF ITS INTEGRATION INTO UBYANPOWER GRID

3-Phase fault at bus: Bus9

Nominal kV = 11.000
 Voltage c Factor = 1.10 (User-Mined)
 Peak Value = 10.909 kA
 Steady State = 1.199 kAnns

from Bus	To Bus	Voltage & Initial Steady-state Current (kA)				
		%Y	kA	kA	XIR	kA
m	ID	~	~	~	~	~
Bus9	Total	0.00	0.610	-1.347	7.1	4.390
Bus7	Bus9	31.45	0.540	.J. @	6.7	3.~
Lump2	Bus9	100.00	0.070	-0.703	10.0	0.707
BusZ	Bus7	32.46	0.045	-0.304	6.7	0.307
Bus2	Bus7	32.46	0.045	-0.304	6.7	0.307

Bi-annual and DC Fault Currents

Based on Total Bus fault Current

ID(S)	Ib sym	Ib esym	Id.
0.01	4.782	6.343	4.680
0.02	4.66	5.564	3.596
0.03	4.204	\$0.016	2.716
0.04	0.112	4.609	2.083
0.05	3.954	4.269	1.610
0.06	3.855	4.046	1.219
0.07	3.757	3.871	0.938
0.08	3.660	3.729	0.716
0.09	3.563	3.605	0.547
0.10	3.468	3.494	0.414
0.15	3.244	3.246	0.m
0.20	1.025	3.025	0.029
0.25	2.511	2.813	0.008
0.30	2.798	2.198	0.001

Project: I>USIBR THE.5IS ETAP Page: 16
 Location: HOJN 'CM- LIBYA 12.6.0H Date: 28-06-2016
 Contractor: NEAR EAST UNIVERSITY -EEE Department SN:
 Engineer: SAJID MUSTAFA AL-REF AI Study Case: SC ReVision: Base
 Filename: HOUN SUBSTATION 220kV Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

3-Phase fault at bus: BusI0

Nominal kV = 11.000
 Voltage Factor = 1.10 (User-Defined)
 Peak Value = 19.943 kA Method C
 Steady State = 1.226 kArms

From Bus	Connnection	Voltage & Initial Current (rms)			
		%V	kA	kA	XIR
r0	m				
Bus 0		0.00	0.333	7.907	9.8 7.91
Bu.S	BusI0	47.36	0.89	0.441	9.2 SA19
Lump3	Bu,10	100.00	0.246	-Z.460	10.0 L.173
Bu,I	Bu,S	48.88	0.080	JJ.460	9.2 OA6Z
BusI	BusS	48.88	0.080	0.460	9.2 MGZ

Initial Line and Bus Fault Currents

Based on Total Bus Fault Current

TD (S)	lbus,m	lbas,m	lde
0.01	7,678	11.526	8.597
0.02	7,608	10.099	6.641
0.03	1,529	9.096	5.104
0.04	7,184	8.397	3,922
0.05	7,167	7,886	3,06%
0.06	7,118	1,499	2,361
0.07	6,947	7,181	1,816
0.08	6,774	6,918	1,403
0.09	6,603	6,691	1,281
0.10	6,434	6,491	0,956
0.15	6,035	6,040	0,336
0.20	5,646	5,646	0,065
0.25	5,168	5,168	0,018
0.30	S.240	5,240	0,008

Proj&t:	MASTER ThESIS	ETAP	Page:	17
Location:	HOUN CUY LIBYA	12.60H	Date:	28-06-2016
Contract:	LIBAR EAST t:NfFERSH Y EEE Dtpar n-nt		SN:	
Engineer:	SA.ID ~fuSTAFAL-REFAI	StuL-CaSf: SC	ReVision:	Base
Filename:	BOUN ShillSTATION 220kV		Config:	Normal

DESIGN OF A URGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATIONTH TO LIBYA'S POWER GRID.

Short-Circuit Summary Report QVith f\}

3-Phas. Fault Currents

Bus	ID	IV	Delice	ID	Type	nico Capacity (kA)				Short-Ch'cuit cur..-nt (kA)			
						MildHg Peak	lb s.m	Th asym	Ide	Peak	IV	Th-m	Jba,ym
Bus1	6MOO	Bus1			Bu,					U93	8.368		0.02
Bus1	66,000	Bus2			Bus					1.011	111S		0.211
Bus9	11.000	Bus9			Bus					4.390	10.909		1.199
Bus 0	11.000	Bus0			Bu,					7,951	19.943		1.226

ip.b takunltdusing method C
lb does not include duty of non-faulted industrial motors
Ik is the minimum steady-state fault current
Ide is based on X/R from Method C and is limited by the device capability

LV CB duty determined based on service rating.

Total through current is used for dnt<1dut).

* Indicates a device with calculated duty exceeding the device up-limit.

Device with calculated duty exceeding the direct maximum limit (95 % times, device capability)

APPENDIX 8
HARMONICS ANALYSIS WITHOUT PV

Project:	IELLSIER THESIS	ETAP	Page:	1	
Location:	HOUN CTV LIBYA	12.6.0H	Date:	28-06-2016	
Contact:	NEAR EAST UNIVERSITY - EEE Department		SN:		
Engineer:	SAND misrAf AAL-REF AI	Study Case:	HA	Region:	Base
Filename:	HOUN SUBSTATION 220kV		Config:	No/tnill	

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Electrical Transient Analyzer Program

Harmonic Load flow (Without P_h)

Loading: Operating P, Q

Generation: Operating P, Q, V

Number of Buses:	Swing	V-Conn-ol	Load	~	
	3	0	26	29	

Number of Branches:	XNW	XNW	Rfactor	Lin+Capl.	Impedance	Ti.PD	ImpJ:
	15	0	0	14	0	0	29

Number of Buses, Sources:	Current	Voltage
	3	0

Number of Filters: 0

Method of Solution: Adaptive Newton-Raphson

Iteration No. of iteration: 99

Precision of Solution: 0.000100000

System Frequency: 50.00Hz

Unit SJ-tens: kV/kA

Project: -USTER THESIS
Location: HOUN CITY LIBYA
Contract: NEAR EAST lib(TVER-ITY) EEF Department
Engineer: SAND MUSTAFA AL-REFAI
rname: HOnN ShB STATION 220kV

ETAP

12.6.0H

Page: 2
Date: 28-06-2016
SN:
Revision: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Adjustments

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer Impedance:	Yes	Individual	
Reactor Impedance:	Yes	Individual	
Overload Heater Resistance:	No		
Transmission Line Length:	No		
Cable Length:	No		

Temperature Correction	Apply Adjustments	Individual /Global	Degree C
Transmission Line Resistance:	Yes	Individual	
Cable Resistance:	Yes	Individual	

Project: MASTER THESIS ETAP
 Location: HOUN, CTRY - LIBYA 12.6.0H
 Contrner: NEAREASI UNIVERSIY • EEE Department
 Engin'eer: SAND MUSI AFA AL-REF AI Study Case: HA
 filename: HOUN SUBSIDIATION 220kV Revslom Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA-POWERGRID

Bus. Input Data													
Bus	ID	kV	Sub-sys	% Mag.	Am.	Constant kVA		Constant Z		Constant I		Gtmit	% Limits
						M:W	M:U	R:V	I:frmr	M:V	Mv:ir		
Bus1		66.000	1	99.1	-30.0							10.0D	10.00
Bus1		66.000	2	98.9	0.0							10.00	10.00
Bus3		110.000	1	100.0	0.0							10.00	10.00
Bus4		110.000	3	100.0	0.0							10.00	10.00
Bus5		120.000	2	100.0	0.0							10.00	10.00
Bus6		11.000	1	98.1	-60.0	0.000	0.991	0.000	0.1-19			MO	1.50
Bu7		66.000	2	98.8	0.0							10.40	10.00
Bus8		66.000	1	99.0	-30.0							10.00	10.00
Bu9		11.000	2	98.1	-1.0	1.600	0.992	0.400	0.248			10.00	10.00
Bm10		11.000	1	97.5	-60.0	5.600	3.471	1.400	0.868			10.00	10.00
Bus11		66.000	1	98.1	-30.0							10.00	10.00
Bus12		66.000	2	98.0	0.0							10.00	10.00
Bud5		11.000	1	98.1	-60.0	4.800	2.975	1.100	0.744			10.00	10.00
Bud6		11.000	2	98.1	-5.1	4.800	2.975	1.100	0.744			10.00	10.00
Bud7		66.000	1	98.9	0.0							10.00	10.00
Bud8		66.000	2	98.8	30.0							10.00	10.00
Bus13		11.000	1	98.7	-0.0	4.400	0.000	1.100	0.000			10.40	10.00
Bus10		11.000	2	98.7	-3.3	1.800	0.000	0.700	0.000			10.00	10.00
Bus11		66.000	1	98.9	-30.0							10.00	10.00
811\$2		110.000	1	98.4	-60.0	4.800	0.000	1.200	0.000			10.00	10.00
Bus13		66.000	1	99.1	-30.0							10.00	10.00
Bm11		11.000	1	98.1	-60.0	1.600	0.991	0.100	0.248			10.00	10.00
Bud7		66.000	1	98.8	0.0							10.00	10.00
Bus15		11.000	1	98.4	-0.0	1.000	1.487	0.600	0.372			10.00	10.00
Bm19		11.000	1	97.9	-60.0	1.400	1.487	0.600	0.372			10.00	10.00
Bus30		66.000	1	98.5	0.0							10.00	10.00
Bu<11		66.000	2	98.6	0.0							10.00	10.00
Bus32		11.000	1	98.0	-60.0	8.800	5.455	1.200	1.164			10.00	10.00
Bu<12		11.000	2	100.5	0.0	1.000	1.419	1.000	0.620			10.00	10.00
Total Number of Buses~ 19						41.999	11.307	12.000	S.8Z7	0.000	0.000	0.000	0.000

Generation Bus				Voltage		Queratio			M-min-Limits	
ID	kV	Type	Sub-sys	% Mag.	Angle	MW	lfrar	.iPF	Max	Min
Bud	210.000	Sl:im	1	100.0	0.0					

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIDYIA'S POWER GRID

Generation Bus				Voltage		Generation			Limits	
ID	kV	Type	Sub-sys	%Mtg.	Au;lt	MW	Mnu	%PF	Max	Min
Bu:a	110.000	Swing	3	100.0	0.0					
Bus5	22.0000	Swing	2	100.0	0.0	0.000	0.000			

Project: MASTER THESIS ETAP
 Location: HOUN CITY - LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND MUSTAFA AL-REFAI SN:
 Filename: HOUN SUBSTATION 220kV Study Case: HA Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Cable Length Data

Cable ID	Library	Size	Length							
			#Tol	#Phase	T (°C)	R1	X1	Y1	R0	X0

Cable resistances are listed in the Iptdfidt temperature part

Initial Line Input Data

Ohms or -lhos 11000 m per Phase

Line ID	Library	Size	Length	Adj(m)	%Tol.	#Phes	T (°C)	R1	X1	Y1	R0	X0	Y0
Line1	674	moo.o	0.0	1	15	0.056003	0.374255	.0000010	0.200077	1.60791	.000007		
Line2	674	moo.o	0.0	1	75	0.056001	0.342069	.0000014	0.100037	unon	.000016		
Line3	674	23000.0	0.0	1	15	0.056001	0.340919	.0000034	0.1000m	L.14041	.000016		
Line4	674	15000.0	0.0	1	15	0.056001	0.342009	.0000034	0.200037	1.411041	.000016		
Line5	67J	0000.0	0.0	1	75	0.056001	0.342069	.0000034	0.200637	U1041	.000016		
Line6	674	4000.0	0.0	1	75	0.056001	0.341009	.0000034	0.100637	L.14041	.000016		
Line7	674	4000.0	0.0	1	75	0.056001	0.34069	.0000034	0.200637	1.424041	.000016		
Line8	674	4000.0	0.0	1	75	0.056001	0.342069	.0000034	0.1000m	U14041	.000016		
Line9	674	4000.0	0.0	1	75	0.056001	0.342009	.0000034	0.200637	1.424041	.000016		
Line10	674	8000.0	0.0	1	15	0.066001	0.34069	.0000034	0.200637	1.424041	.000016		
Line11	674	8000.0	0.0	1	15	0.066001	0.342069	.0000034	0.200637	1.424041	.000016		
Line12	674	11000.0	0.0	1	15	0.066001	0.342069	.0000034	0.100637	1.424041	.000016		
Line13	614	161000.0	0.0	1	75	0.056001	0.342069	.0000034	0.100637	1.424041	.000016		
Line14	67J	140000.0	0.0	1	75	0.056001	0.341009	.0000034	0.200637	1.424041	.000016		

Unterstants art listNI -tih, iptdfidt temperatures

Project: IIIASTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engineer: SAID -WSTAFAL-REFAI
 Filename: HOUN SUBSTATION220KV

ETAP
 12.6.0H
 Page: 6
 Date: 28-06-2016
 SN:
 Revisor: Base
 Config: No.nnal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

2-Vinding Transformer Input Data

Transformer	Rating	Z Variation						% Tap		Adjus-t*d	Plus. Shift	
		MVA	Prim.kV	Sec.kV	% 2	XIR	+5%	-5%	% Tol.	Priin.	Sec.	% 2
T1	~.000	110.000	66.000	12.50	45.00	0	0	0	0	0	0	11.5-000
T3	61.000	210.000	66.000	12.50	45.00	0	0	0	0	0	0	11.5000
H	10.000	66.000	11.000	3.33	13.00	0	0	0	0	0	0	3.35-00
TS	10.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000
!6	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000
T9	10.000	66.000	11.000	8.33	13.00	0	0	0	0	0	0	8.35-00
TIO	10.000	66.000	11.000	8.33	13.00	0	0	0	0	0	0	8.3500
TII	10.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000
TU	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000
!13	10.000	66.000	11.000	8.33	13.00	0	0	0	0	0	0	8.3500
TU	10.000	66.000	11.000	8.33	13.00	0	0	0	0	0	0	8.3500
!16	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000
T17	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000
TIS	20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	0	10.0000
TJ9	20.000	66.000	11.000	10.00	10.00	0	0	0	0	0	0	10.0000
												D)u

2-Vinding Transformer Grounding Input Data

Transformer	Rating	Grounding												
		Conn.	Primary				Secondary				Secondary			
ID	MVA	Prim. kV	Sec. kV	Type	Type	kV	Amp	Ohm	Type	kV	Amp	Ohm		
T1	63.000	220.000	66.000	D/Y					Solid					
T3	63.000	220.000	66.000	D/Y					Solid					
T4	10.000	66.000	11.000	M'					Solid					
T5	20.000	66.000	11.000	D/Y					Solid					
T6	10.000	55.000	11.000	Dil.					Solid					
T9	10.000	66.000	11.000	D/Y					Solid					
TIO	10.000	66.000	11.000	D/Y					Solid					
TII	20.000	66.000	11.000	III.					Solid					
T11	20.000	66.000	11.000	D/Y					Solid					
TJJ	10.000	66.000	11.000	D/Y					Solid					
T14	10.000	66.000	11.000	D/Y					Solid					
T16	20.000	66.000	11.000	D/Y					Solid					

Project: I.U.ST.ER IIIESIS
 Location: HOUN CTTY -LIBYA
 Contract: EUREAST UNIVERSITY- EEE Department
 Engineer: SAI(1> mrsTAFIA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Page: 7
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

2. Windin(1) Transformer Grounding Input Data

Grounding

Transformer ID	MVA	R _{siug}	Conn.	Primary Type	Primary kV	Secondary T1L	Secondary K
T17	10.000	-000	11.0-00	Dfl'		Solid	
T18	20.000	66.000	11.000	Dfl'		Solid	
T19	20.000	66.000	11.000	Dfl'		Solid	

Project: HIASIER THESIS ETAP Page: 8
 Location: HOUN CITY -LIBYA 12.6.0H Date: 28-06-2016
 Conn-acre NEAR EAST UNIVERSITY -EEE llipal'llnem SN:
 Engineer: SA\DMUSTAFAAL-REFAI Redsiou: Base
 Fileame: HOUN ShBSTATIOn220kV Config: Nonn-I

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

BrauchConnedfons

C'KT/Bran.h	ID	Tip<	FromBus	Connected Bu. ID	ToBus	% Positive-t-Sequence Impedance (IOOIn/ABas)			
						R	X	Z	V
	T1	IWXFMR	BuJ	Bus1		0.11	19.84	19.84	
	T1	2WliBIR	Bus\$	BuJ		0.11	19.84	19.84	
H	IWXFMR	Bud		Bus-		6.40	83.15	SJ.50	
TS	1wx:nm	Bu-7		Bus9		:L50	49.94	50.00	
T6	2WliBIR	Buss		Bus10		L...	49.94	sae	
T9	2WXD.IR	Bu-13		Bus15		MO	83.1\$	83.50	
TIO	IWXFMR	Bud.1		Bus16		MO	83.15	SJ.50	
TJ	1wim.m	Bus17		Bud9		:L50	49.94	50.00	
T11	1WXBIR	BusS		BuZ0		Z.50	49.94	50.00	
TJ	2WXFMR	Bu21		Bus11		6.40	83.1-	83.50	
T14	IWXFMr	Bus:23		Bu1S		6.40	83.15	83.50	
no	IWXBIR	Bu-17		BusZS		2.50	49.94	50.00	
T17	ZW.xnm.	Bus\$27		Bus29		Z.50	49.94	50.00	
TIS	IWXBIR	BuJO		Bus11		1.W	49.94	50.00	
T19	1wim.m	BuJI		Bus33		2.50	4M4	50.00	
L11d	l..	BrsL		Bus4		Z.48	16.58	1.677	0.1607619
L1nZ	l..	BusL		Bud3		2.48	15.16	LS.J6	0.2842266
LlnJ	l..,	Bu2		Bus\$		1.96	18.06	18.30	0.3J87157
Lln4	Un,	Bt27		Bus7		1.93	11.78	11.94	O.Zl0901S
LittS	l..:	BusL		Bu,27		1.03	6.28	M7	O.lJ78141
Uu.6	Lin,	Bu-?		Bus7		0.51	3.14	.1.18	0.05S9071
Line7	l..:	BusL		Bu'8		0.31	J.14	3.18	0.05S9071
Lines	Uh,	Bu,2		Bus7		0.51	J.14	3.18	0.05S9071
Lht9	LJnt-	Bud		Bu.S		0.S1	3.14	.1.18	0.0589071
LhdO	Uh,	Bos?		BuJI		1.03	6.28	6.37	0.1178142
Lholl	Lin,	BusL		BuJO		1.03	6.28	M7	0.1178142
Lindl	Liat	lit,17		Bus21		Z.70	16.49	16.71	0.3092612
LieuU	l..:	Bu,17		Busl3		20.70	II.M3	II.S.11	2.3710100
Lind4	l..:	Bu-I		Bus1~		18.00	109.94	111.40	2.0611480

Project: HIA.-R THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR EAST UNIVERSITY- EEE Department
 Engineer: SAJID MUSTAFAAL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 StudyCn,e: HA

Page: 9
 Date: 28-06-2016
 S.N:
 Reffilou: Base
 Config: Normal

DESIGN OF A LARGESCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Branch Impedance
Z-i-o SequenceImpedance

Cl\T/Bra.nch	IO	Type	Connected	Bus ID	% Impedance, Zer<S<q., 100 MV Ah			
					FremBus	ItuBus	RO	XO
T1	ZWXmr		Bus1	Bus4				
T3	2WXfmr		Bus5	Bus1				
H	IWXimr		Bus1	Bus6				
TS	IWXfmr		Bus7	Bus10				
TS	2VXFmr		Bus1	Bus10				
T9	IWXfmr		Bus13	Bus8				
T10	2VXfmr		Bus4	Bus16				
TU	2WX6nr		Bus7	Bus9				
T12	2VXfmr		Bus18	Bus20				
T13	ZWXfur		Bus11	Bus11				
TH	2WXfmr		Bus13	Bus1				
T16	2VXlmr		Bus27	Bus8				
T17	IWXlmr.		Bus27	Bus29				
T18	2WX:f-r		Bus10	Bus12				
T19	2VXfmr		Bus31	Bus13				
Lin1	Lin		Bus1	Bus14	M6	60.99	60.94	0.1410145
Lin2	Lin		Bus1	Bus16	8.89	63.09	63.72	0.1341983
Lin3	Lin		Bus1	Bus18	10.59	15.19	75.93	0.1899Z15
Lin4	Lin		Bus1	Bus7	6.91	49.04	49.82	0.1042992
Lin5	Lin		Bus1	Bus17	5.68	2635	26.41	0.05((262
Lin6	Lin		Bus1	Bus7	1.84	1.1ps	1an	0.0278131
Lin7	Lin		Bus1	Bus8	1.84	0.08	U.21	M278111
Lin8	Lin		Bus1	Bus7	1.84	13.08	13.21	0.0Mm
Lin9	Lin		Bus1	Bus5	1.84	13.05	13.21	0.0278131
Lin10	Lin		Bus1	Bus31	3.68	26.15	26.41	0.0556162
Lin11	Lin		Bus1	Bts30	3.68	26.15	26.41	0.05((262
Lin12	Lin		Bus17	Bus11	5.67	68.65	69.33	0.1460189
Lin13	Lin		Bus17	Bus23	74.16	526.33	5.11.11	1.1194780
Lin14	Lin		Bus11	Bus23	64.48	457.68	46.10	0.9734595

Project: HOUN CITY-LIBYA
Locnfen: NEAR EAST UNIVERSITY • EEE Depririn.nu
Connact: SAJ1> ijlSTA1A AL-REFAI
Engineer! Study Case: HA
Filename: HOUN SUBSTATION 220kV

ETAP
IZ.MH

Page: 10
Date: 28-06-2016
SN:
dsion: Base
Config: Nonnnl

DESIGN OF AUR.GE SCALE SOLAR PV SYSTEM AT IDL|PACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Machine Input Data

Machine ID	Type	Connected Bus	Rating (Base)			% Negati. Se- Imp.			Ground.ip.g	Amp	% Zero Seq. Imp.
			MVA	IV	RPM	XR	III	X!			
U1	Grid	Bus.1	1.1E1	120.000	10.00	9.9~	-9.-I	Wye	Solid	10.00	35.648
U2	Grid	Bus.2	1.101	220.000	10.00	MSO	99.50	Wye	Solid	10.00	17.738
U3	Grid	Bus.3	22.101	110.000	10.00	99.50	99.50	Wye	Solid	10.00	17.738

Project: MASIER TiiESIS
 Location: HOUN QTY-LIBYA
 ceurrae: NEAR EAST IJJAVERSITT • EEE Depar'nneut
 Engineer: SAND MUSTAFAAL-REFAL
 filename: HOUN SUBSTATION 220kV

ETAP
 12.5.0H
 Study Case: HA

Page: 11
 Date: 28-06-2016
 SN:
 Redson: Base
 Config: Nominal


DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

ffamonic Libraj'.

Current Harmonic Source in %

Manufactur'r: ABB																	
Model:	ACS600 UP																
Ordr-r	Freq. Hz	Mag. %	Or&r	Freq. Hz	Itag. %	Ordt-r	Freq. Hz	Mag. %	Ordn	Freq. Hz	Mag. %	Ordr	Freq. Hz	Itag. %	Or-dtt	Freq. Hz	Mag. %
1.00	50.00	100.00	5.00	150.00	1.60	1.00	350.00	1.60	11.00	556.00	3.70	13.00	650.00	3.70	11.00	850.00	0.50
19.00	950.00	0.30	23.00	1150.00	0.10	25.00	1250.00	0.50									

Manufactur'r: ABB																	
Model:	ACS600 12P																
Ordr-r	Freq. Hz	Mag.	Ordr	Freq. Hz	Itag. %	Or-dtr	Freq. Hz	Mag.	Ordr	Freq. Hz	Mag.	Ordr	Freq. Hz	Itag. %	Ordu	Freq. Hz	Mag.
1.00	50.00	100.00	5.00	150.00	1.60	7.00	350.00	1.60	11.00	556.00	3.70	17.00	750.00	1.60	17.00	850.00	0.50
19.00	950.00	0.30	23.00	1150.00	0.10	25.00	1250.00	0.50									



Project: IUSTE:RTHB1S
 Location: HOUNCITY-LIB\A
 Contract: NEAR EAST h1\IVERSITY- EEE Department
 Engineer: SALI\IUSTAFAAL-REFAI
 Filename: HOUNS-iBSTATION220kV

ETAP
 12.6.0H
 Study Cis.: HA

Page: 12
 Date: 28.06.2016
 SN:
 Revision: Base
 Config: Nol'wal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND ITS ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

HarmoNk Source Title Library

HarmoNk, \$9,ource Information-QP

BnsID	Device ID	Manufac,ur.r	Mod.!	Fund.Frq.	Mod.Fnl.
Bus1	U1	Curmit	ABB	ACS600 IIP	0.00
Bus2	U2	Current	ABB	ACS600 12P	0.00
Bus5	U3	Current	ABB	ACS600 IIP	0.00

Project:	MASTER THESIS	ETAP	Page:	13
Location:	HOUN CHIY LIBYA	12.60H	Date:	28-06-2016
Contract:	NEAR EAST UNIVERSITY - EEE Department		SN:	
Engineer:	S. Al-REFAI	Study Case: HA	Revision:	Base
Filename:	HOUN.stBSTATION?OkV		Config:	Normal

DESIGN OF A LARGESCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

(fundamental) Load Flow Report (Without PV).

Bus	ID	Voltage		Generation		Load		ID	Load Flow			%PF	%Tap
		kV	Mag.	Ang.	AIW	lfrnr	MW		MW	hfolt'	Amp		
Bus1		66.000	95.550	-38.0	0	0	0	0	Bus13	8.8U	3.883	6.U	8.~
									Bu-17	19.134	1.494	17M	99.7
									Bm8	3.815	1.248	37.4	S.5
									Buss	3.415	1148	37.1	83.8
									Bus30	10."3	7.536	119.7	81.7
									Bus3	-41889	-15.638	425.6	91.6
									Bus6	0.101	1.130	11.1	0.1
Bus2		66.000	98.167	28.1	0	0	0	0	Bus14	5.~1	3.915	63.0	SI.3
									Bus18	3.480	-0.141	31.1	-99.8
									Bus?	0.991	0\$72	10.2	86.6
									Bus7	0.191	0.5H	10.1	86.6
									Bus31	4.939	3.144	SZ.1	84.4
									Buss	-16.103	-7.961	IS.1S	89.9
* Bus3		10.000	100.000	0.0	41.694	23.334	0	0	Bu.1	41.69.1	Z3.J4	117.7	87.7
* Bus5		220.000	100.000	0.0	16.118	S.637	0	0	Bus?	16.318	8.637	-48.5	88.4
Bus6		11.000	94.178	-65.0	0	0	0.000	1,217	Bud	0.000	.L217	67.6	0.0
Bu.7		66.000	98.2.2	18.1	0	0	0	0	Bus?	-0.991	-0.618	1M	84.8
									Bm2	-0.991	-0.118	10.4	84.8
									Bus9	1.98\	1.156	10.9	84.8
Bus8		66.000	98.4S7	.35.1	0	0	0	0	Bus1	-.3.IU	-2.296	37.7	83.0
									Bud 0	6.818	4.592	1S.J	a.0
Bu.9		11.000	97.5.8	-1.,	0	0	1.981	1.228	Bus7	-1.981	-1.ns	lls.4	88.0
Bm10		11.000	91.940	-67.Z	0	0	6.809	U:U	Bu.8	-6.809	-4.2U	452.1	85.0
Bud3		66.000	94.766	.38.5	0	0	0	0	Bus1	-5.818	-4.057	68.S	S1.1
									Bus8	5.8'8	4.057	65.S	S1.1
B~14		66.000	97.1.10	17.6	0	0	0	0	Bus1	-888	-4.077	64.1	82.1
									Bus6	8.888	4.017	64.3	S1.1
Bud5		11.000	90.937	<SM	0	0	5.792	J.590	BusU	-5.191	-3\$90	393.1	85.0
Bu.16		11.000	93.691	-5.3	0	0	5.853	3.627	Bu-U	-5.853	-3.627	385.8	85.0
Bus7		66.000	98.181	.3M	0	0	0	0	Bns17	-13.782	-2..61	114.ll	-98.1
									Bus1	6.810	-1.18E	60.7	-98.5
Bus18		66.000	98.179	17.8	0	0	0	0	Bu2	1.370	-1..181	18.8	-67.9
									Bus20	5.403	0.161	49.6	100.0
Bu.99		11.000	95.099	-68.5	0	0	5.395	0.000	Bu.17	-5.395	0.100	197.7	100.0

Project: ~L.\&TER THESIS

ETA

Page: 14

Locations HOUN CITY LIBYA

12.< i.OH

Datum 28.06.2016

Contract: NEAR EAST UNIVERSITY - EEE Department

Date _____

ECE-201 ENGINEERING ELECTRICAL MACHINES

•SN:

Etlevamer HOUN SIITSTATION 220kV

Relis.iou: Base

DESIGN OF A LARGE SCALE SOLAR-PV SYSTEM AND THIPACI ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

* Indic:dl'\$u Yoltagrtgul:ntdbus (↳inrgt <ntroUtdci's:niug type.m.'(thi:nttonitdtd to it)
indk:itts a bus mitha Jod minmitch()fmo~ th:nO.I.MVA

Project: MASTER THESIS
 Location: HOUN CITY - LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: HA

Page: 15
 Date: 28-06-2016
 SN:
 Revision: Bas
 Config: Nonna l

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

System Hün;moniç Bus İnfürtüratıon

ID	Bus	kV	Voltage Distortion								
			Fund. %	RMS %	ASPL. %	nui %	TIF	mm %	TSID %	THDG %	mos %
Bud		66.000	95.55	95.5J	109.35	7.11	147.90	0.00	0.00	7.71	7.71
BU\$2		36.000	98.17	98\$S	113.93	U6	131.63	0.00	0.00	7.66	7.66
'Bun3		220.000	100.00	100.61	121.75	II.0S	129.91	0.00	0.00	11.08	11.08
Bu-		110.000	100.00	100.17	115.06	7.31	121.60	0.00	0.00	7.32	7.32
#" Bu\$6		11.000	94.48	94.76	108.14	7.71	148N	0.00	0.00	7.71	7.71
Bu7		66.000	98.24	98.53	113.91	7.67	m.11	0.00	0.00	7.67	7.67
Bu\$5		66.000	95.46	95.74	109.II	7.69	147.SI	0.00	0.00	7.69	7.69
Bus9		11.000	91.56	97.83	III.SI	7.53	128.35	MO	0.00	7.5J	7.53
Bml0		11.000	91.94	93.16	10U7	6.88	126.99	0.00	0.00	6.88	MS
Bus3		66MO	94.77	95.04	108.45	7.67	148.38	0.00	0.00	7.67	7.67
Bml4		66.000	91.44	97.71	1USS	7.60	131.01	0.00	0.00	7.60	7.60
Buds		11.000	90.94	S1.11	101.60	6.26	III.48	0.00	0.00	6.16	6.16
Bu16		11.000	93.69	93.BS	106.01	6.36	1OU1	0.00	0.00	6.36	6.36
Bud?		66.000	95.28	95.SI	108.29	7.04	131.44	0.00	0.00	1.01	1.04
Bus16		66.000	96.18	98.48	IIIC11	7.83	136.15	0.00	0.00	7.83	7.83
B1D19		11.000	95.10	95.30	107.11	6.50	118.89	0.00	0.00	6.50	6.50
Bus20		11.000	98.07	98.35	IIJ..II	7.53	128.6-1	0.00	0.00	7.53	7.3
Bus21		66.000	95.28	95.49	105.SS	6.70	136.U	0.00	0.00	6.70	6.70
Bml?		11.000	-9.47J	94.88	105."6	5.48	99.u.	0.00	0.00	SAS	5.48
BuZ3		66.000	95.54	95.99	11M3	9.70	149.73	0.00	0.00	SI.70	9.70
Bu\$6S		11.000	94.32	91.73	111.68	9.32	UI.77	0.00	0.00	9.42	9.31
Bn?1		66.000	95.25	95.S1	108.41	J.39	135.IS	0.00	0.00	1.39	7.39
Ba.U		11.000	94.10	94.JJ	106.78	7.15	132.37	0.00	0.00	1.15	1.15
Bu\$29		11.000	94.20	94.14	106.78	7.15	m.37	0.00	0.00	7.1S	7.1S
Bus30		66.000	9U4	98.31	108.38	7.54	144.38	0.00	0.00	7~	7.54
s.,31		66.000	98.01	98.30	113..S	7.64	131.13	0.00	0.00	7.64	7.64
BunJ?		11.000	90.86	91.03	101.33	6.16	110.97	0.00	0.00	6.16	6.16
Bus31		11.000	96.27	96.52	nASS	7.19	120.08	0.10	0.00	7.19	7.19

* hdktT ID (TotalHar'UlunkDittorfn)Es(tds. tht Limit.
 #dicatt nID (Indidioal Hurmonk Distol'tion) -Excittds tht limit.

Project: MUSIER THESIS
 Location: HOUN CIIT-LIBYA
 Connect: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAJID AL-REIAI
 Filename: HOUN SITBATION220kV

ETAP
 12.6.0H
 Stlur Case: HA
 Revision: Base
 Config: Normal

Page: 1S
 Date: 28-06-2016
 SN:

DESIGN OF A URGE SCALE SOLAR PV SYSTEM IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

System Harmonics Branch Information

Bus	FromBusID	ToBusID	Current Distribution											
			Fund. Amp	RMS Amp	ASU! Amp	%	rrr	IT Amp	ITI	ITR Amp	THD %	TSHD %	THDG %	THDS %
Bu_d	Bus3		-22	-27	69.43	4.18	80.84	5195.61	5195.61	Mii	0.00	0.00	4.1S	,US
	Bus17		176.61	111.29	n1.SS	8.70	143.72	25180.07	25180.07	0.00	0.00	0.00	8.70	8.70
	B_u_S		37.1U	37.47	40.83	4.88	88.47	3315.13	3315.13	0.00	0.00	0.00	4.88	4.88
	B_u_S		37.43	37.47	40.6~	4.88	88.47	Jft.13	3315.13	0.00	0.00	0.00	4.88	4.88
	BuJO		11M9	119.79	118.95	4.15	12.81	8728.96	871S.96	0.00	0.00	0.00	4.15	,US
	Bu_6		425.61	415.32	477.79	5.76	97.57	41595.09	41595.09	0.00	0.00	0.00	S.16	S.76
	Bu_6		11.1S	11.26	11.41	0.69	10.37	116.81	116.81	0.00	0.00	0.00	MO	M9
BusJ	Bus14		63.0t	63.10	68.91	4.38	70.90	4473.93	4473.93	0.00	0.00	0.00	4.38	4.38
	Bus1S		11.0S	31.20	37.41	9.70	185.H	57.6.SI	5776.SI	0.00	0.00	0.00	9.70	,9.70
	Bu.7		1E.1S	10.21	11.69	1.01	12.,s1	1302.18	10.0:US	0.00	0.00	0.00	7.03	7.03
	Bu.7		10.19	1211.	11.69	1.03	11.S1	1302.28	1301.18	0.00	0.00	0.00	7.03	7.01
	Bus.3l		SI.12	81.20	Si.0S	5.53	91.J	475.71	4151.11	0.00	0.00	0.00	5.53	5.53
	Bm5		161.51	161.79	181.75	5.93	101.60	16600.U	16600.U	0.00	0.00	0.00	5.91	SI3
Bu_J	Bud		127.-	117.90	W.~	5.76	97.57	m15.53	EZ.178.53	0.00	0.00	0.00	5.76	S.76
Buss	Bu_l		48.45	48.54	54.SZ	5.93	10:10	4980.04	4980.04	0.00	0.00	0.00	5.93	5.93
Bu_6	Bud		67.88	67.88	68.47	0.69	10.37	700.87	700.87	0.00	0.00	0.00	0.69	0.69
Bu_7	Bu_2		10.45	10.47	11.79	6.17	10.07	1100.07	1100.07	0.00	0.00	0.00	6.17	6.17
	Bu_2		10.46	10.47	11.79	6.17	105.07	1100.07	1100.07	0.00	0.00	0.00	6.17	6.17
	Bu_2		10.90	10.94	UJ.88	6.17	I0S.07	1200.14	11QO.U	0.00	0.00	0.00	6.17	6.17
BusS	Bus1		37.70	37.76	41.36	S.II	96.06	3616.42	3626.4?	0.00	0.00	0.00	S.11	S.21
	Bus1		37.70	37.75	41.36	S.z	96.06	-626.42	36Z6A?	0.00	0.00	0.00	S.11	S.11
	Bus0		75.40	75.51	SI.73	5.21	96.06	7151.54	BSZLS~	0.00	0.00	0.00	S.21	S.21
Bu_9	Bu.7		1:25.40	125.63	UJ.46	6.17	105.07	13200.84	1100.84	0.00	0.00	0.00	6.17	6.17
Bu_10	BusS		JS.24	45.1.04	496.35	S.II	96.06	43517.01	43517.0?	0.00	0.00	0.00	S.11	S.21
Bu_13	Busl		65.SS	65.62	71.16	4.57	82.80	5.133.09	5.133.09	0.00	0.00	0.00	4.57	4.57
	Bud5		65.SS	6.62	71.16	1.1	81.80	5.IJJ.09	54.13.09	0.00	0.00	0.00	.57	,U7
Bu_U	Bus1		-20.0	6.7U	70.78	4.87	78.75	5030.68	SOJ0.68	0.00	0.00	0.00	4.87	4.87
	Bus6		64.29	64.37	70.78	4.87	18.15	5030.68	SOJ0.68	0.00	0.00	0.00	4.87	4.87
Bu_15	Bud3		J93.29	393.70	J76.P1	4.7	82.80	3598.63	31598.54	0.00	0.00	0.00	4.57	4.51
Bud6	Busu		36.75	386.11	414.66	4.87	78.15	30184.05	30184.05	0.00	0.00	0.00	4.81	4.81
Bud7	Bus7		tU.0?	111.1S	154.73	10.86	177.19	?103.41	mo3.41	0.00	0.00	0.00	10.86	10.86
	des11		60.67	61.09	77.JS	11.TS	1.9.40	14625.48	14625.48	0.00	0.00	0.00	11.75	
	Bus23		18.52	19.23	%9.66	21.91	\$70.4S	6163.5	6163.15	0.00	0.00	0.00	21.91	27.97
	Bu_19		1.1.11	49.71	\$\$AO	8.99	109.65	5451.03	5.151.03	0.00	0.00	0.00	S.99	~99
Bud8	Bus1		3M8	31.06	35.68	7.30	UJ.61	3870.57	3870.57	0.00	0.00	0.00	7.30	7.30
	Bus20		J0.98	31.06	35.68	7.30	UJ.61	3870.57	3870.57	0.00	0.00	0.00	7.30	7.30
Bud9	Bus1?		197.75	198.28	332.41	5.99	!OMS	n706.U	3170U6	0.00	0.00	0.00	5.99	5.99
Bu_20	B-tl8		ISS.88	186.37	214.08	7.30	124.61	im3.44	1.Uz.3.U	0.00	0.00	0.00	7.30	7.30
Bu\$21	Bus7		60.27	60.74	77.14	11.58	ll.64	14009.08	14009.08	0.00	0.00	0.00	USS	U.SS
	Bus23		12.1s	14.16	IT.11	49.54	879.14	1254.19	125.12.29	0.00	0.00	0.00	49.51	49.54
	Bus21		51.27	SI.33	59.95	5.01	90.95	49U.45	494U5	0.00	0.00	0.00	5.01	5.01

Project: JIASTER THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engue-r: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.MH
 StudyCase: HA

Par.: 17
 Date: 28-06-2016
 SN:
 Relision: Base
 Config: Nonna!

DESIGN OF A LARGESCALE SOLAR PV SYSTEMA TIDJIIPACTAN ALYSIS QFITSI INTEGRATION INTO LIBYAN POWER GRID

Bus	Frcu Bus ID	ToBn.;ID	Fund. -Imp	R.AIS	ASUM	nm %	Cun .nt Distortion			THD	TSHD %	THDG	THDS %	
							IT	ITB	ITS					
Bmll	lu,21	Jc15,39	316.00	35M7	5.01	90.95	2968.68	Z9648.~	0.00	0.00	0.00	S.02	\$02	
Bu,13	Bus17		13.84	13.90	16.60	9.58	183.74	2554.51	2554.~	0.00	0.00	0.00	9.58	9.58
	Bus1]		7.111	W1	10.47	15.81	3169.	I\$0G.6S	2506.~	0.00	0.00	0.00	15.81	
	Bu,1S	21-4	21.39	U..1S	7.21	109.96	I'52.16	L;SL16	0.00	0.00	0.00	,11	,11	
Bu,25	Bus3	USE1	113,34	146.1a	1-1	10996	14112.98	141n98	0.00	MO	0.00	7.11	7.22	
Bu,27	Bus7		124.35	USES	154.78	10.61	1?1.11	21-5.01	i1ns.01	0.00	0.00	0.00	IMZ	10.62
	Busl		176.69	171.18	212.16	8.111	US.16	6.40.37	26780.37	0.00	0.00	0.00	8.82	8.82
	Bus2S	32.04	32.08	3S.35	***	101.36	.1184.10	378UO	0.00	0.00	0.00	5.SJ	/W	
	Bu,29	31.04	31.08	35.35	S.43	102.36	32SUO	3234.10	0.00	0.00	0.00	M.1	S.53	
Bm1S	Bus7	192.21	IS1,SI	10M	S..V	10L.16	19705.U	19705.IS	0.00	0.00	0.00	5.53	S.SS	
Bu,29	19_1,ZI	191.51	III.07	5.53	10.36	10S.1S	19705.IS	0.00	0.00	0.00	0.00	5.53	5.53	
BUS30	Busl	U0.25	U0.37	130.35	H9	80.88	97.11.70	9732.70	0.00	0.00	0.00	4.49	4.49	
	Bu,dl	II0JS	U0.37	130.35	4.49	80SS	97.11.70	9731.70	0.00	0.00	0.00	4.49	4.49	
Bus3l	Busl	52.67	52.76	5895	5.16	96.21	5075.7	5075.17	0.10	MO	0.00	5.76	5.76	
	Bus3	SL67	SL76	5895	S.76	96.U	5075.57	5075.57	0.00	0.00	0.00	5.76	5.76	
Bu,32	Bu,30	721.51	111.24	78.2.10	4.49	80.115	\$\$396.ZZ	SS396.II	0.00	0.00	0.00	4.49	4.49	
lu,33	Bus31		316.02	316.55	353.11	S.76	96.21	.1045.45	304S3.45	0.00	0.00	0.00	S.76	S.76

Project: MASIER TARSIS ETAP
 Location: LtOJN CITY -LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAMI AL-STAFIA AL-REFAI Study Case: HA
 File name: LtOJN ShillISTATION 220kV Revision: Base
 Config: Nonna!

DESIGN OF A LARGEST SOLAR PV SYSTEM AND BIPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

BUS Harmonic

Harmonic Voltages (% of fundamental Voltage)

Bus-ID: Bus1		Harmonic Voltages (% of fundamental Voltage)															
Fund. kV:	63.06.1	Hz	%	Hz	%	Hz	%	Hz	%	Hz	%	Hz	%	Ht	%		
5.00	150.00	2.21		7.00	350.00	0.54		11.00	550.00	4.71		13.00	650.00	5.58			
13.00	1150.00	0.11		25.00	1150.00	0.88								IMO	95MO		
Bus-ID:	Bu10																
Locality:	10.123																
Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mg.	Onlu	Frtq.	Mg.	Ordet	Fr-q.	Mag.	Ordtr	Freq.	Mag.
5.00	150.00	2.19	7.00	350.00	0.51	11.00	550.00	4.26	13.00	650.00	4.87	17.00	850.00	0.11	19.00	950.00	0.14
23.00	IIS0.00	0.09	15.00	IIS0.00	0.55												
Bus-ID:	Bu2																
Fund. kV:	64.856																
Order	Freq.	Mg.	Order	Freq.	Mg.	Order	Freq.	Mg.	Onlu	Frtq.	Mg.	Ordet	Fr-q.	Mag.	Ordtr	Freq.	Mag.
5.00	150.00	2.91	7.00	350.00	1.80	11.00	550.00	4.77	13.00	650.00	4.83	17.00	850.00	0.61	19.00	950.00	0.16
11.00	US0.00	0.11	25.00	IIS0.00	0.80												
Bus-ID:	Bu9																
fund. kV:	10.21																
Order	Freq.	Mg.	Ordet	Fr-q.	Mg.	Ontr	Frtq.	Mg.	Ontr	Frtq.	Mg.	Ordet	Fr-q.	Mg.	Ontr	Fr-q.	Mg.
5.00	250.00	11.3	7.00	350.00	1.79	11.00	550.00	4.69	13.00	650.00	4.72	17.00	850.00	0.61	19.00	950.00	0.35
23.00	IIS-0.00	0.11	15.00	IIS0.00	0.46												

Projerr: IL<\\$1ER THESIS ETAP Page: 19
 Lotution: HOUN CiY LIBYA 12.6.0H Date: 28-06-2016
 Contract: EAR EAST UNIVERSITY EEE Department SN:
 Engineer: SAJ(I) MUSTAFA AL-REFAI Relision: Base
 Pteuanie: HOUN SUBSTATION 220kV Config: Nonnal

DE-IGN OF A LARGE SCALERSOLARPV SYSTEM AND DIPACT ANALYSIS OF ITS INTEGRATIONINTO LIBYA.; POWER GRID

Bus Tabulation

Harmonics Voltages (% of Nominal Voltage)

Bus ID:	Bus1												Bus2											
Nom. kV:	66.000												11.000											
Order	Freq. Hz	Mag. %	Order	Freq.	Mag. %	On-dtr	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	On-dtr	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	
5.00	150.00	1.1	7.00	350.00	0.51	11.00	550.00	4.50	13.00	650.00	5.33	17.00	850.00	0.17	19.00	910.00	0.11							
11.00	1150.00	0.13	15.00	1250.00	(1.8)																			
Bus ID:	Bus3												Bus4											
Nom. kV:	11.000												11.000											
Order	Freq. Hz	Mag. %	On-dtr	Freq.	Mag. %	(h-dtr)	Freq. Hz	Mng. %	Order	Freq. Hz	Mag. %	On-dtr	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	
5.00	150.00	1.01	7.00	350.00	MS	11.00	880.00	1.96	13.00	650.00	4.53	17.00	850.00	O.21	19.00	m.00	sse.ee	0.10						
23.00	1150.00	0.08	15.00	1250.00	0.54																			
Bus ID:	Bus5												Bus6											
Nom. kV:	66.000												11.000											
Ordr	freq. Hz	?lbg. %	Otdtr	FtNj.	Mtg. %	Ordn	frtq. Hz	Mag. %	Order	Frtq. Hz	Mag. %	Ordr	Frtq. Hz	Mag. %	Ordr	Frtq. Hz	Mag. %	Ordr	Frtq. Hz	Mag. %	Ordr	Frtq. Hz	Mag. %	
5.00	150.00	2.59	1.00	350.00	1.11	11.00	880.00	4.69	13.00	650.00	4.74	17.00	850.00	Mi	19.00	950.00	0.36							
11.00	1150.00	0.11	25.00	1250.00	0.49																			
Bus ID:	Bu.9												Bu.10											
Nom. kV:	11.000												11.000											
Ordr	Freq. Hz	Mag. %	O'dtr	frtq.	Ma;	Ordr	Frtq. Hz	Mag. %	O'dtr	Freq. Hz	Ma;	Ordr	Frtq. Hz	Ma;	Ordr	Frtq. Hz	Ma;	Ordr	Frtq. Hz	Ma;	Ordr	Frtq. Hz	Ma;	
5.00	250.00	2.86	7.00	350.00	1.75	11.00	550.00	4.58	13.00	650.00	4.60	17.00	850.00	Y	19.00	950.00	0.34							
23.00	11.00	0.10	25.00	1250.00	0.45																			

Project: ETAP
 Location: HOUN CITY - LIBYA
 Contrac: NEAR EAST UNIVERSITY -EEE füparnmen
 Engineer: SANDIWSTAFAAL-REFAI
 File name: HOUN SUBSTATION220kV
 ETAP
 12.6.0H
 StudyCts.: HA
 Page: 20
 Date: 28.06.2016
 SN:
 Revision: Base
 Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM | A 1D IMPACT ANALYSIS OF US INTEGRATION INTO LIBYA'S POWER GRID

VIIHD (Individual Harmonic Distortion) Report

Bus	Voltage Distortion			
	ID	kV	Fund. %	VIIID %
Bu.6		11.000	94.48	2.23
Bus6		11.000	94.48	4.71
Bm6		11.000	94.48	5.58

Indicates buses 11th HD (Individual Harmonic Distortion) exceeding the limit

Project: MASTER THESIS
Location: HOUN CITY - LIBYA
Contract: NEAR EAST UNIVERSITY - EEE Department
Engineer: SAND MUSTAFA AL-REFAI
Filename: HOUN SUBSTATION 220KV

ETAP
12.6.0H
Study Case: HA

Page: 21
Date: 28-06-2016
SN:
Revision: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

VTHD (Total Harmonic Distortion) Report

Bus	Voltage Distortion			
	ID	kV	Fund.	VTBD
Bin3		210.00	100.00	11.65
Bu,6		11.00	94.48	7.71

Indicates buses idtb IID (Total Harmonic Distortion) exceeding the limit

Project: MASTER THESIS
Location: HOUNCITY- LIBYA
Contract: NEAR EAST UNIVERSITY -EEE Department
Engineer: SA'ID IDSTAFAAL-REFAI
Filename: HOUNSUBSTATION220kV

ETAP
12.6.0H
Study Case: HA

Page: 22
Date: 28-06-2016
SN:
Revision: Base
Config: Nonnal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEMA', DRAFT ANALYSIS OF ITS INTEGRATION INTO LIBYA's POWER GRID

Alert Summary Report

% Alert Settings

Qualifal Marginal

Indhi \leq lualBus VTHD / VIHD values are used,

Transformer

Total	100.0	95.0
Capacitor		
Inductor Amp	100.0	95.0

Capacitor

ll:a::kV	100.0	95.0
----------	-------	------

Cable

Ampacity	100.0	95.0
----------	-------	------

APPENDIX9

HARMONICS ANALYSIS WITH PV

Project: MASITR THESIS
Location: HOUN CITY- LIBYA
Contract: NEAR EAST UNIVERSITY -EEE Department
Engineer: SMI- MUSTAFA AL-REFAI
filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
Study Case: HA

Page: 1
Date: 28-06-2016
SN:
Rtisison: Base
Config: No'l'mal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Electrical Transient Analysis Program

Harmonic Load Flow (\|th PV)

Loading: OperatingP,Q

Generation: OperatingP,Q,V

Number of Buses:

SnnL	V-Control	Load	~il
3	7	30	40

Number of Branches:

moo	XFlifR3	Reactor	Line/Cable	Impedance	Tie PD	Toffl
24	0	0	16	0	0	40

Number of Banned Sources:

Qiruu!	Y~J!a2
4	0

Number of Filter:

0

Method of Solution:

Adaptive Newton-Raphson

Minimum No. of Iteration:

99

Precision of Solution:

0.000100000

System Frequency:

50.00Hz

Unit System:

Metric

Project: HUNSIERTHESIS
Location: HOUN CITY -LIBYA
Contract: NEAR EAST UNIVERSITY - EEE Department
Engineer: ASAND'HUJSTAFAAL-REFAI
Filename: HOUN SUBSTATION 220kV

ETAP
12<0H
Study Case: HA

Page: 2
Date: 28-06-2016
SN:
Revision: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND THE PACTA.IJAL'SIS OF ITS INTEGRATION INTO LIBYA.II POWER GRID

Adjustments

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer Impedance:	Yes	Individual	
Reactor Impedance:	Yes	Individual	
Overload Heater Resistance:	No		
Transmission Line Length:	No		
Cable Length:	No		

Temperatur Cerreerien	Apply Adjustments	Individual JGlobal	Degree C
Transmission Line Resistance:	Yes	Individual	
Cable Resistance:	Yes	Individual	

Project: HOUIN SUBSTATION
 Location: HOUN CITY LIBYA
 Cemraer: NEAR EAST UNIVERSITY EEE department
 Engineer: SAID AL-NISTAFI AL-REF AI
 Filename: HOIIN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: HA

Page: 3
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Input Data

Bus	ID	kV	Sub-sys	Inrush Current		Constant kVA	Constant Z		Constant I	Gmetric		% Lines				
				% Inrg	Ang.		hW	h-ar		MW	Mvar	MW	%frA	MW	Ifmr	VTH
Bus1		61.000	J	98.8	-30.0										10.00	10.00
BwZ		66.000	1	100.0	30.0										10.00	10.00
Bus3		120.000	1	100.0	0.0										5.00	5.00
Bus4		110.000	3	100.0	0.0										10.00	10.00
Bn <i>s</i>		110.000	2	100.0	0.0										10.00	10.00
Bus <i>f</i>		11.000	1	98.1	-60.0										5.00	5.00
Bus7		66.000	2	98.8	30.0										10.00	10.00
Bus8		66.000	1	99.0	-30.0										10.00	10.00
Bu\$9		11.000	1	98.1	0.0										10.00	10.00
Bus10		11.000	1	97.8	-60.0										10.00	10.00
Bus11		66.000	1	100.0	30.0										10.00	10.00
Bud1		61.000	1	100.0	-30.0										10.00	10.00
Bus13		66.000	1	98.3	-30.0										10.00	10.00
Bus14		61.000	1	98.0	30.0										10.00	10.00
Bus15		11.000	1	98.7	-60.0										10.00	10.00
Bus16		11.000	1	98.3	0.0										10.00	10.00
Bus17		66.000	1	98.9	-30.0										10.00	10.00
Bu18		66.000	2	98.6	30.0										10.00	10.00
Bus19		11.000	1	98.7	-60.0										10.00	10.00
Bus20		11.000	2	98.7	0.0										10.00	10.00
Bus21		66.000	1	98.9	-30.0										10.00	10.00
Bm1Z		11.000	J	98.4	-60.0										10.00	10.00
Bus23		61.000	1	99.3	-30.0										10.00	10.00
Bm1S		11.000	1	98.1	-60.0										10.00	10.00
Bu27		61.000	1	98.8	-10.0										10.00	10.00
Bn <i>s</i>		11.000	1	98.4	-60.0										10.00	10.00
Bw19		11.000	1	98.4	-60.0										10.00	10.00
Bus20		66.000	1	98.5	-30.0										10.00	10.00
Bus31		66.000	1	98.6	30.0										10.00	10.00
Bus32		11.000	1	98.0	-60.0										10.00	10.00
B <i>s</i>		11.000	1	100.0	0.0										10.00	10.00
Bus33		0.100	1	100.0	-50.0										5.00	\$0.00
Bu35		0.400	1	100.0	-30.0										10.00	10.00
Bus36		0.400	1	100.0	-30.0										10.00	10.00

Project: MASTER IHEYSIS
 Location: HOUN CITY-LIBYA
 Contracr: NEAR EAST UNIVERSITY-EEO.parmiut
 Engineer: SAND MUSTAFA AL-REFAI
 Filenumme: HOUN SUBSTATION 220kV

ETAP

12.6.0H

Page: 4
 Date: 28-06-2016
 SN:
 Relision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

III.	IltinlVolngt	ComtautkYA	ComtautZ	Load		Gtunif	MW	Mvar	MW	lb~r	VTID	VIUD	% Limits	
				MW	Mvar									
Bus37	MOO	1	100.0	-30.0									10.00	10.00
Bus38	0.400	2	100.0	30.0									5.00	5.00
Bus39	0.400	2	100.0	30.0									5.00	5.00
Bus40	0.400	2	100.0	30.0									5.00	5.00
Bus41	11.000	1	120.8	-60.0									10.00	10.00
Bin41	11.000	2	98.9	0.0									10.00	10.00
Total Number of Buses: 40			0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000		

Generator on Bus	ID	KV	Tpc	Subsys	Voltage		Generation			Thermal limits	
					-iAb:	Hiile	MW	Ifrat	% PF	Atu	Min
Bus1		220.000	S'ing	1	100.0	0.0					
Bus2		220.000	S'ing	3	100.0	0.0					
Bus5		10.000	S-ing	2	100.0	0.0					
Bus14		0.400	VoltageCentrl	1	100.0	JO.0	1.952			0.000	0.000
Bus15		MOO	Voltge Control	1	100.0	JO.0	1.952			0.000	0.000
Bus16		0.400	Voltage Conh'Ol	1	100.0	~0.0	1.952			0.000	0.000
Bus17		MOO	Yd1Uge Control	1	100.0	JO.0	1.952			0.000	0.000
Bus18		0.100	V-tage-Control	2	100.0	JO.0	1.952			0.000	0.000
Bus19		0.400	Voltag-Collt'Ol	2	100.0	JO.0	1.952			0.000	0.000
Bus-10		0AO0	V-raie Control	2	100.0	30.0	ui:2			0.000	0.000
					13.662	0.000					

Pr- ojek: MASTE!!..THESES
Location: HOJN COY -LIBYA
Contract: NEAR EAST UNIVERSm' -EEE Department
Engin?N: SAJLID~TAFA AL-REFAI
Ittenaue: HOUN SUBSTATION 220kV

ETAP
12.6.0H

Page: 5
Dare: 28-06-2016
SN: 1
Re:h;fon: Base
Config: Normal

DESIGN OF A L4.RGE SCALE SOLAR PV SYSTEM A."I"> IMPACT ANALYSIS OF ITS INTEGRATION II."TO UJIYA-> POWER GRID

C:\liJe Input_pata

Oinnsoillfhos /1000 m yr Conductor

Gainsformos 11000 kV Cables												
Cable ID	Ungh											
	Library	Siu	Adj. (m)	% T.L.	#Ph.e	T (G)	RI	XI	YI	RO	XO	YO
Cabtl	11MCUS3	300	100.0	0.0	1	Is	0.0001	0.00016-16	0.0401s1	0.000001	0.000001	-
Cabtl	11MCUS3	300	100.0	0.0	1	75	0.076101	0.057400	0.00016-16	0.140151	0.1H000	-

Cable resistancees are listed at the speed limit pointeratum

Tr:msmi_sfon_Line_Innput_Data

Ohms or Mhos / 1000 m per Phase

Line	ID	String of Nodes / 1000ft per Phase											
		library	Siu	Lcugth	Adj.(m)	% ToL	I(Ph..)	T(°C)	RI	XI	YI	RO	XO
Un_!			674	19300.0	0.0	1	75	0.056003	0.374155	.0000031	0.100077	1.360791	.0000017
IJtotI			614	19000.0	0.0	1	IS	0.056001	0.342069	.00000H	0.100637	1.424041	.0000016
Lin3			674	23000.0	0.0	1	75	0.056001	0.m0@	.0000034	0.100637	1.4140U	.0000016
Lin4			674	15000.0	M	1	75	0.056001	0.347069	.0000034	0.100637	1.424041	.0000016
Lin5			674	8000.0	0.0	1	75	0.056001	0.342069	.0000034	0.200m	1.414041	.0000016
Lin6			674	4000.0	0.0	1	IS	0.056001	0.342069	.0000034	0.200637	1.424041	.0000016
Une7			674	4000.0	0.0	1	75	0.056001	0.342069	.00000H	0.200637	1.424041	.0000016
UnitS			614	4000.0	0.0	1	75	0.056001	0.341069	.0000034	0.200637	1.414041	.0000016
Unt9			674	4000.0	0.0	1	75	0.056001	0.341069	.0000034	0.100637	1.424041	.0000016
IJntIO			674	8000.0	0.0	1	IS	0.056001	0.342069	.0000084	0.200637	1.414041	.0000016
Un_IU			674	8000.0	0.0	1	IS	0.056001	0.342069	0.000034	0.200637	1.414041	.0000016
LinI11			674	%1000.0	0.0	1	75	0.056001	0.341069	.0000084	0.100637	1.4140il	.0000016
IJntH			674	161000.0	0.0	1	IS	0.056001	0.III069	.0000034	0.200637	1.II0U.II	.0000016
Un_14 :			674	140000.0	0.0	1	IS	0.056001	0.342069	.0000034	0.100637	1.424041	.0000016

Lint redstoneesart lintel at the sptdfitd ttmptratul't\$

Project: JIU.SIER FTSIS
Locartion: HOUN CITY -LIBYA
Contracu MEAR EAST h1ill-ITY • UE Deparneur
Engineer: SAND MUSTAFA AL-REFAI
Filename: HOUN SOSSFATION 220kV

ETAP
12.6.0H

Page: 6
Date: 28-06-2016
SN:
Rt>ision: Base
Config: Normal

DESIGN OF ALAR>ESCALE SOLAR PV SYSTEM AND DIMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA's POWER GRID

2.-Vinding Transformer Input Data

Trnnsfonner	ID	Rating				Z Variation			oIC Tap Setting			Adj/sted	PhaseShift	
		MVA	Prim.kV	StR-kV	%Z	XIR	+5%	-5%	%Tot	Prim.	Sec.	%Z	Typt	Angle
T1		63.000	110.000	66.000	1.Z..SC	~8.00	0	0	0	0	0	12.000	D11	30.000
T3		63.000	110.000	66.000	n.s0	~8.00	0	0	0	0	0	11.woo	Dyu	~10.000
T4		10.000	66.000	11.000	6.3.<	13.00	0	0	0	0	0	8.3500	D11	30.000
T5		20.000	66.000	11.000	J0.00	20.00	0	0	0	0	0	10.0000	D/*	30.000
T6		0.000	66.000	11.000	10.00	IMO	0	0	0	0	0	10.0000	Dyn	30.000
T7		12.500	11.000	66.000	8.3S	13.00	0	0	0	0	0	8.3500	\N\nd	30.000
TS		12.100	11.000	66.000	S.3S	13.00	0	0	0	0	0	8.3500	\N\nd	30.000
T9		10.000	66.000	11.000	.35	13.00	0	0	0	0	0	8.3500	Dyn	30.000
TIO		10.000	66.000	11.000	8.35	H.00	0	0	0	0	0	8.3500	Dyu	30.000
TII		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	Dyn	30.000
ru		10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	Dyu	30.000
TB		10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	8.3500	oj11	30.000
!14		10.000	66.0-0	11.000	s+s	1s.ee	0	0	0	0	0	s.;soo	D/*	10.000
!16		10.000	66.0-0	11.000	10.00	20.00	0	0	0	0	0	10.0000	oj*11	10.0-0
T17		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	oj1>	30.000
ris		10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	D11	30.000
T79		10.000	66.000	11.0-0	10.00	10.00	0	0	0	0	0	10.0000	nl..	10.000
no		1.000	0.100	11.000	6.zs	6.00	0	0	0	0	0	6.2500	*INd	JO.000
rn		1.000	0.100	11.000	6.2s	6.00	0	0	0	0	0	6.1800	\N\nd	-30.000
T21		1.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.2500	\N\nd	-30.000
ras		1.000	0.100	11.000	S.1s	6.00	0	0	0	0	0	6.2500	\N\nd	JO.000
!14		1.0-0	0.400	11.000	6.25	6.00	0	0	0	0	0	6.2500	\N\nd	~10.000
T1!		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.1800	\N\nd	-30.000
T26		3.000	0.400	11.000	6.L	6.00	0	0	0	0	0	6.2100	\N\nd	J-0.000

2.1\`inding TransformerGlonudingInput Data

Grounding

Transformer		Rating			Conn.				Primary			Secondary			
ID	M:VA	PuinkV	S.t.kV		Tip*	Type	k\'	Amp	Ohm		Typ.	k\'	Amp	Ohm	
T1	6MOO	10.000	66.000		Dil'						Solid				
rs	6x.00-0	10.000	66.000		DIY						Solid				
T4	10.000	66.000	11.000		Dil.'						Solid				
TS	20.000	66.000	11.000		Dil'						Std				

Project: LIBSTER IHESIS
 Location: HOUN CIY • LIBYA
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engineer: SAID MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220KV

ETAP 12.6.0H Pg.: 7 Date: 28-06-2016
 Stud Case: HA Revision: Base SN:
 Con ig: Normal

DESIGN OF A LARGE SCALE SOURCE PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA POWERGRID

2-Vinding Trafo for Grouping Input Data

Transformer	Rating	Conn.	Grounding					
			T-H	Primary	Strondary	DDR	Di_Y	Di_N
ID	MYA	~	~	~	~	~	~	~
T6	20.000	66.000	11.000	D/Y		Solid		
T7	11.000	66.000	D/Y			Solid		
T8	11.500	11.000	66.000	DN		Solid		
T9	10.000	66.000	11.000	D/Y		Solid		
T10	10.000	66.000	11.000	Dil		Solid		
T11	10.000	66.000	11.000	D/Y		Solid		
T12	20.000	66.000	11.000	Dil		Solid		
T13	11.000	66.000	11.000	DIV		Solid		
TU	10.000	66.000	11.000	Dil		Solid		
T16	10.000	66.000	11.000	Dil		Solid		
T17	10.000	66.000	11.000	Dil		Solid		
T18	10.000	66.000	11.000	Dil		Solid		
T19	10.000	66.000	11.000	Dil		Solid		
T20	3.000	0.400	11.000	Dil		Solid		
T21	3.000	0.400	11.000	D/Y		Solid		
T22	3.000	MOO	11.000	DIF		Solid		
T23	3.000	0.400	11.000	DIF		Solid		
T24	3.000	0.400	11.000	DIF		Solid		
T25	3.000	0.400	11.000	D/Y		Solid		
T26	3.000	0.400	11.000	D/Y		Solid		

Project: MISTER THESIS
 Location: HOUNCHIY-LIBYA
 Contract: NEAREST VNIVERSITY-EEE Department
 Engineer: S.~1)USTAFAAL-REFAI
 Filename: HOUNSUBSTATION220kV

ETAP
 12.0.OH

Page: 8
 Date: 28-06-016
 SN:
 Revision: Base
 Config: Nonna!

DESIGN OF A LARGESCALE SOLAR PV SYSTEM: THE IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Brauch Connections

Cl, T/Bi-anch	IO	Type	Connected Bus, ID		% Positive Sequence Impedance (100MYABA ₀)			
			From Bus	To Bus,	R	X	Z	Y
T1		ZW:XM	Bus3	Bus1	0.11	19.84	19.84	
T1		::wxnm	Bus5	Bus2	0.44	19.84	19.84	
T4		?WXENIR	Bus1	Bus6	6.40	83.18	83.50	
TS		?WXFlifi	Bus1	Bus9	2.50	49.94	50.00	
T6		?WXFlifi	Bus5	Bus10	2.50	49.94	50.00	
T7		?WXF2tIR	Bus1	Bus11	5.12	6MO	~80	
TS		2WXnm	Bus1	Bus12	2.7	6MO	~80	
T9		TWXnIR	Bus3	Bus5	6.40	83.18	83.50	
T10		IWXFMR	Bus4	Bus16	6.40	83.18	83.50	
T11		?WXFlifi	Bus7	Bus9	1.80	49.14	50.00	
T12		2WXnm	Bus8	Bus20	2.50	49.94	50.00	
T13		?WXFlIR	Bus1	Bus12	6.40	83.18	83.50	
TU		?WXFlIR	Bus13	Bus25	6.40	83.25	83.50	
T16		?WXFlIR	Bus27	Bus28	2.50	49.94	50.00	
T17		1WXnm	Bus7	Bus29	1.50	49.94	50.00	
T18		IWXFIR	Bus30	Bus32	1.50	49.94	50.00	
T19		IWXFMR	Bus31	Bus33	1.50	49.94	50.00	
T20		2WXFAIR	Bus34	Bus31	34.18	205.50	208.13	
T21		?WXFlIR	Bus35	Bus41	31.11	205.50	208.13	
T22		2WXFlIR	Bus36	Bus41	34.28	205.50	208.13	
T23		1WXnm	Bus37	Bus41	30.5	205.50	208.13	
T24		2WXFMR	Bus38	Bus42	1.125	205.50	208.13	
T25		2WXFlIR	Bus39	Bus42	34.25	205.50	208.13	
T26		IWXBFfi	Bus10	Bus11	34.18	205.50	208.13	
Cable1		C.bl.	Bus1	Bus1	0.02	0.01	0.01	0.0716998
Cable2		Cabl	BusU	Bus1	0.01	0.02	0.03	0.0716998
Lin.1		Lin	Bus1	Bus14	2.48	16.58	16.77	0.0601619
Lin.2		Lin	Bus1	Bus13	1.18	15.16	15.36	0.2&12166
Lin.3		Lin	Bus2	Bus3	2.96	ISM	18.30	0.1.87157
U..1		Liu	Bus27	Bus7	1.93	1L78	1L94	0.2209015
LIn.S		Liu	Bus1	Bus27	1.03	6.28	U1	0.0589071
Liu.6		U..	Bus1	Bus7	0.51	3.14	S.18	0.0589071
Liu.7		Lin	Bus1	Bus8	0.51	3.14	S.18	0.0589071
LinS		Lin	Bus2	Bus7	0.51	3J4	J.18	0.0589071
Unt9		Lin	Bus1	Bus8	0.51	3.U	3.18	0.0589011
U..10		Lhe	Bus1	Bus31	1.03	6.18	6.37	0.1178142
LIn.11		Lin	Bus1	Bus40	1.03	6.18	6.37	0.1178142

Project: MASTER THESIS
 Location: HOUN CITT' • LIBYA
 Courier: NEAREAST UNIVERSITY- EEE Department
 Engineer: SANDumSTAFA ALcREFAI
 File name: HOUN SUBSTATION220kV

ETAP
 12.6.0H

Pag.: 9
 Date: 28-06-2016
 SN:
 -sion: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Ckt/Branch		Connected Bus ID		% Positive Sequence Impedance (IOI/IVABase)			
ID	Type	From Bus:	To Bus	R	X	Z	Y
Lind?	Line	B11'17	Bus11	1.70	16.49	16.71	0.3092622
Lintl3	Line	Bu'17	Bus23	20.70	126.43	128.11	2.3710100
Litud4	Line	Btt-21	Bus1,\	18.00	109.94	111.1C	2.0617480

Project: I:\L\SIER THESIS
 Location: HOUNCITI-UBYA
 Contract: NEAREASTUNIVERSITY-EEE-Dpartinent
 Engineer: SAID ~WSTAFAL-REPAI
 Filename: HOUNSUBSTATION20kV

ETAP
 12.6.0H

Page: 10
 Date: 28-06-1016
 SN:
 Revision: Base
 Config: Nonna!

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACTS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Jiran5:hConnedious
Zero Sequence Impedance

Ckt/Branch ID	T-P ⁿ	Connected Bus ID		0 ohm impedance	Zd<0 Seq.	100i(t)VAh	VO
		From Bus	To Bus				
T1	2WXfuu	Bus1	Bu,1				
TS	IWXfmr	Buss	Bu,l				
T4	:nVXfmr	Bud	Bus6				
T5	2 VXfur	Bm7	Bu59				
T6	:1WXfmr	Bu,S	Bu,10				
T7	2WXfmt	Bus,11	Bu,-11				
TS	ZWXfmr	Bus41	B-11				
T9	IWXfmr	Busl3	Baul\$				
TIO	2WXfmr	BusH	Busl6				
T11	2WXfmr	Bu,17	Bnd9				
T12	2WXfmr	Bud8	Bus2-0				
TU	IWXftrU	Bu,21	Btrt?2				
T14	2WXfmr	Bns23	Busl5				
T16	I VXfmr	Bu,27	Bus28				
T17	2WXbnr	Bns7	Bu19				
TIS	2WXfmr	Bu,30	Bu<12				
T19	2WXfuu	Bu,<11	8'''33				
NO	IWXfmr	Bus34	B'''41				
TN	IWXfmr	Bus35	Bu,41				
T1?	2WXl'mr	Bu,36	Bus,1tl				
T23	IWXtum	Bus,7	B'''41				
T14	2WXfuu	Bus38	Bm-1?				
T15	IWXfmt	Bus39	Bus,12				
T16	IWXfmr	Bu,40	Bus-42				
Cahid	Cable	Bus,II	Bns1	0.06	0.08	0.07	
Cabl-1	Cabl,	Busll	Bud	0.06	0.08	0.07	
Lind	Lin*	Busl	Busl-I	8.86	60.29	60.94	0.u1om
Uae-2	Lint	Bud	Bm13	8.89	63.09	63.72	0.1341983
LiuJ	Lint	Busl	Bm18	10.89	15.19	15.91	0.I999ISS
Lint4	Lin*	Bus,?7	Ba,17	6.91	49.04	49.52	0.1042992
Lue-5	Lin,	Busl	Bm?7	3.68	16.15	%6.41	0.0556262
Lw6	Lue	Bu,2	Bu-7	1.84	13.08	13.%1	0.0mm
Lint7	Line	Busl	B,,S	1.84	11.08	13.21	0.0278131
Lin,S	Liu,	Bts2	Bu47	1.84	11.08	13.21	0.OI78U1
Liu,9	Lint	Busl	B,,8	1.84	13.08	13.21	0.0278131
LinJO	Lint	Bu-l	B,,31	1.68	16.15	26.41	0.05;6262

Project: HOUNSUBSTATION
Location: HOUN CITY-LIBYA
Contract: NILEAST UNIVERSITY- EEE.Department
 Engineer: SAID STAFAL-REFAI
 Filename: HOUNSUBSTATION220kV

ETAP
12,6,0H

Study Caso: HA

Page: 11
 Date: 28-II-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND PACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Cl\,v/Bnincb	ConnectedBns ID				% Impedance, Zero seq., 100% I'Ab			
	ID	Tn>t	From Bus	To Bu-	R0	X0	Z0	Y0
Linell	Lline	Bud	BU>30		3,68	26.18	26.41	0.083m
Lintll	Line	Bu,17		Bt611	9.67	68.65	69.33	0.1460189
Lintl3	Liae	Bu,17		Bu\$23	74.16	S26.33	531.53	1.1194780
Lintel4	Llin	Butll		BmZ3	6U8	487.68	61.10	0.9734595

Project: IIASIER. IBESIS
 Location: IIOUN CTY-LIBYA
 Contract: IYEAR EAST UNIVERSITY - EEE Dpartinenc
 Engineer: SAID UUSTAF J.AL-RETAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H

Study Case: HA
 Revistom Base
 Config: Normal

Page: 12
Date: 28-06-2016
SN:

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND THURST ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Machine Input Data

Machine	Connected Bus			Rating(Base)			% Negattve Seq. Imp.			Grounding			% Z.i.o Seq. Imp.		
	ID	Type	ID	MVA	IV	Rl/M	XIR	JU	XI	Conn.	Typ.	Amp	XIR	RO	XO
U1		Grid	Bus3		22.101	220.000	10.00	9.950	99.50	Wye	Solid		10.00	3M.CS	356.48
U2		Grid	Bus1		22.101	110.000	10.00	9.950	99.50	Wye	Solid		10.00	17.738	177.38
U3		Grid	B.S.		22.101	120.000	IMO	9.9,0	99.50	Wye	Solid		10.00	17.738	177.38

Project: HOUN SUBSTATION 220KV
 Location: HOUN C.I.Y - LIBYA
 Contractor: QATAR UNIVERSITY - EEE Department
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220KV

ETAP
 12.6.0H
 Page: 13
 Date: 28-06-2016
 &
 Revision: Base
 Config: Normal

DESIGN OF A URGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Harmonic Library

C:\Ufficio\faa\run\equlc_0.1ff -i ut.00

Manufacturer: Typkal-IEEE																			
Model: 12 Pulse2		Ordr.	Freq. Hz	Mag. %	Ordr.r	Freq. Hz	Ldg. %	Ordr	Frtq. Hi	Mag.	Ordr.r	Frtq.	Mag.	Ordr	Frtq.	Ibg.	Or.&r	Freq.	Mag.
1.00	\$0.00	100.00	11.00	SS0.CO	8.10	13.00	650.00	6.70	21.00	1150.00	2.80	15.00	1150.00	2.10	1750.00	JMO	1150.00	1.10	1150.00
37.00	1850.00	0.60	17.00	1150.00	0.20	49.00	2450.00	0.10											

Manufacturer: Typkal-IEEE																			
Model: 12 Pulse2		Ordr.	Freq. Hz	Mg. %	Ordr	Freq. Hz	Mg. %	Ordr	Freq. Hz	Mg.	Ordr.r	Freq. Hz	Mg.	Ordr	Freq. Hz	Mg.	Ordr	Freq. Hz	Mg.
1.00	sce	100.00	11.00	550.00	8.10	13.00	650.00	6.70	23.00	1150.00	2.80	1150.00	1.10	350.00	1150.00	0.50			
37.00	1850.00	0.60	11.00	2350.00	0.20	49.00	US0.0D	0.20											

Manufacturer: Typkal-IEEE																			
Model: 12 Pulse2		Order	Freq. Hz	Mg. %	Ordr	Freq. Hz	Mg. %	Ordr	Freq. Hz	Mg.	Ordr.r	Freq. Hz	Mg. %	Ordr	Freq. Hz	Mg.	Ordr	Freq. Hz	Mg.
1.00	\$0.00	100.00	11.00	SW0.D	8.10	13.00	650.00	6.70	23.00	1150.00	2.80	1150.00	1.10	350.00	1150.00	0.50			
37.00	1850.00	MO	7.00	1150.00	0.20	19.00	UW.00	0.0%											

Manufacturer: Typical-IEEE																			
Model: 12 Pulse2		Ordr.	Frtq. Hi	Mg. %	Ordr.r	Freq. Hz	Mg. %	Ordr	Freq. Hz	Mg.	Ordr.r	Frtq.	Mg.	Ordr	Frtq.	Mg.	Ordr	Frtq.	Mg.
1.00	\$0.00	100.00	11.00	S0.00	8.10	11.00	650.00	6.70	23.00	mo.00	2.811	15.00	1150.00	2.30	35.00	1150.00	0.50		
37.00	1850.00	MO	1.00	%3S0.00	0.20	49.00	:US0.00	0.20											

Project: JUSTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAR EAST UNIVERSITY-EEE Department
 Engineer: SAND MUSTAFAAL-REFAI
 Filename: HOUN SUBSTATION220kV

ETAP
 12.6.0H
 Study Case: HA

Page: 14
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Harmonic Source from Library

Bu.ID	Device ID	Harmonic Source Information				
		~	Manufacturer	Model	Fund. Freq.	Mod. Freq.
Bus34	In\11	Cmmut	typkrd-IEEE	11Puls,1	0.00	0.00
Bus3-	In\15	Currnt	Typkul-IEEE	12 Pulse-1	0.00	0.00
Bus37	In\18	Currtot	Trpkrd-IEEE	11Pulse-1	0.00	0.00
Bus39	In\1	Curi.ttt	Typkul-IEEE	12 Puls1	0.00	ae0

Project: ~IASIER THESIS
 Location: HOIIN CITY -L BYA
 Contract: NEAR EA.SI !!! TTERSJT EEE Department
 Engineer: SAND MUSIAF A.A.-REFAI
 Filenane: HOIIN SUBSTATION 220kV

ETAP 12.6.0H
 Study Case: HA
 Page: 15
 Date: 28-06-2016
 SN:
 Refution: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO IJBYAN POWER GRID

Final Load Flow Report

Bus	Generation						Load Flow						XFLR
	ID	11	21	31	41	51	61	71	81	91	101	%Tap	
Bus1	66.000	101.039	-29.1	0	0	0	0	Bw.U	-7.726	0.622	67.1	-99.7	
								BusU	0.000	0.290	28	0.0	
								Bus17	0.014	0.291	42.6	-0.3	
								Buss	0.000	0.060	08	0.0	
								BusS	0.000	0.000	0.5	0.0	
								Bus10	0.000	0.120	1.0	0.0	
								Bus3	7.712	>180	SM	83.0	
								Bus8	MOO	MOO	0.0	0.0	
									-1.199	0.384	50.5	-99.8	
Bus1	66.000	100.109	-10.	0	0	0	0	Bns.ll	0.000	0.261	1.3	0.0	
								Bus14	0.000	0.000	3.0	0.0	
								Bus18	0.000	0.010	3.0	0.0	
								Bus7	0.000	0.059	AS	0.0	
								Bm7	0.000	0.059	AS	0.0	
								Bn.ll	0.000	0.115	1.0	0.0	
								Buss	S.m	CUS.1	50.5	99.7	
*Bus\$	220.000	100.000	0.0	-7.708	.S.OU	0	0	Bus1	-7.708	0.000	24.1	85.8	
"Bus5	20.000	100.000	0.0	-5.198	-0.386	0	0	Bus1	-5.798	0.386	15.1	99.8	
Bus6	11.000	101.039	.SS.1	0	0	0	0	Bud	0.000	0.000	0.0	0.0	
Bus7	66.000	100.110	30.7	0	0	0	0	Bus1	0.000	0.000	0.0	0.0	
								Bns2	0.000	0.000	0.0	0.0	
								Bm9	0.000	0.000	0.0	0.0	
Bu.a	66.000	101.040	-19.J	0	0	0	0	Bud	0.000	0.000	0.0	0.0	
								Bus1	0.000	0.000	0.0	0.0	
								Busl0	0.000	0.000	0.0	0.0	
Bus9	11.000	100.110	0.7	0	0	0	0	Bus?	0.000	0.000	0.0	0.0	
Bud 0	11.000	101.040	-59.J	0	0	0	0	Buss	0.000	0.000	0.0	0.0	
Busll	66.000	100.110	30.7	0	0	0	0	Bus1	5.799	0.456	50.5	-99.7	
								Bustil	S.m	OA56	50.8	-99.7	
Busl?	66.000	101.041	-29.1	0	0	0	0	Bus1	7.726	0.695	61.2	-99.6	
								Bu..l	-7.7M	0.000	61.2	-99.6	
Bus.I	66.000	101.061	-29.1	0	0	0	0	Bud	0.000	0.000	0.0	0.0	
								Bud5	0.000	0.000	0.0	0.0	
Bud4	66.000	100.130	30.7	0	0	0	0	Bus?	0.000	0.000	0.0	0.0	
								Busil	0.000	0.000	0.0	0.0	
BusJS	11.000	101.061	-59.I	0	0	0	0	Bud!	0.000	0.000	0.0	0.0	
Bud.6	11.000	100.130	0.7	0	0	0	0	Bud4	0.000	0.000	0.0	0.0	
Busl?	66.000	101.950	-29.2	0	0	0	0	Bus27	-0.007	4.968	41.6	-0.1	

Project: MASTER THESIS
 Location: HOUN CITY -LWYA
 Company: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND IIUSTAFA AL-REFAI
 File name: HOUN SUBSTATION 220kV
 ETAP 12.6.0H
 Study Case: !!A
 Page: 16
 Date: 28-06-2016
 SN:
 Revision: Best
 Config: NolInal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LOCAL POWER GRID

Bus	Voltage	Generation	Load	Load Flow				Xfmr
				ID	% Top			
				Bus11	0.004	-1.86	21.3	.0.1
				Bus23	0.003	-1.481	11.3	.0.1
				Bud9	0.000	0.000	0.0	0.0
Bus15	66.000 100.139	-10.7	0 0 0	Bud1	0.000	0.000	0.0	0.0
				Bud-O	0.000	0.000	0.0	0.0
Bus19	11.000 101.950	-59.1	0 0 0	Bus17	0.000	0.000	0.0	0.0
Bus10	11.000 100.139	0.7	0 0 0	Bus18	0.000	0.000	0.0	0.0
Bus21	66.000 1020.6	-29.3	0 0 0	Bus17	0.001	1.111	18.6	-0.1
				Bus13	0.001	1.111	18.6	-0.1
				Bu-12	0.000	0.000	0.0	0.0
Bus12	11.000 101.326	-59.3	0 0 0	Bus11	0.000	0.000	0.0	0.0
Bm23	66.000 103.500	-29.4	0 0 0	Bus17	0.000	0.001	0.1	-16.2
				Bus11	0.000	0.001	0.0	-16.2
				Bu\$S	0.000	0.000	0.0	0.0
Bus25	11.000 103.500	-59.4	0 0 0	Bus23	0.000	0.000	0.0	0.0
Bu27	ff.000 1C1.363	-29.4	0 0 0	Bud7	0.011	-1.117	-4.6	-0.2
				Bu-11	-0.011	5.167	11.6	-0.2
				Bus15	0.000	0.000	0.0	0.0
				Bu-19	0.000	0.000	0.0	0.0
Bus28	11.000 101.363	-59.4	0 0 0	Bus17	0.000	0.000	0.0	0.0
Bud9	11.000 101.363	-59.2	0 0 0	Bus17	0.000	0.000	0.0	0.0
Bw30	66.000 1C1.E1S	-29.1	0 0 0	Bud	0.000	0.000	0.0	0.0
				Bus1Z	0.000	0.000	0.0	0.0
Bu31	ff.000 100.m	10.1	0 0 0	Bus1	0.000	0.000	0.0	0.0
				Bin.13	0.000	0.000	0.0	0.0
Bum	11.000 1OLOH	-5-1	0 0 0	Bud 0	0.000	0.000	11.0	0.0
Bu33	11.000 100.m	0..	0 0 0	Bus31	0.000	0.001	0.0	0.0
Bu34	0.400 101.655	-24.0	1.98Z	0.000	0	0	Bus.ti	1.952 0.000 2776.4 100.0
BUS\$5	0.100 1O1.SSS	1.1.0	1.98Z	0.000	0	0	BuII	1.932 0.000 1770.4 100.0
Bm36	0.100 101.685	2.1.0	1.951	0.000	0	0	Bus-II	1.952 0.000 1770.4 100.0
Bud7	0.100 1O1.SSS	1.1.0	1.951	0.000	0	0	Buwl	1.952 0.000 177M 100.0
Bus38	0.400 100.161	-8Z	1.952	0.000	0	0	BuJ2	1.952 0.000 2m.J 100.0
Bu39	M00 100.761	35.1	1.952	0.000	0	0	Bw41	1.951 0.000 2795.7 100.0
Bu40	0.400 100.762	35.2	1.952	0.000	0	0	BuWl	1.951 0.000 2795.7 100.0
Bm.U	11.000 101.10.1	-56.1	0 0 0	Bus11	1.156	0.303	403.0	-99.9
				Bu-f	-1.939	0.076	100.7	-99.9
				Bus35	-1.939	0.076	100.7	-99.9
				Bus36	-1.939	0.076	100.7	-99.9
				Bm31	-1.939	0.076	100.7	-99.9

Project: ETAP
 Location: HOUN CM LIBYA
 Contract: ETAP
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Study-Case: HA
 Page: 17
 Date: 28-06-2016
 Version: Bas.
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus	Generation			Load			Load Flow			XFMR	
	ID	kV	MVA				ID	MW			
BusJ1		11.000	100.178	2.9	0	0	0	Bnd1	5.817	-0.231	308.0 -99.9
								Bu--S	1.939	0.077	101.7 -99.9
								Bus39	-1.939	0.077	10L7 -9M
								Bu,Lfil	-1.939	0.077	101.7 -99.9

• Indik als a voltage regulated bus (voltage controlled or using type- in add due control if it is)
 #indikat's a bus with a load minmax of more than 0.1 MVA

Project: JIASTER THESIS
 Location: HOUN CITV-LIBYA
 Contract: NEAR EAST UNIYERSITY, EEE Department
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 StudyCase: HA

Page: 18
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA's POWER GRID

Solar Harmonics Bus Information

Bns	ID	IV	Voltage Distortion							
			Fond. %	RMS %	ASU/I %	THD %	M %	THD %	TSHD %	THDG %
Bus1		66.000	100.01	JOLO?	105.13	1.31	53.04	0.00	0.00	1.12
Bu-I		66.000	100.11	100.II	101.91	1.14	20.5-1	0.00	0.00	1.14
Bus3		220.000	100.00	100.03	103.91	2.2S	51.33	0.00	0.00	2.15
Bus5		11.000	100.00	JOO.OI	101.72	1.09	19.70	0.00	0.00	1.09
Bus6		11.000	101.04	101.01	105.13	2.32	\$3.04	0.00	0.00	1.32
Bus7		66.000	101.11	100.IZ	101.91	1.14	20.-8	0.00	0.00	1.14
Bus8		66.000	101.04	101.07	105.14	2.2-	\$3.21	0.00	0.00	2.35
Bus9		11.000	100.11	100.II	101.91	1.14	20.58	0.00	0.00	1.14
Bus0		11.000	101.04	101.01	105.14	1.31	53.11	0.00	0.00	Z.32
Bus!		66.000	100.11	100.11	101.91	1.14	20.54	0.00	0.00	1.14
Bus%		6MOO	101.04	101.07	105.13	1.32	53.05	0.00	0.00	2.32
Bu.1		66.000	101.06	101.09	105.40	1.40	51.88	0.00	0.00	Z.10
Bud4		66.000	100.13	100.14	101.01	1.17	N.S1	0.00	0.00	1.17
Bu.15		11.000	101.06	101.09	105.40	Z.40	57.58	0.00	0.00	1.40
Bu16		11.000	100.13	100.U	101.01	1.17	21.51	0.00	0.00	1.17
Bus17		66.000	101.95	101.97	105.01	1.19	36.15	0.00	0.00	1.89
Bud8		66.000	100.14	100.15	102.06	1.19	21.99	0.00	0.00	U.9
Bus9		11.000	101.95	101.97	105.01	1.19	36.15	0.00	0.00	1.89
BU\$10		11.000	100.14	100.18	102.06	1.19	ZI.99	0.00	0.00	1.19
Bus11		66.000	102.33	101.34	105.s.1	1.19	51.33	0.00	0.00	1.19
Bus12		11.000	101.33	101.34	105.84	1.79	51.33	0.00	0.00	1.79
Bus13		66.000	103.50	103.55	107.72	2.96	47.16	0.00	0.00	1.96
Bus-25		11.000	103.50	103.55	107.71	Z.96	47.16	0.00	0.00	2.96
Bm17		66.000	101.36	101.39	105.02	Z.18	43.49	0.00	0.00	1.15
Bus18		11.000	101.36	101J9	105.01	2.15	43.49	0.00	0.00	1.15
Bm19		11.000	101.36	101.39	105.01	1.15	43.49	0.00	0.00	2.15
Bus30		66.000	101.04	101.07	105.17	2.33	S3.75	0.00	0.00	2.33
Bus31		66.000	100.II	100.II	101.91	1.15	20.70	0.00	0.00	1.15
Bus31		11.000	101.04	IOLO?	101.17	2.33	53.73	0.00	0.00	2.33
Bus33		11.000	100.u	100.11	101.92	1.15	10.70	0.00	0.00	1.15
Bus34		0.400	101.65	101.91	112.50	6.13	213.30	0.00	0.00	6.73
Bus35		MOO	101.68	101.75	109.U	3.69	130.71	0.00	0.00	3.69
Bus36		0.400	101.68	101.91	117.50	6.73	273.JO	0.00	0.00	6.73
Bus37		D.400	101.68	101.91	117SO	6.73	273.30	0.00	0.00	6.73
Bus38		0.400	100.16	100.76	102.19	ESS	ZS.34	0.00	0.00	0.58
Bnh9		0.400	100.76	100.83	110.01	3.61	181.76	0.00	0.00	3.61
Bus40		0.400	100.76	100.16	102.19	USS	18.34	0.00	0.00	0.58
Bn41		11.000	101.10	101.18	109.18	3.9?	U0.38	0.00	0.00	3.97
Bus42		11.000	100.11	100.18	101.70	0.6?	30.46	0.00	0.00	MJ

* Indicates THD (Total Harmonic Distortion) Exceeds the Limit.

Indicates IID (Individual Harmonic Distortion) Exceeds the limit.

Project: HL-1.SERTHESIS
 Location: HOUN,CITY -LIBYA
 Om tract: NEAR EAST UNIVERSITY - EEE Deparment
 Engineer: SMII IWSTAFIA AL-REFAI
 Filenamer: HOUN SUBSTATION220kV

ETAP
 12.MH
 StudyCase: HA

Page: 19
 Date: 28-06-2016
 Sfu:
 R-siou: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND INPUT ANALYSIS OF ITS INTEGRATION INTO THE KI POWER GRID

System ijar.egnics Branch Ipfonnfifgu

Bus	FromBu1ID	ToBu1ID	Current Distribution											
			Fwad. Amp	RMS Amp	ASUM	TIID %	TIF	IT Amp	ITB Amp	ITu Amp	TIID %	TSID %	TIIDG %	THDS %
Bud	Btd2		67.11	67.18	71.91	M6	98.65	661H6	661U6	0.00	0.00	0.00	3.66	M6
	Bic3		1.51	Z.63	4.13	31.18	1067.19	1808.61	2808.61	0.00	0.00	0.00	31.18	31.18
Bu-27		48.64	45.71	51.39	6.51	115.97	51871.87	9871.82	0.00	0.00	0.00	0.00	6.57	6.51
B~\$	O:il		0.54	0.84	30.34	1005.48	-5-17.05	5-11.08	0.00	0.00	0.00	0.00	30.34	30.34
Bus	0.82	0.51	0.84	30.34	1005.48	547.08	547.08	0.00	0.00	0.00	0.00	30.34	30.34	
B~O	1.04	1.09	Ü9	30.44	10111	1107.09	J101.09	0.00	0.00	0.00	0.00	30A4	3M4	
Bud	80.43	8-0.43	81.00	0.46	8.15	655.68	655.68	0.00	0.00	0.00	0.00	0.46	0.46	
Bu.6	0	0	0	0	0	0.00	655.68	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bu.12	Bud1		50.79	50.79	51.38	1.64	41.16	1090.84	1090.84	0.00	0.00	0.00	1.64	1.64
	Bus4		1.18	1.31	1.86	13.81	316.86	730.SI	730.51	0.00	OM.	0.00	13.81	13.81
BudS		1.97	3.00	3.73	13.91	313.86	970.03	970.03	0.00	0.00	0.00	0.00	13.91	13.91
Bits7	0.81	0.82	M4	13.58	304.59	155.87	158.57	0.00	0.00	0.00	0.00	13.SS	13.SS	
Bu11	0.82	0.82	0.64	13.58	304.59	158.57	158.51	0.00	0.00	0.00	0.00	0.00	0.00	
~!	1.0.	1.04	1.19	13.61	306.03	318.66	318.66	0.00	0.00	0.00	0.00	IMI	13.61	
e-1:		50.83	50.83	-1.09	O-ti	5.95	302.37	301.37	0.00	0.00	0.00	0.00	0.36	0.36
Bu\$.l	Bic1	2U3	24.0	14.10	0.46	a1s	196.70	196.70	0.00	0.00	0.00	0.00	0.46	0.46
Bu.S	Bus?	1S.18	15.25	15.33	0.36	5.95	90.71	90.71	0.00	0.00	0.00	0.00	0.36	0.36
Busti	Bud	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
But7	But1	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
	B.Z	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
Bu.9	0	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
Bu.S	Bus1	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
	Bu.!	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
	Bns10	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
Bu.1>	Bu.7	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
Bu.0	B~\$	0	0	0	0	0	0.00	90.71	0.00	0.00	0.00	0.00	0.00	0.00
Bu.11	B.Z	50.81	50.84	S1SS	1.80	44.89	Z181.37	1282.37	0.00	0.00	0.00	0.00	1.80	1.80
	B@Z	50.83	50.84	52.SS	1.80	44.89	2282.37	1181.37	0.00	0.00	0.00	0.00	1.80	1.80
Bud?	Bic1		67.16	67.10	71.81	3.57	93.57	6288.25	6188.15	0.00	0.00	0.00	3.57	3.57
	Bus11		67.16	67.10	71.81	3.57	93.51	6288.15	6288.25	0.00	0.00	0.00	3.57	3.57
Bus13		0	0	0	0	0	0.00	6288.15	0.00	0.00	0.00	0.00	0.00	0.00
	Bu.65	0	0	0	0	0	0.00	6288.25	0.00	0.00	0.00	0.00	0.00	0.00
Bus14	Bus?	0	0	0	0	0	0.00	6288.15	0.00	0.00	0.00	0.00	0.00	0.00
	Bud6	0	0	0	0	0	0.00	6283.75	0.00	0.00	0.00	0.00	0.00	0.00
Bus15	Bic3	0	0	0	0	0	0.00	6288.25	0.00	0.00	0.00	0.00	0.00	0.00
Bu.16	Bu.U	0	0	0	0	0	0.00	6288.15	0.00	0.00	0.00	0.00	0.00	0.00
BUJ17	B1.27	4Z.68	J.77	48.61	8.07	ZSS.0J	11036.00	11036.00	0.00	0.00	0.00	0.00	8.07	S.07
Bu.11		11.33	21.45	25.19	1M6	448.69	9625.84	9615.-	0.00	0.00	0.00	0.00	10.66	10.66
Bu.13		%1.30	21.H	23.80	6.56	181.11	3865.78	3865.78	0.00	0.00	0.00	0.00	6.56	6.56
Bu.17		0	0	0	0	0	0.00	3865.78	0.00	0.00	0.00	0.00	0.00	0.00

Project: HIL-1-STER THESIS
 Location: HOUN CITY-LIBYA
 Contract: UNIVERSITY EAST-ELECTRICAL DEPARTMENT
 Engineer: SAND HIDSTAFAL AL-RUAH
 filename: HOUN SHIESTATION 220KV

ETAP

12.6.0H

Page: 20
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION IN LIBYAN POWER GRID

Bus	FromBwID	ToBwID	Fund	RMS	ASy!	Pan	Current Distortion		ITR	ITB	ITR	MRO	TSHD	THDG	THDS
							TIF	Affil							
Bus8	Bus1	0	0	0	0	0	0.00	3865.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Bu-O	0	0	0	0	0	0.00	3865.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus9	Bus7	0	0	0	0	0	0.00	3865.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus10	BndS	0	0	0	0	0	0.00	3865.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bual	Bud7	18.57	18.72	B.OB	11.90	445.83	8347.30	8347.30	0.00	0.00	0.00	0.00	12.90	nse	1:su
	Bu:3	18.57	18.72	23.08	11.90	445.83	8331.30	8147.30	0.00	0.00	0.00	0.00	11.90	1:su	0.00
	Bus1?	0	0	0	0	0	0.00	8347.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus22	Bus21	0	0	0	0	0	0.00	5317.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus23	Bus7	0.01	0.39	0.15	-4650.20	Z613.05	1019.93	1019.93	0.00	0.00	0.00	0.00	-550.10	4550.10	
	Bus21	M1	0.39	0.75	4850.10	1613.08	1019.93	1019.93	0.00	0.00	0.00	0.00	4850.20	4850.20	
	11-15	0	0	0	0	0	0.00	1019.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus25	Bum	0	0	0	0	0	0.00	1019.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus27	Bus17	U.59	44.71	50.56	7.15	-37.32	10610.18	10610.28	0.00	0.00	0.00	0.00	1.15	1.15	
	Bus1	44.59	44.71	S0.56	7.15	-237.11	10610.28	10610.18	0.00	0.00	0.00	0.00	7.15	7-15	
	Bus15	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus28	Bw27	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus29	Bu.27	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bm30	Bus1	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Bus31	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bm31	Bus1	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Bu.33	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bus32	Bus.0	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bm33	Bm32	0	0	0	0	0	0.00	10610.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bm34	Bus41	2770.37	2771.68	3033.78	4.89	m.69	354180.40	541s0.40	0.00	0.00	0.00	0.00	-4.89	4.89	
Bus35	Bus1	1770.37	2770.40	179.24S	0.s0	10.76	29801.97	29801.97	0.00	0.00	0.00	0.00	8.8E	8.8E	
Bm36	Bw1	2770.37	2773.68	3033.78	4.89	127.69	354180.40	354180.40	0.00	0.00	0.00	0.00	4.89	4.89	
11.11	Bu-II	1770.37	2773.68	3033.76	1.89	m.69	.54130.40	.541s0.40	0.00	0.00	0.00	0.00	4.89	4.89	
Bus38	Bus.fl	2195.12	Z79.ii.7	1799.17	0.83	1.98	5530.49	5530.49	0.00	0.00	0.00	0.00	0.0	0.07	0.07
Bus39	BUS.1	ZWS.71	2799.70	3082.91	5.34	136.04	380861.30	380861.30	0.00	0.00	0.00	0.00	8.34	8.34	
Bus40	Bu-S.2	2795.71	2795.72	1792.27	0.02	1.98	5530.49	5530.49	0.00	0.00	0.00	0.00	0.07	0.07	
Bus41	Bud.2	402.96	403.22	450.94	18.7	93.57	3769.53	37719.53	0.00	0.00	0.00	0.00	3.57	3.57	
	Bm34	100.74	100.86	110.32	4.89	177.69	1879.19	1879.19	0.00	0.00	0.00	0.00	4.89	4.89	
	Bu.35	100.74	100.74	101.53	0.s0	10.76	1083.71	1083.71	0.00	0.00	0.00	0.00	8.8E	8.8E	
	Bu.36	100.74	100.86	110.32	4.89	m.69	1879.20	12879.20	0M	0.00	0.00	0.00	4.89	4.89	
	Bu.37	100.74	100.86	110.31	4.89	m.69	1879.29	1879.29	0.00	0.00	0.00	0.00	4.89	4.89	
BusU	Bus1	304.99	305.04	318.16	1.80	44.89	13694.11	13694.11	0.00	0.00	0.00	0.00	1.80	1.80	
	Bu.38	101.66	101.66	101.79	0.02	1.98	201.11	ZE1.11	0.00	0.00	0.00	0.00	0.07	0.67	
	Bu.39	101.66	101.81	111.11	5.34	136.04	13849.10	13849.50	0.00	0.00	0.00	0.00	5.34	5.4	
	Bu.40	101.66	101.66	101.79	0.07	1.98	SE1.11	1E1.11	0.00	0.00	0.00	0.00	0.0	0.01	

Project: MASTER THESIS
 Location: HOUN CITY-LIBYA
 Centrcu: NEAR EAST LITIVERSITY - EEE Department
 Engineer: S.-D MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP

12.6.0H

Pag.: 21
 Date: 28-06-2016
 SN:
 Rrlifon: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND PACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Jahulation

Harmonic Voltages(% of Fundamental Voltage)

Bus ID:		Bus1		Bus2		Bus3		Bus4		Bus5		Bus6		
Fund. KV:	66.656	Order	Freq.	Mng.	Order	Frtq.	%lag.	Order	Frtq.	I-g.	Order	Freq.	Ibg.	
		Hz	Hz	%		Hz	%		Hz	%		Hz	%	
11.00	SSAEE	1.89	13.00	6.000	1.1s	2.00	11.00	o.J	is.00	mo.00	JS.00	mo.00	ASS	
47.00	usoo.00	0.01	49.00	2450.00	0.01									
Bus ID:		Bus0		Bus11		Bus12		Bus13		Bus14		Bus15		
Fund. KV:	11.114	Order	Freq.	Mng.	Order	Frtq.	%lag.	Order	Freq.	Mng.	Order	Frtq.	%lag.	
		Hz	Hz	%		Hz	%		Hz	%		Hz	%	
11.00	550.00	1.59	13.00	650.00	1.18	23.00	1150.00	0.33	15.00	1250.00	0.S.	35.00	1100.00	
47.00	2350.00	0.01	49.00	2450.00	0.01									
Bus ID:		Bus11		Bus12		Bus13		Bus14		Bus15		Bus16		
Fund. KV:	66.072	Order	Freq.	Mng.	Order	Frtq.	Mng.	Order	Frtq.	Mng.	Order	Frtq.	Mng.	
		Hz	Hz	%		Hz	%		Hz	%		Hz	%	
11.00	550.00	0.96	13.00	650.10	0.59	21.00	1150.00	0.12	25.00	1150.00	0.09	35.00	1750.00	
47.00	1150.00	0.00	49.00	2450.00	0.00									
Bus ID:		Bus12		Bus13		Bus14		Bus15		Bus16		Bus17		
Fund. KV:	66.681	Order	Freq.	Mng.	Order	Frtq.	Mng.	Order	Frtq.	I-g.	Order	Frtq.	I-g.	
		Hz	Hz	%		Hz	%		Hz	%		Hz	%	
11.00	550.00	1.89	13.00	650.00	1.18	23.00	1150.00	0.33	25.00	1150.00	0.55	35.00	1150.00	
47.00	2350.00	0.03	49.00	2450.00	0.01									
Bus ID:		Bus13		Bus14		Bus15		Bus16		Bus17		Bus18		
Fund. KV:	66.700	Order	Freq.	Mng.	Order	Frtq.	Mng.	Order	Frtq.	I-g.	Order	Frtq.	I-g.	
		Hz	Hz	%		Hz	%		Hz	%		Hz	%	
11.00	550.00	1.94	13.00	650.00	1.11	23.00	1150.00	0.37	25.00	1250.00	0.62	35.00	1750.00	
47.00	2350.00	0.05	49.00	2450.00	0.04									
Bus ID:		Bus14		Bus15		Bus16		Bus17		Bus18		Bus19		
Fund. KV:	66.056	Order	Frtq.	Mng.	Order	Frtq.	Mng.	Order	Frtq.	I-g.	Order	Frtq.	I-g.	
		Hz	Hz	%		Hz	Hz		Hz	%		Hz	%	
11.00	550.00	0.99	13.00	650.00	1.22	23.00	1150.00	0.13	25.00	1250.00	0.10	35.00	1750.00	
47.00	2350.00	0.00	49.00	2450.00	0.00									
Bus ID:		B-15		Bus1		Bus2		Bus3		Bus4		Bus5		
Fund. KV:	11.117	Order	Frtq.	Mng.	Order	Freq.	Mng.	Order	Frtq.	I-g.	Order	Frtq.	I-g.	
		Hz	Hz	%		Hz	%		Hz	%		Hz	%	
11.00	550.00	1.94	13.00	650.00	1.22	23.00	1150.00	0.37	25.00	150.00	0.62	35.00	1750.00	
47.00	2350.00	0.05	49.00	2450.00	0.04									
Bus ID:		Bus5		Bus6		Bus7		Bus8		Bus9		Bus10		
Fund. KV:	11.011	Order	Frtq.	Mng.	Order	Freq.	Mng.	Order	Frtq.	I-g.	Order	Frtq.	I-g.	
		Hz	Hz	%		Hz	%		Hz	%		Hz	%	
11.00	550.00	0.99	13.00	650.00	0.61	23.00	1150.00	0.09	150.00	150.00	0.10	35.00	1750.00	

Project: JLSIER THESIS

ETAP

Page: 22

Location: HOUN CTTY-LIBYA

12.6.0H

Date: 21H16-2016

Contract: LEAR EAST UNTIERTSITY - EEE Deparment;

SN:

Engineer: SAND-MUSTAFA AL-REFAI

Relision: Base

Filename: HOUN SUBSTATION 220kV

Study Case: HA

Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND THYRISTOR ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Tabulation**Harmonic Voltages (0% of Fundamental Voltage)**

BusID: Bns16 Fund.kV: 67,287	Order	Freq.	Mag.	Ordr	Frtq.	Mng.	Or-dtr	Frtq.	Mag.	Order	Freq.	Mag.	Ordr	Frtq.	Mag.	Order	Freq.	Mag.	
	0	0	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	~	
47.00	2350.00	0.00		4MO	2450.00	0.00													
	11.00	550.00	1.3	13.00	650.00	1.33	23.00	1150.00	0.11	25.00	1250.00	0.08	35.00	1750.00	0.08	37.00	1850.00	0.08	
	17.00	mo.oo	0.01	49.00	1450.00	0.01													
	BusID: BusS Fund.kV: 66,091	Order	freq.	M.g.	Order	Freq. Hz	Infag. %	Or&r	Freq. Hz	Mag. %	Order	Freq. 1h	Mag. %	Order	Freq. Hz	Afag. %	Order	Freq. Hz	Mag. %
		11.00	550.00	1.00	13.00	650.00	1.33	23.00	1150.00	0.11	25.00	1250.00	0.08	35.00	1750.00	0.08	37.00	1850.00	0.08
		17.00	2350.00	0.01	49.00	2450.00	0.01												
	BusID: Bud15 Fund.kV: 1L115	Order	Freq.	Mag.	Ordr	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Freq.	Ang. %	Order	Freq. Hz	Ang. %	Order	Freq. Hz	Mag.
		11.00	550.00	1.33	11.00	650.00	1.33	23.00	1150.00	0.11	25.00	1250.00	0.08	35.00	1750.00	0.08	37.00	1850.00	0.08
		47.00	1350.00	0.01	49.00	1450.00	0.01												
	Bu-ID: Bw2 Fund.kV: 66,07	Order	Frtq.	(fag.)	Ord,r	Freq.	-Lig.	Ordtr	Frtq.	Mag.	Order	Freq. Hz	Ang. %	Order	Freq.	Ang. %	Order	Freq.	Mag.
		11.00	550.00	0.96	13.00	650.00	0.59	23.00	1150.00	0.11	25.00	1250.00	0.08	35.00	1750.00	0.08	37.00	1850.00	0.01
		47.00	2350.00	0.00	49.00	2450.00	0.00												
	BusID: Bus20 Fund.kV: 11,015	Or-dtr	Freq.	Mag.	Ordr	Freq.	Mag.	Or-dtr	Freq.	Mag.	Ordr	Freq.	Mag.	Ordr	Freq.	Mag.	Ordu	Freq. Hz	Mag.
		11.00	550.00	1.00	13.00	650.00	0.01	13.00	1150.00	0.11	15.00	1250.00	0.10	35.00	1750.00	0.03	37.00	1850.00	0.01
		47.00	2350.00	0.01	49.00	1450.00	0.01												
	Bus ID: Bw21 Fund. kV: 6LS36	Or-dtr	Freq.	Mag.	Ordr	Freq.	Mag.	Or-dtr	Freq.	Mag.	Ordr	Freq.	Mag.	Ordr	Freq.	Mag.	Ordu	Freq. Hz	Mag.
		11.00	550.00	0.99	13.00	650.00	0.11	23.00	1150.00	0.11	15.00	1250.00	0.08	35.00	1750.00	0.08	11.00	1850.00	0.01
		47.00	2350.00	0.01	49.00	2450.00	0.00												
	Bus ID: BwZ1 Fund. kV: 1L2S6	Or-dtr	Freq.	Mag.	Ordr	Freq.	Mag.	Or-dtr	Freq.	Mag.	Ordr	Freq.	Mag.	Ordr	Freq.	Mag.	Ordu	Freq. Hz	Mag.
		11.00	550.00	0.99	13.00	650.00	1.12	11.00	1150.00	0.11	13.00	1250.00	0.08	35.00	1150.00	M>9	11.00	mo.oo	0.01
		47.00	2350.00	0.01	49.00	1450.00	0.00												

Project: MASTER THESIS: ETAP
 Location: HOUN CITY - LIBYA 12.6.0H
 Contract: YEAR EASI UNIVERSIT- EEE Deparment
 Engineer: SAND MUSTAFA AL-REFAI Study Case: HA
 file name: HOUN SUBSIDIATION 220kV Rertrslcu Base
 Config: Normal

DE-SIGN OF A LAR,(ESCAPE) SOL/RPVSYSYTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA!! POWER GRID

Bus Tabulation

Harmo Volnges (% offundamental Volnges)

Bus ID:	Bus3	Fund. KV:	68.310	Order	Freq. Hz	Ilng. %	Order	Fnq.	Mag. fil	0.0dr	Freq. Hz	Mrg. %	Ordr	Frtq. Hz	Mag. %	Ordr	Fnq. Hz	Mag. %	Order	Freq. Hz	Mag. %
				11.00	550.00	2.~	13.00	~00	1.33	ZMO	mo.oo	0.15	25.00	110.00	0.05	35.00	1750.00	0.00	noo	issae	0.00
				,1.00	2350.00	0.00	,9.00	2450.00	0.00												
Bus ID:	Bus5	Fund. KV:	113.5	Order	Freq. Hz	Ilng. %	Order	Fnq.	Mag. fil	0.0dr	Freq. Hz	Mrg. %	Ordr	Frtq. Hz	Mag. %	Ordr	Fnq. Hz	Mag. %	Order	Freq. Hz	Mag. %
				11.00	110.00	1.65	11.00	~00	13;	13.00	110.00	0.00	1250.00	0.00	35.00	1110.00	0.00	J7.00	110.00	0.00	
				,1.00	2350.00	0.00	49.00	US0.00	0.00												
Bus ID:	Bm17	Fund. KV:	66.900	Order	Freq. Hz	Ilng. %	Order	Frtq. Hz	Mag. fil	0.0dr	Freq. Hz	Mrg. %	Ordr	Fnq. Hz	Mag. %	Ordr	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
				U.00	550.00	1.71	13.00	~00	1.35	23.00	1150.00	0.18	25.00	mo.oo	0.05	35.00	170.00	0.06	37.00	1850.00	0.03
				,1.00	2350.00	0.0!	49.00	110.00	0.01												
Bus ID:	Bm25	Fund. KV:	11.150	Order	Fmi. Hz	Ab. %	Order	Frtq. Hz	Mag. %	Order	Frtq. Hz	Mrg. %	Order	Freq. Hz	Mag. %	Ordr	Frrq. Hz	Mag. %	Ordr	Frtq. fil	Mag. %
				11.00	110.00	1.71	13.00	~00	1.18	uo0	110.00	0.18	1250.00	0.05	3.00	170.00	0.06	37.00	1850.00	0.03	
				,1.00	1350.00	0.0!	,15.00	2450.00	0.01												
Bus ID:	But19	Fund. KV:	11.150	Order	Frtq. Hz	Ilng. %	Order	Fnq. Hz	Mag. %	Order	Frtq. Hz	Mrg. %	Ordr	Frrq. Hz	Mag. %	Ordr	Frtq. Hz	Mag. %	Order	Frtq. Hz	Mag. %
				11.00	110.00	1.11	u.00	110.00	1.18	uo0	mo.oo	0.18	2.00	mo.oo	0.05	35.00	110.00	0.06	J1.00	110.00	0.03
				,1.00	1350.00	0.02	,1.00	110.00	0.01												
Bus ID:	Buu	Fund. KV:	110.000	Order	Frtq. Hz	Ma. %	Order	Frtq. Hz	Mag. %	Onier	Fnq. Hz	Mag. %	Order	Freq. Hz	Ilng. %	Ordr	Frtq. Hz	Ilng. %	Onlu	Frtq. Hz	Mag. %
				<1.00	2350.00	0.0	J.00	2450.00	0.0												
Bus ID:	Bm30	Fund. KV:	66.688	Ordr	Frtq. fil	Mag. %	Ordr	Frtq. Hz	Mng. %	Ordr	Frtq. Hz	Mng. %	Ordr	Frtq. fil	Mng. %	Ordr	Frtq. Hz	Mng. %	Order	Freq. Hz	Mag. %
				11.00	110.00	1.88	13.00	6.00	1.19	z.,00	mo.oo	0.11	18.00	110.00	0.56	J8.00	110.00	0.08	37.00	110.00	0.00
				,1.00	2350.00	0.0!	,0.00	2450.00	0.01												
Bus ID:	Bm11	Fund. KV:	66.011	Ordr	Frtq. fil	Mag. %	Ordr	Frtq. Hz	Mng. %	Ordr	Frtq. Hz	Mng. %	Ordr	Frtq. fil	Mng. %	Ordr	Frtq. Hz	Mng. %	Order	Freq. Hz	Mag. %
				11.00	550.00	0.97	13.00	~00	Q.60	23.00	1150.00	0.11	25.00	mo.oo	0.09	35.00	1750.00	0.07	37.00	1850.00	0.01

Project: MASTER THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engineer: SAND rosTAF A AL-REF AI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.MH
 p.ge: 24
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nogla

DESIGN OF A LARGE SCUZ SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA POWER GRID

Bus Tabulation

Hatmonk Voltages (% of Fundamental Voltage)


Bus-ID:	Bus-V	Fund.kV:																	
Bu-ID:	B-Z	66.0U																	
Fund.kV:	11,115																		
47.00	1150.00	0.00																	
47.00	4MO	U50.00																	
47.00	0.00	0.00																	
11.00	550.00	1.00																	
47.00	mo.00	0.01																	
47.00	49.00	2450.00																	
Bu-ID:	Bw.I3	11.0U.																	
Fund.kV:																			
Ordtl'	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Fnq.	Alag.	Ord-tr	Freq.	-Lig.	Or-dtr	Fr.q.	Udg.	Or-dtr	Fr.q.	Afag.	
11.00	550.00	0.97	13.00	650.00	0.60	Z3.00	1150.00	0.11	25.00	1250.00	0.09	35.00	17.00	0.01	37.00	18.00	0.01		
47.00	2350.00	0.00	49.00	24.00	0.00														
Bu-ID:	Bw.II																		
Fund.kV:	0.407																		
11.00	550.00	4.13	L.00	650.00	1.20	23.00	1150.00	Z.n	25.00	1250.00	2.67	31.00	1750.00	III	37.00	1850.00	1.00		
47.00	2350.00	0.46	49.00	U50.00	USE														
Bu-ID:	Bus3S																		
Fund.kV:	0.407																		
Ordu	Freq.	AI-g.	Ordtl	Freq.	Mag.	%	Order	fnq.	Abg.	Ord-tr	Freq.	it.Lig.	Ordtl	Freq.	Mag.	Ordu	Freq.	Mag.	
11.00	550.00	.05	13.00	6.00	0.50	23.00	1150.00	1.32	25.00	1250.00	1.39	35.00	1750.00	MS	37.00	1850.00	0.39		
47.00	1350.00	0.16	4MO	2450.00	0.17														
Bu-ID:	Bun																		
Fund.kV:	0.407																		
Ordu	Fr.q.	Mag.	Ordtl	Fr.q.	Mng.	0'dtr	Frtq.	Uag.	0'dtr	Freq.	1h	it.fag.	Order	freq.	Ma.	Ordu	Frq.	Mag.	
11.00	550.00	4.79	13.00	650.00	1.20	13.00	1150.00	Z.n	18.00	1250.00	2.67	35.00	1750.00	1.21	37.00	1850.00	1.00		
47.00	2350.00	0.46	49.00	2450.00	0.50														
Bu-ID:	Bw.I7																		
Fund.kV:	6.407																		
11.00	550.00	4.79	13.00	650.00	2.20	23.00	1150.00	1.72	25.00	1150.00	2.67	35.00	1750.00	1.11	37.00	1850.00	J.00		
47.00	2350.00	0.46	49.00	2450.00	0.50														
Bu-ID:	Bw.I8																		
Fund.kV:	0.403																		
11.00	550.00	0.37	13.00	650.00	e.u	23.00	115MO	0.17	25.00	1250.00	0.26	35.00	17.00	e.us	37.00	1850.00	O.il		
47.00	2350.00	0.06	49.00	2450.00	0.06														

Project: -LISIER THESIS
 Location: HOUN C11Y-LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Enginier: SAI'D MUHAFAT AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP.
 12.6.QH

Page: 18
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

D-IGN OF A LARGE SCALE SOLAR PV SYSTEM INTEGRATION INTO UBTAN POWER GRID



Projeci. AUSTER THESIS
Location: HOUN' CITY- LIBYA
Contracn MEAR EAST U\N'TRSITY -EEE Deparment
Engin ter: SAND)WSTAFAL AL-REFAI
Fllename: HOUN' suasRATIOn 220kV

ETAP

12.MH

Page: 26

Date: 2016-06-27

SN

SNT

Config: Nonappl

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND THIPAC: f ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus.Tahu lafionu

Halononk Voltages (% off fundamental Voltage)

Project: MASTER THESIS
 Location: HOUN CITY LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engine-!: SAAD MUSTAFA AL-REF AI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Page: 27
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGESCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS ON ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Impedance

Harmonic Voltages (% of nominal voltage)

BusID: Bus1 Nom. kV: 66.000		Harmonic Voltages (% of nominal voltage)															
Order	Freq. Hz	Mag. %	Ordtr	Frtq. Hz	Ifag. %	Ordu	Fttq.	Afag. %	Order	Frq. Hz	Ifag. %	Ordr	Frtq. Hz	Mag. %	Ordtr	Frtq. Hz	Mag. %
11.00	~0.00	1.91	13.00	650.00	1.19	23.00	1150.00	0.33	18.00	1150.00	0.33	35.00	1750.00	0.05	37.00	1850.00	0.00
47.00	1350.00	0.03	49.00	150.00	0.02												
Bus ID: Bus 0 Nom.kV: 11.000																	
Order	Freq. Hz	Mag. %	Ordtr	Frtq. Hz	Ibg. %Hi	Ordtl	Freq.	Mag. %	Order	tnq. Hz	Mng. %	Ordtr	fnq. Hz	Min.	Onltr	Prq.	M.g.
11.00	550.00	1.91	13.00	650.00	1.19	13.00	1150.00	0.33	18.00	1250.00	0.33	35.00	1750.00	0.05	37.00	1850.00	0.00
47.00	2350.00	0.01	49.00	2450.00	0.01												
Bus ID: Bus1 Nom. kV: 66.000																	
Order	Freq. Hz	Mag. %	Ordtr	Frtq. Hz	Mag. %	Ordtl	Freq. Hz	Mng. %	Order	freq.	Mug.	Ordtr	Fnq.	Aüg.	Ordtr	f-q.	Mai.
11.00	ssae	0.96	13.00	650.00	0.59	11.00	1150.00	0.59	2s.00	U50.00	0.0?	3s.00	1750.00	0.0:	37.00	issane	0.01
47.00	1350.00	0.01	49.00	2450.00	0.01												
Bu. ID: Bu.12 Nom. kV: 66.000																	
Order	Freq. Hz	Mag. %	Ordtr	Frtq. Hz	Mag. %	Ordtl	Freq. Hz	Mng. %	Order	freq.	Mug.	Ordtr	Fnq.	Aüg.	Ordtr	f-q.	Mai.
11.00	550.00	1.91	13.00	650.00	1.19	13.00	1150.00	0.33	1Mo	ns0.00	ass	JS.D0	1750.00	0.05	37.00	1850.00	0.00
47.00	21.0.00	0.01	49.00	2450.00	0.01												
Bus ID: Bus1! Nom. kV: 66.000																	
Order	Frtq. Hz	Alag. %	Ordtr	Frtq. Hz	Mag. %	Ordtl	Freq. Hz	Afag. %	Order	Frq. Hz	Mag. %	Ordtr	fnq. Hz	Mag. %	Ordtr	Fl'tq. Hz	Alng. %
11.00	ss0.00	1.96	u.oo	650.00	1.11	13.00	1150.00	0.11	is.oo	1150.00	0.61	is.oo	1750.00	0.01	37.00	is50.00	0.00
47.00	2350.00	0.05	49.00	2450.00	0.04												
Bus ID: Bu.14 Nom. kV: 66.000																	
Order	Freq. Hz	Mag. %	Ordtr	Frtq. Hz	Mag. %	Ordtl	Freq. Hz	Mng. %	Order	Fnq. Hz	Mng. %	Ordtr	Fnq. Hz	Mng. %	Ordtr	Fnq. Hz	Abg.
11.00	ss0.00	0.9	u.oo	650.00	MI	11.00	nsaee	0.11	1.5.00	mo.00	0.10	Js.oo	1750.00	0.01	31.00	mo.on	0.0:
41.00	mo.oo	0.01	49.00	150.00	0.00												
Bus ID: Bus15 Nom. kV: 11.000																	
Order	Freq. Hz	Mag. %	Ordtr	Frtq. Hz	Mag. %	Ordtl	Freq. Hz	Ifag. %	Order	Frtq. Hz	Mng. %	Ordtr	Fl-tq. Hz	Mng. %	Ordtr	Fl-tq. Hz	Mng. %
11.00	50.00	1.96	11.00	6.00	1.23	13.00	1150.00	0.37	25.00	1250.00	0.61	35.00	1750.00	0.06	37.00	1850.00	0.00
11.00	mo.oo	0.05	49.00	ns0.00	0.04												

Project: LIU.STER TASSIS ETAP
 Location: HOUN CM LIBYA Date: 28-06-2016
 Contract: ISLAR EAST UNIVERSITY EEE Depar-ent SN:
 Engineer: SA.III ILLUSTAFAL-REFAI Revision: Base
 Filename: HOUN ShIUSTATION 220KV Config: Nerial

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Transient

Harmonic Voltages(% of Nominal Voltage)

Bus ID:	Bus 6	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.			
Nom. KV:	11,000																		
Order	Freq.	~1.g.	Or-der	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.		
11.00	SSo.G0	0.99	11.00	6.00	MI	as.ee	J.F.	0.13	11S0.00	11.00	0.01	35.00	1750.00	0.03	37.00	1850.00	0.03		
41.00	1350.00	0.01	49.00	1450.00	0.01														
Bus ID:	Bus 7	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.			
Nom. KV:	66,000																		
Order	Freq.	MI	Or-der	Freq.	Mog.	Order	Freq.	Ifag.	Order	Freq.	Ifag.	Order	Freq.	Ifag.	Order	Freq.	Mat.		
11.00	SSo.G0	1.16	13.00	680.00	1.33	z.i.o0	J.F.	0.01	1150.00	e.n	25.00	US.00	0.05	31.00	1750.00	0.08	31.00	1850.00	0.08
47.00	1350.00	0.01	49.00	2450.00	0.01														
Bus ID:	Bus 8	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.			
Nom. KV:	66,000																		
Order	Freq.	MI	Mag.	Order	Freq.	~1.g.	Or-der	Freq.	?ifag.	Or-der	Freq.	?ifag.	Or-der	Freq.	Mag.	Or-der	Freq.	?ifag.	
11.00	SSo.G0	1.00	13.00	610.00	0.81	as.ee	J.F.	0.01	1150.00	11.00	0.10	35.00	1750.00	0.03	31.00	1850.00	0.01		
47.00	2350.00	0.01	49.00	WSO.00	0.01														
Bus ID:	Bus 19	Ht	%	Ht	%	Ht	%	Ht	%	Ht	%	Ht	%	Ht	%	Ht	%		
Nom. KV:	11,000	11.00	SSo.G0	1.36	18.00	650.00	1.33	13.00	1150.00	0.11	18.00	1250.00	0.08	18.00	1150.00	0.05	37.00	1850.00	0.01
	47.00	1350.00	0.01	49.00	180.00	0.01													
Bus ID:	Bus 2	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	11.g.			
Nom. KV:	66,000																		
Order	Freq.	Abg.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	11.g.		
11.00	SSo.G0	0.96	11.00	680.00	0.39	13.00	1050.00	0.11	18.00	1250.00	0.09	35.00	1150.00	0.02	31.00	1850.00	0.01		
41.00	2350.00	0.00	49.00	2450.00	0.00														
Bns ID:	Bus 30	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.			
Nom. KV:	11,000																		
Order	Frtq.	Ht	%	Or-der	Freq.	Hz	%	Order	Freq.	Hz	Or-der	Frtq.	Ht	%	Or-der	Freq.	Hz	%	
11.00	SSs.ee	1.00	18.00	680.00	MI	23.00	J.F.	0.11	18.00	1150.00	0.10	35.00	1750.00	0.03	37.00	J.F.	0.07		
47.00	2350.00	MI	49.00	us.o.oo	0.01														
Bus ID:	Bus 21	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.			
Nom. KV:	66,000																		
Order	Frtq.	Ht	%	Or-der	Freq.	~1.g.	Or-der	Freq.	Mag.	Order	Frtq.	Ht	%	Or-der	Freq.	~1.g.			
11.00	SSo.G0	1.01	13.00	680.00	1.33	23.00	1150.00	0.41	18.00	1150.00	0.11	35.00	1150.00	0.09	37.00	J.F.	0.07		
41.00	1350.00	0.01	49.00	2450.00	0.00														

Project: MASTER THE-S ETAP
 Location: HOIN CIVT LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND STOSI AFA AL-REFAI SnydQis.: HA
 Filename: HOUN STATION 220kV Config: Nounat

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM A.1.0. BIPAC: f ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Talmation

Hannouk Voltages(% of Nominal Voltage)

Bus ID:	Bus22																
Nom. kV:	11.000																
Order	Freq. Hz	Alig. %	Order	Frtq. Hz	%	Order	Fnq. Hz	Ma.	Otdr	Freq. Hz	Mag. %	Order	Frtq. Hz	Mag. %	Order	Freq. Hz	Mdg. %
11.00	550.00	1.01	11.00	650.00	1.88	23.00	1150.00	0.41	18.00	150.00	0.51	3.00	1750.00	0.09	11.00	1850.00	0.00
41.00	2350.00	0.01	49.00	2450.00	0.00												
Bus ID:	Bus23																
Nom. kV:	66.000																
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Frtq. Hz	Mag. %	Otdr	Fnq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Onltr	Freq. Hz	Mdg. %
11.00	550.00	2.74	13.00	650.00	1.17	23.00	1150.00	0.05	18.00	1250.00	0.05	35.00	1750.00	0.00	37.00	1850.00	0.00
47.00	2350.00	0.00	49.00	2450.00	0.00												
Bus ID:	Bus25																
Nom. kV:	11.000																
Order	F~	Mng.	Order	Freq.	Mag.	Order	F'nq.	Alag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Freq.	Mdg.
11.00	550.00	1.74	13.00	650.00	1.17	23.00	1150.00	0.05	25.00	1250.00	0.05	35.00	1750.00	0.00	37.00	1850.00	0.00
47.00	2350.00	0.00	49.00	2450.00	0.00												
Bus ID:	Bus27																
Nom. kV:	66.000																
Order	Fffl. Hz	Mng. %	Order	Freq. Hz	Mag. %	Order	Fffl. Hz	M& %	Otdr	Freq. Hz	Mag. %	Order	Frtq. Hz	Mng. %	Order	Freq. Hz	Mdg. %
11.00	550.00	1.71	13.00	650.00	1.26	23.00	1150.00	0.19	25.00	1250.00	0.23	35.00	1150.00	0.06	31.00	1850.00	0.00
47.00	2350.00	0.01	49.00	2450.00	0.01												
Bus ID:	Bus2S																
Nom. kV:	11.000																
Order	Fnd. Hz	Mng. %	Order	Frtq. Hz	ibg. %	OnU'r	Frtq. Hz	Mag. %	Or&r	Frtq. Hz	Mag. %	Order	Frtq. Hz	Mag. %	Order	Freq. Hz	Mng. %
11.00	550.00	1.73	13.00	650.00	1.16	23.00	1150.00	0.19	25.00	1250.00	0.15	35.00	1150.00	0.06	31.00	1850.00	0.01
47.00	2350.00	0.01	49.00	2450.00	0.01												
Bus ID:	Bus29																
Nom. kV:	11.000																
11.00	550.00	1.71	11.00	650.00	1.16	23.00	1150.00	0.19	25.00	1250.00	0.35	35.00	1750.00	0.06	37.00	1850.00	0.01
47.00	2350.00	0.01	49.00	2450.00	0.01												
Bus ID:	Bus3																
Nom. kV:	220.000																
Order	Fr.q. Hz	Mog. %	Order	Fr~.	Mag. %	Order	Frtq. Hz	Mag. %	Otdr	Fr-tq. Hz	Mag. %	Order	frtq. Hz	Mag. %	Order	Frtq. Hz	Mag. %
11.00	550.00	1.83	11.00	650.00	1.11	23.00	1150.00	0.11	18.00	1250.00	0.53	3.00	1750.00	0.04	37.00	1850.00	0.00
47.00	2350.00	0.03	49.00	2450.00	0.01												

Project: II MASTER THESIS

ETAP

Page: 30

Location: HOUN CITY-LIBYA

12.6.0H

Date: 28-06-1016

Con tr.net: NEAR EAST UTILISITY - EEE-Depar-tm-nt

SN:

Engineer: SAJID ILLIUSTAFAAAL-REFAI

Rt-isition: Base

Filename: HOUN SHI STATION220KV

StudyCase: HA

Config: Non.nal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM'S SIMULATION AND PACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Tabulation

Harmonic Volt.Iges (% o!Nominal Voltage)

Bus ID: Bus30											
Nom. kV: 66.000											
Ordet	Frtq. Hz	Mag. %	Order	Frtq. Hz	Mag. %	Order	Frtq. Hz	Ib: %	Ordrtr	Frtq. Hz	YLG: %
11.00	550.00	1.92	13.00	650.00	1.10	23.00	1150.00	0.34	25.00	1150.00	0.56
47.00	2350.00	0.01	42.00	1450.00	0.00				3:00	1750.00	0.05
Bus ID: Bu31											
Nom. kV: 66.000											
Ordet	Freq. Hz	Mng. %	Order	Freq. Hz	Mag. %	Ordrtr	Frtq. Hz	Mag.	Ordrtr	Frtq. Hz	Ifag.
11.00	510.00	0.97	13.00	650.00	MO	11.00	1150.00	0.12	25.00	1150.00	0.011
41.00	2350.00	0.00	49.00	2450.00	0.00				3s.00	1850.00	(1.02
Bus ID: Bu32											
Nom. kV: 11.000											
11.00	550.00	1.92	13.00	650.00	1.20	23.00	1150.00	0.34	25.00	1150.00	0.56
47.00	2350.00	0.01	49.00	2450.00	0.00				35.00	1750.00	0.05
Bus ID: Bus33											
Nom. kV: 11.000											
11.00	550.00	0.11	13.00	650.00	MO	11.00	1150.00	0.11	18.00	1150.00	0.01
41.00	2350.00	0.00	49.00	2450.00	0.00				3s.00	1850.00	0.01
Bus ID: Bus34											
Nom. kV: 0.400											
11.00	550.00	4.81	11.00	650.00	1.11	23.00	1150.00	1.77	11.00	1750.00	1.11
41.00	13.00	0.47	49.00	2450.00	O.SI				35.00	1750.00	1.13
Bus ID: Bus35											
Nom. kV: 0.400											
11.00	550.00	0.16	13.00	650.00	0.81	11.00	1150.00	1.34	18.00	1150.00	1.0
47.00	2350.00	0.16	49.00	2450.00	0.17				18.00	1750.00	0.46
Bus ID: Bus36											
Nom. kV: 6.400											
11.00	550.00	4.87	13.00	650.00	2.24	11.00	1150.00	5.11	18.00	nsaee	2.11
47.00	2350.00	0.47	49.00	2450.00	O.SI				18.00	1750.00	1.1J

Project: iL^{STER} THESIS
Lccarion: HOIN CITY-LIBYA
Contract: NEAR EAST UNIVERSITY -EEE ; Department
Engieer:- SMD iNSTA A AL-REF AI
Filenmee:- HOUN SUBSTATION220kV

ETAP
12.MH

Page: 31
I)afu: 23-06-1016
SN:
Re,ision: BaSt
C-0nfig: No:n:n:l

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN PFOERGRID

Bus Tahu 1:itiou

Hnrmouk Voltage,%; of Nominal Voltage)

— H1 % — H1 % — H1 % — H1 % — H1 % — H1 % — H1 % — H1 % — H1 % — H1 %

BusId: Bus.S
Nom. kV: 220.000.

Project: -U&UR THESIS
 Location: HOUN aTY LIBYA
 Contract: NEAR EASI UNIVERSITY - EEE Department
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: HA

Page: 32
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A RUGGEDIZED SOLAR PV SYSTEM AND INTEGRATION OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Tabulation

Harmonic Voltages(% of Nominal Voltage)

BusID:	BusS																
Nom. kV:	220.00																
Order	Freq.	Mag.	Ordr	Freq.	%fag.	Order	Preq.	Mag.	Ordr	Freq.	%fag.	Ordr	Freq.	Mag.	Ordu	FWJ.	htg.
47.00	2350.00	0.00	49.00	2450.00	0.00										--		
BusID:	Buro																
Nom. kV:	11.00																
Order	Frtq.	Mag.	Orde	Frtq.	Mng.	Ordr	Freq.	Mag.	Ordr	Freq.	Mng.	Orde	Frtq.	Irg.	Orde	Fw	htg.
11.00	55.00	1.91	18.00	650.00	1.19	23.00	1150.00	0.00	18.00	1250.00	0.00	18.00	1750.00	MS	37.00	1850.00	0.00
41.90	1180.00	0.00	49.00	2480.00	0.01										--		
BusID:	Bus7																
Nom. kV:	66.000																
Ordr	Frtq.	Mag.	Ordr	Frtq.	%fag.	Ordr	fnq.	lbg.	Ordr	Frtq.	%fag.	Orde	Freq.	Mag.	Ontr	fnq.	hhg.
11.00	55.00	0.97	13.00	650.00	0.59	23.00	1150.00	0.00	18.00	1180.00	0.09	35.00	1750.00	0.01	37.00	1850.00	0.01
47.00	2350.00	0.00	49.00	2450.00	0.00										--		
BusID:	Bu'8																
Nom. kV:	66.000																
Order	FWJ.	Mag.	Ordr	Frtq.	Mng.	Ordr	Frtq.	Mag.	Ordr	Frtq.	Attg.	Order	Freq.	Mag.	Ontr	fnq.	hhg.
11.00	55.00	1.91	13.00	650.00	1.19	23.00	1150.00	0.00	18.00	1180.00	0.00	35.00	1750.00	0.00	37.00	1850.00	0.00
47.00	2350.00	0.03	49.00	2450.00	0.02										--		
BusID:	Bus9																
Nom. kV:	11.000																
Order	FWJ.	Mg.	Ordr	Frtq.	Mrg.	Ordr	Fnq.	Mag.	Ordr	Frtq.	lbg.	Onler	Frtq.	Abg.	Ordr	Frtq.	Mag.
11.00	55.00	0.97	13.00	650.00	0.59	23.00	1150.00	0.12	18.00	1180.00	0.09	35.00	1750.00	0.02	37.00	1850.00	0.01
47.00	2350.00	0.00	49.00	2450.00	0.00										--		

Project: HOUN SUBSTATION
Location: HOUN CITY - LIBYA
Contractor: NEAR EAST UNIVERSITY - EEE Department
Engineer: SANDYUSTAFA.AL-REFAI
Filename: HOUN SUBSTATION 220kV

ETAP
12.6.0H

Study Case: HA

Page: 33
Date: 28-06-2016
SN:
Revision: Base.
Config: Normal

DESIGN OF A LA.Rf. & SCALE SOLAR PV SYSTEM IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Alert Summary Report

% Alert Settings

Critical Marginal

§.1.1. Individual Bus VTHD & VI.HD values are used.

Transformer	Total	IEEE	9M
filter			
Capacitor kV	100.0	95.0	
Inductor Amp	100.0	95.0	
Capacitor			
Max: kV	100.0	95.0	
Capacitor			
Ampacity	100.0	95.0	

APPENDIX 10

HARMONICS ANALYSIS WITH FILTERS. AND NO PV CONNECTION

Project:	MASTER THESIS	ETAP	Page:	1	
Location:	HOUN CITY • LIBYA	12.6.0H	Date:	28-06-2016	
Contract:	EAR. EAST UNIVERSITY - EEE Deparment		\$N:		
Engineer:	SAND IDSTAF AL-REFAI	Study Case:	HA.	Revislon:	Base
Filename:	HOUN ShI STATION 220kV			Config:	Normal

DESIGN OF ALARGE SCALE OLARPV SYSTEM DEMAND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID.

Electrical Transient Analyzer-Program

Harmone study with filters and no PV connection

Loading:	Operating P, Q
Generation:	Operating P, Q, V

Number of Buses:	Snin~	V-Conn-ol	L~	Imn!			
	3	0	26	2P			
Number of Branches:	Xfl[R2]	Xfl[R,3]	Reactor	Line/Cable	Impedance	Tie PD	Total
	15	0	0	14	0	0	29
Number of Harm. Sources:	Current	Voltage					
	3	0					

Number of filters:

2

Method of Solution: Adaptive Newton-Raphson

Maximum No. of Iteration: 99

Precision of Solution: 0.000100000

System Frequency: 50.00Hz

Unit System: Metric

Project: ETAP
 Location: HOUN CIY -LIBYA
 Contract: NEAREAST UNIVERSITY-EEE Department
 Engineer: SAND MUSTAFA AL-REFAI
 Filenname: HOUN SUBSTATION220kV

ETAP
 12.6.0H
 StudyCas.: HA
 Revision: Base
 Config: Normal

Page: 2
 Date: 28-06-2006
 SN:
 Config:

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Adjustments

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer Impedance:	Yes	Individual	
Reactor Impedance:	Yes	Individual	
Overload Heater Resistance:	No		
Transmission Line Length:	No		
Cable Length:	No		

Temperature Correction	Apply Adjustments	Individual /Global	Degree C
Transmission Line Resistance:	Yes	Individual	
Cable Resistance:	Yes	Individual	

Project: MASI:ER IIIESIS
 Location: HOUNCUY LIBYA
 Contract: NEAREASIVNnERSITY-EEDepirun,ni
 Engineer: SAJ|I>MUSTAFAAL-REFAI
 Filename: HOUNSUBSIDIATION220kV

ETAP
 12.6.0H
 Page: 3
 Date: 28.06.2016
 SN:
 Redision: Base
 Config: Nonna!

DESIGN OF A LARGESCALE SQL ARPV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Bus Input Data

Bus	ID	kV	Sub-sys	%M.g.	Ang.	Load						%Limits							
						Constant kVA	Constant Z	Constant I	Generic	MW	h.m.r	MW	%cat.	MW	MV-r	MW	MV-r	VTHD	VHD
Bus1		6000	1	98.8	-30.0													10.00	10.00
Bnd		66.000	2	100.0	0.0													10.00	10.00
Bus3		110.000	1	100.0	0.0													10.00	10.00
Bus4		120.000	3	100.0	0.0													10.00	10.00
Bw5		220.000	2	100.0	0.0													10.00	10.00
Bus0		11.000	1	98.1	-60.0													2.50	1.50
Bus7		66.000	2	98.8	-30.0													10.00	10.00
Buss		66.000	1	99.0	-30.0													10.00	10.00
Bu10		11.000	2	98.1	0.0													10.00	10.00
Bus10		11.000	1	97.5	-60.0													10.00	10.00
Bus13		66.000	1	98.3	-30.0													10.00	10.00
Bud4		66.000	2	98.0	-30.0													10.00	10.00
Bu15		11.000	1	98.7	-60.0													10.00	10.00
Bus16		11.000	2	98.1	0.0													10.00	10.00
Bnd7		66.000	1	98.9	-30.0													10.00	10.00
Bus18		66.000	2	98.5	-30.0													10.00	10.00
Bud9		11.000	1	98.7	-60.0													10.00	10.00
Bus10		11.000	2	98.7	0.0													10.00	10.00
Bns11		66.000	1	98.9	-30.0													10.00	10.00
Bu12		11.000	1	911.4	-60.0													10.00	10.00
Bu23		66.000	1	99.3	-30.0													10.00	10.00
Bus19		110.0	1	98.1	-60.0													10.00	10.00
Bml7		66.000	1	98.8	-30.0													10.00	10.00
Bml8		11.000	1	98.4	-60.0													10.00	10.00
Bus29		11.000	1	98.4	-60.0													10.00	10.00
Bu30		66.000	1	98.5	-30.0													10.00	10.00
Bus31		66.000	2	9M	30.0													10.00	10.00
BoJl		11.000	1	98.0	-60.0													10.00	10.00
Bus33		11.000	2	100S	0.0													10.00	10.00

Total Number of Buses: 19

ID	kV	Type	Sub-sys	Voltage		Generation			Thermal Limits	
				%Ldg.	Angle	MW	Mvar	%PF	MW	Min
Bus3	110.000	Swing	1	100.0	0.0					

Project: MASTER THESIS
Location: HOUN CITY - LIBYA
Contract: NEAR EAST UNIVERSITY - EEE Department
Engineer: SAND MUSTAFA AL-REFAI
Filename: HOUN SUBSTATION 220kV

ETAP
12.6.0H

Study Case: HA

Page: 4
Date: 28-06-2016
SN:
Revision: Bilse
Config: Nonnnl

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

ID	Generation Bus			Voltage		Generation			1/fyar Limits	
	kV	Type	Sub-sys	% Mag.	Angle	MW	Mvar	% PF	Max	Miu
Bus4	220.000	Swing	3	100.0	0.0					
Bus5	220.000	Swing	2	100.0	0.0					
										0.00- MOO

Project: IL4STER THESIS
Location: HOUN CITY • LIBYA
 Contracter NEAR EAST UNIVERSITY, EEE Department
 Eugineel: SAJIDUSTAFAAL-REFAI
 Filename: HOUN SUBSTATION 220KV

ETAP
 12.6.0H

Page: 5
 Date: 28-06-2016
 SN:
 Reisious: Base
 Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM ALDIMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Cable Input Data

Cable	ID	Length	•n•L f/Plm"		T (°C)	RI	XI	YI	RO	XO	YO
			Libell,	Size							

Cable resistances are listed at the specified temperatures

Transmission Line Input Data

Line	ID	Ohms or Ohhos / 1000 m per Phase										
		Lengrh	Adj.(m)	% Tol	1/Plmtt	T (°C)	RI	XI	YI	RO	XO	YO
Un,1	674	19m.0	0.0	0.0	1	75	0.056001	0.142069	.0000034	0.200637	1.424041	.0000016
Liu,2	674	2300<1.0	0.0	0.0	1	75	0.056001	0.m~	.0000034	0.zoom	1.424041	.0000016
Ltu,3	674	15000.0	0.0	0.0	1	75	0.056001	0.34%9	.0000034	0.200637	1.424041	.0000016
Lln,4	674	sooo.o	0.0	0.0	1	75	0.056001	0.11;00	.0000034	0.zoom	1.424041	.0000016
Ll***	674	4000.0	0.0	0.0	1	75	0.056001	0.m~	.0000014	0.2006>1	1.424041	.0000016
Un,6	674	4000.0	0.0	0.0	1	75	0.056001	0.m~	.0000014	0.2006>1	1.424041	.0000016
Un,7	674	4000.0	0.0	0.0	1	75	0.056001	0.mor;9	.0000014	0.zoom	1..114on	.0000016
Ltu,S	674	4000.0	0.0	0.0	1	75	0.056001	0.34%69	.0000034	0.200637	J.4;.1041	.0000016
Lint9	674	4000.0	0.0	0.0	1	75	0.056001	0.341%9	.0000034	0.2006.7	U.1:1041	.0000016
Lln,10	674	8000.0	0.0	0.0	1	75	0.056001	0.34%9	.0000034	0.200637	U24041	.0000016
Until	674	8000.0	0.0	0.0	1	75	0.056001	0.342%9	.0000034	0.200637	U14041	.0000016
LintU	674	21000.0	0.0	0.0	1	75	0.056001	0.342%9	.0000034	0.2006.7	U14041	.0000016
Until	674	161000.0	0.0	0.0	1	75	0.056001	0.342%9	.0000034	0.2006.7	U1.1041	.0000016
LintI4	674	140000.0	0.0	0.0	1	75	M.<6001	0.342069	.0000014	M006J7	1.424041	.0000016

Line resistances are listed at the specified temperature

Project: MASU:R THE.51S ETAP Pag= 6
 Lot-tfon: HOUN CIY •LIBYA 12.6.0H Date: 28-06-2016
 Contract: NEAR EA-q IIIVERSIY • EEE Department SN:
 Engineer: SAND MU&LJA AL-REF AI Stud-Case: HA Revision: Base
 Filename: HOUN TUBSTATION 220kV Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

2-Winding Trafo Input Data

Transfomer	ID	Rating					Z Vnialion			%Tap Setting		A<justed	Name	
		MVA	Prim.kV	St.t.kV	%Z	X/R	+S.%	-5%	%Tol.	Prim.	Stt.			
T1	6.1.000	120.000	66.000	12.50	45.00		0	0	0	0	0	U.\$000	Dyn	10.000
T3	11.0.000	120.000	66.000	11.00	45.00		0	0	0	0	0	12.5000	Dyn	-30.000
T4	10.000	66.000	11.000	ass	13.00		0	0	0	0	0	8.3500	Jlyn	11.000
T5	10.000	66.000	11.000	10.00	20.00		0	0	0	0	0	10.0000	Dyn	30.000
T6	20.000	66.000	11.000	10.00	10.00		0	0	0	0	0	10.0000	Jlyn	10.000
T9	10.000	66.000	11.000	8.35	13.00		0	0	0	0	0	8.3500	Jlyn	10.000
TIO	10.000	66.000	11.000	8.35	13.00		0	0	0	0	0	8.3-0	Dyn	30.000
TII	20.000	66.000	11.000	10.00	20.00		0	0	0	0	0	10.0000	Dyn	10.000
T12	20.000	66.000	11.000	10.00	10.00		0	0	0	0	0	10.0000	Dyn	30.000
TB	10.000	66.000	11.000	8.35	13.00		0	0	0	0	0	8.3-	Dyn	10.000
TU	10.000	66.000	11.000	8.35	13.00		0	0	0	0	0	8.3-0	Jlyn	11.000
T16	20.000	66.000	11.000	10.00	20.00		0	0	0	0	0	10.0000	Dyn	Jlyn
T17	20.000	66.000	11.000	10.00	20.00		0	0	0	0	0	10.0000	~	30.000
TIS	20.000	66.000	11.000	10.00	20.00		0	0	0	0	0	10.0000	D-11	30.000
T19	20.000	66.000	11.000	10.00	20.00		0	0	0	0	0	10.0000	~11	30.000

2\Winding Trfm. GrouInput Data

Tr-ausfonner	ID	Rating			Primar			Seconday			Gounding
		~	~	J1!..	TPt				kV	Amp	Ohm
T1	6.1.000	120.000	66.000	Dil'				Solid			
T3	@-000	120.000	66.000	Dil'				Solid			
T4	10.000	66.000	11.000	DIY				S.Ud			
T5	20.000	66.000	11.000	Dik'				S.liid			
T6	20.000	66.000	11.000	Dil'				Solid			
TB	11MQO	66.000	11.000	Dil'				Solid			
TIO	10.000	66.000	11.000	Dil'				Solid			
TII	20.000	66.000	11.000	Dil'				Solid			
TU	20.000	66.000	11.000	Dil'				S.Ud			
T11	10.000	66.000	11.000	i.II'				Solid			
TU	10.000	66.000	11.000	Dil'				Solid			
T16	20.000	66.000	11.000	Dil'				Solid			

Project: JIIA.STERTHESIS
 Location: HOUNCITY-LIBYA
 Contract: NEA!!-EASTU!IYERSITY-EEE Department
 Engineer: SAJ!)-WSTAFAALREFAI
 File(URIWt: HOUNSUBSTATION220kV

ETAP
 12.6.0H
 StudyCase: HA

Page: 7
 Date: 28-06-2016
 SN:
 Revision: Bas.
 Config: Normal

DESIGN OF A LARGE SCALE 9LARPY SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

2-Viewing Transfor.mel Grounding Data

Transformer	Ridug	Grounding					
		Primary			Secondary		
ID	Prim.k-v	TYP	kV	Amp	Type	kV	
T17	20.000	66.000	11.000	D/Y	Solid		
T18	20.000	6MOO	11.000	D/Y	Solid		
T19	20.000	66.000	11.000	D/Y	Solid		

Project: MASTER THESIS
 Location: HOUN CITY - LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 StudyCase: HA
 Page: 8
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Branch Connedigs

Circuit/Branch		Connected Bus ID		% Positive Sequence Impedance (100 MVA Base)		
ID	Type	FromBus	ToBus	R	X	Z
T1	2WXFMR	Bus1	Bus1	0.44	19.84	19.84
T3	IWXFMR	Bu,S	Bu,2	0.44	19.84	19.84
T4	ZWXFMR	Bus1	Bu,6	6.40	83.25	83.50
T5	2WXFMR	Bu,7	Bu,9	1.00	49.94	50.00
T6	aw XFMR	Bus8	Bus10	2.30	49.14	50.00
T9	IWXFmr	Bu,13	Bus15	6.40	83.25	83.50
T10	2wxnm	Bus14	Bus16	6.40	S3Z5	83.50
T11	2WXFJIR	Bu,17	Bus19	1.50	49.94	50.00
T12	2WXFMR	Brn!S	Bu,20	2.50	49.14	50.00
T13	IWXFim	Bus21	Bu,z1	UO	83.25	83.50
T14	IWXFirR	Bu,?3	Bu,25	6.40	S3.25	83.50
T16	IWXFMR	Bus27	BusZS	2.30	49.9,J	50.00
T17	IWXF!R	Bus27	Bu,19	2.50	49.14	50.00
T18	IWXF!R	Bu'30	Bus32	2.50	49.94	50.00
T19	2WXF!R	Bus,11	Bu,33	2.50	49.14	50.00
Lin1	Lin,	Bu,1	Bu,14	2.48	16.58	16.77
Lin,1	Lin,	Bud	Busl3	2.48	15.16	15.36
Lin,3	Lin,	Bu,2	Bu,18	2.66	18.06	18.30
Lin,4	Lin,	Bu,Z7	Busl7	1.93	11.78	11.94
Lin,5	Lin,	Busl	Bum	LOI	6.28	6.37
Lin&	Lin,	Busl	Bus7	M1	1.14	3.18
Lin,7	Lin,	Bud	Buss	US1	1.14	3.18
Lin,8	Lin,	Bu,2	Bus7	0.51	3.14	3.18
Lin,9	Lin,	Busl	Bus8	0.51	3.14	3.18
Linl0	Lin,	Bw12	Bus,1l	1.03	6.28	6.37
Lin,11	Lin	Busl	Bus10	LOI	6.28	6.37
Linl2	Lwr	Busl?	Bus21	1;70	16.,9	16.71
Linl3	Lin,	Busl7	Bus1.	20.70	IZMJ	128.1!
Linl4	Lin,	Bus21	Bu,23	18.00	109.14	111.40

Project: MA-TER THESIS ETAP
 Location: HOUN CITY -LIDYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY -EE Department.
 Engineer: SAND USTAFAL-REFAI Study Case: HA
 Filename: HOUN SUBSTATION 220kV
 Page: 9
 Date: 2&-06-2016
 SN:
 Revision: Base
 Config: Nonna!

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Branch Ignition:
Zero Sequence Impedance

Ckt/Bldg ID	Type	Comorted Bus ID		% Impedance, Uro ~q., 100 Jiff Ab			
		From Bus	To Bus	Ro	Xo	Zo	Yo
T1	%\Xfmr	Bus1	Bus1				
T2	2\Xfmr	B'5	Bus2				
T3	:WXfmr	Bud	Bus6				
T5	1WXfmr	Bus7	Bus9				
T6	1WXfmr	Bus8	Bus10				
T9	2\Xfmr	Bud3	Bud8				
NO	1WXfmr	Bus14	Bus16				
T11	ZWXfmr	Bus17	Bus19				
T12	:?WXfmr	Bus18	Bus20				
TB	:?WXfmr	Bus21	Bus2				
TU	2\WXfmr	Bus13	Buds				
T16	2\WXfmr	Bus27	Bus28				
T17	ZWXfmr	Bus17	Bus29				
T16	2WXfmr	Bus10	Bus32				
T19	2\WXfmr	Bus1	Bus11				
Lin1	Lin.	Bus1	Bud-i	8.86	60.29	60.94	0.1410145
Lin2	Lin	Bud	BusB	8.89	61.09	63.72	0.1341983
Lin3	Lin	Bud	Buds	10.59	15.19	75.93	0.159925\$
Lin-I	Lin	Bus17	Bus17	6.91	49.04	49.52	0.1042992
LinS	Lin	Bud	Bus17	1.6S	26.15	26.U	0.055626:Z
Lin6	Lin,	Bus1	Bus7	1.64	13.0S	13.Z!	0.0278131
Lin7	Lin	Bud	Bus.S	1.64	13.08	13.ZI	0.0278131
Line8	Lin	Bus1	Bus7	1.64	IMS	1S.II	0.0278131
Lin9	Lin	Bud	Buss	1.84	13.08	13.21	0.0278131
Lin10	Lin	Bus1	Bus31	3.6S	26.15	26.41	0.056262
Lin11	Lin	Bus1	Bud 0	1.68	26.15	26.41	0.0556262
LinD2	Lin	Bus17	Bus11	9.61	68.65	69.33	0.1460189
Lnd3	Lin	Bus7	Bud3	74.16	516.33	SSLS	1.1194780
Uid4	Lin	Bud	Bus23	64.4S	457.66	462.10	0.9734595

Project: MASTER THESIS
 Location: HOUN CUY LIBYA
 Contract: NEAR EAST UNIVERSITY - EEI6 Department
 Engineer: SAJII IIDSTAF A-L-REFAI
 Filename: HOUN SUBSTATION Z20KV

ETAP
 12.6.OH

Page: 10
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nonna!

DESIGN OF A LARGE SCAIXSOLAR PV SYSTEM AT THE ANALYSIS OF ITS INTEGRATION TO LIBYAN POWER GRID

Machine Input Data

Madline	Connected Bus		Rating (Base)			% Negath-e Seq. Imp.			Grounding		% Zero Seq. Imp.			
	M	Typt	ID	MVA	kV	R>II	XIR	JU	X!	Conn.	Typt	Amp	XIR	RO
U1	Grid	Bus3		:U.01	220.000	10.00	9.95(1	99.50	Wyt	Solid		10.00	17.738	177.38
IN	Grid	Bus1		:U.101	110.000	10.00	9.95(0	99.50	Wyt	Solid		10.00	17.738	177.38
U3	Grid	BusS												

Project: ILLISTER THESIS
 Location: HOUN CITY - LIBYA
 Contract: ILLAR EAST UNTILRSFI - tte Department
 Engineer: SAND ILWSTAI'A AL-REFAI
 Filename: HOUN SHILLSTATION 220kV

ETAP
 12.6.0H
 Page: 11
 Date: 28-06-2016
 SN:
 RMision: Base
 Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Harmonic Library

Cum: <4 Harmonic Source in %

Manufacturer: ABB											
Model: ACS60012P											
Order	Freq.	M.g.	Ordr	Freq.	Mag.	Order	Freq.	M.g.	Order	Freq.	M.g.
1.00	\$0.00	100.00	5.00	Z\$0.00	2.60	7.00	350.00	1.50	11.00	550.00	3.70
19.00	950.00	0.30	23.00	1150.00	0.10	25.00	1150.00	use	13.00	650.00	3.70

Manufacturer: ABB											
Model: ACS60012P											
Ordr	Freq.	fu.bg.	Ordr	Freq.	fu.bg.	Ordr	Freq.	fu.bg.	Ordr	Freq.	fu.bg.
1.00	\$0.00	100.00	s.00	180.00	2.60	1.00	350.00	1.50	11.00	s;0.00	.10
IMO	950.00	0.30	?~.00	1150.00	0.10	25.00	1150.00	use	13.00	ssaeee	3.10

Manufacturer: ABB											
Model: ACS60012P											
Order	Freq.	fu.bg.	Order	Freq.	fu.bg.	Ordr	Freq.	fu.bg.	Oiltr	Frtq.	Afag.
1.00	\$0.00	100.00	~	"1H00	~	-;00	7\$0.00	1.50	0.00	~	-r.0 10-0 65MO
19.00	950.00	0.30	23.00	1150.00	0.10	25.00	1150.00	use	-r.0 10-0 65MO	-r.0 10-0 8\$0.00	0.50

Project: IIESTER IHE&IS ETAP
 Location: HOTIN CITY -LIB\!A 12.6.0H
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engineer: SAND ?IUSTAFA AL-REFAI Study Case: RA
 Filename: HOUN Sh-STATION 220kV
 Page: 12
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Harmonic Source from Library

BndD	Dtdee-ID	Harmonic Source Information				
		~	M'anfortuJ'l'	Mod'l	Fllld. Frq.	Mod. Frq.
Bu!	UJ	Curnt	ABB	ACS6001P	0.00	0.00
Bu>	U1	Currtut	ABB	ACS6001ZP	0.00	0.00
Bus	U3	Cwnut	ABB	ACS6001ZP	0.00	MO

Project: MASTER THESIS ETAP
 Location: HOUN CIY -LIBYA 12.6.0H
 Contract: EAR EAST UNIVERSITY EEE Department Date: 28-06-2016
 Engineer: SAND USTAFAL-REFAI Revision: Base
 Filename: HC UNSUBSTATION220kV Config: Normal

DESIGN OF A LARGE SCALE SOLAR-PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Filtel' Input Data

Filter Type: Single-Tuned

Filter	Connected Bus	Capacitor C1			Inductor L1				
		ID	IV	AfakV	Ioc	XI	QFct.	MaxI	
HF2	Bus2		66.000	0.000	62000.0	0.0000	0.00	0.0	0.0000
HF1	Bm1		66.000	0.000	62000.0	0.0000	0.00	0.0	0.0000

Project: MASJiR TIIESJS
 Location: HOUN CITY -LIBYA
 Contact: NEAR EAST UNIT, ERSm - I.I.I. Department
 Engineer: SAND MUSTAFA AL-REFAI
 filename: HOUN 1>tiIISTATION220kV

ETAP
 12.6.0H
 Study Case: HA

Pag.: 14
 Date: 28-06-2016
 SN:
 Reflsciu Base
 Couflg: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEMA, "IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYANPOWER GRID

final demand Load Flow Results only with filters until no PV connection

Bus	ID	kV	Voltage		Generation		Load		Load Flow		Xfmr		
			%Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	% PF
Bus1		66.000	115.507	-0.2	0	0	0.000	-82.720	Bu,13	0.000	-0.379	Z9	0.0
									Bus27	0.000	-1.188 ⁹	-1.1	-0.3
									BUS8	0.000	-0.079	M	0.0
									Bus8	0.000	-0.079	C.S	0.0
									Bu,30	-0.000	-0.157	1.1	0.0
									Bu,3	0.000	0.30,	583.9	0.0
									Bus6	0.000	0.000	0.0	0.0
									Bu,H	0.000	-0.10	1.6	0.0
Bus1		66.000	110.1SS	-19.5	0	0	0.000	-50.913	Bus1S	0.000	-0.442	3.4	0.0
									Bus7	0.000	-0.077	0.6	0.0
									Bus7	0.000	-0.071	0.6	0.0
									Bus31	0.000	-0.154	1.2	ae
									BusS	0.000	SL003	67.9	0.0
*Bus3		120.000	100.000	0.0	0.1SS	1s.m	0	0	Bus1	0.1SS	1s.11?	ZOS1	-0.4
*Bus5		210.000	100.000	0.0	0.117	-71.782	0	0	Bus2	0.217	-11-182	ISS.4	-0.3
Bus6		11.000	115.< j7	-60.1	0	0	0	0	Bus4	0.000	0.000	0.0	0.0
Bus7		66.000	114.%40	12.8	0	0	0	0	Bus1	0.000	0.000	0.0	0.0
									Bu,1	0.000	0.000	0.0	0.0
									Bu,9	0.000	0.000	0.0	0.0
Bus8		66.000	115.SOS	-10.1	0	0	0	0	Bus1	0.000	0.000	0.0	0.0
									Bud	0.000	0.000	0.0	0.0
									Bus10	0.000	0.000	0.0	0.0
Bus9		11.000	114.240	-0.1	0	0	0	0	Bus7	0.000	0.000	0.0	0.0
Bus10		11.000	115.-0S	-10.1	0	0	0	0	Bus8	0.000	0.000	M	0.0
Bus13		66.000	111.;31	-10.1	0	0	0	0	Bus4	0.000	0.000	0.0	0.0
									Bus11	0.000	0.000	0.0	0.0
BusU		66.000	114.263	19.5	0	0	0	0	Bus2	0.000	0.000	0.0	0.0
									Bus16	0.000	0.000	0.0	0.0
Bus15		11.000	115.SS1	-10.1	0	0	0	0	Bud3	0.000	0.000	0.0	0.0
Bus16		11.000	114.263	-0.1	0	0	0	0	Bud4	0.000	0.000	0.0	0.0
Bus17		66.000	116.549	-10.3	0	0	0	0	Bm,17	-0.009	6.493	48.7	-0.1
									Bu,11	0.008	J.249	14.4	-0.1
									Bus13	0.004	J.244	24.3	-0.1
									Bud9	0.000	0.000	0.0	0.0
Bus18		66.000	114.273	29.11	0	0	0	0	Bud.	0.000	0.000	M	0.0
									Bus10	0.000	0.000	0.0	0.0
Bud\$		11.000	116.549	-10.1	0	0	0	0	Bu,S17	0.000	0.000	0.0	0.0

Project: JIL<STER THESIS

ETAP

Page: 18

Location: HOUN CITY -LIBYA

12.6.0H

Date: 28.06.2016

Contract: NEAREAST UNIVERSITY-EEE Department

SN:

Engineer: SM'D IWSTAFAL-REFAI

Study Case: HA

Revision: Base

Filename: HOUN Sh1STATION 220kV

Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

ID	Bus	Voltage		Generation		Load		ID	Load Flow			Xf/R	
		MW	Xflow	MW	Mrar	1fV	Afr-lr		Amp	% PF	% Tap		
Bus20		11.000	114.73	-0.1	0	0	0	Bus1S	0.000	0.000	M	0.0	
Bus21		U.000	116.979	030	0	0	0	Bus7	-0.003	2.839	21.1	-0.1	
								Bus13	0.003	-1.839	U.1	-0.1	
								Bus12	0.000	0.000	0.0	0.0	
Bts22		11.000	116.979	-60.1	0	0	0	Bus11	0.000	0.000	0.0	0.0	
Bus23		U.000	118.010	-30.4	0	0	0	Bus17	0.000	-0.001	0.0	-16.2	
								Busn	0.000	0.001	0.0	-16.2	
								Bm28	0.000	0.000	0.0	0.0	
Bus18		11.000	118.010	-60.4	0	0	0	Bus13	0.000	0.000	0.0	M	
Bu27		U.000	115.678	-30.2	0	0	0	Bu17	0.015	-6.753	SLO	-0.1	
								Bm1	-0.015	-7.753	SLO	-0.1	
								Bu128	0.000	0.000	0.0	0.0	
								Bus19	0.000	0.000	0.0	0.0	
Bus28		11.000	115.878	-60.1	0	0	0	Bu27	0.000	0.000	0.0	0.0	
Bu19		11.000	115.878	-60.1	0	0	0	Bus27	0.000	0.000	0.0	0.0	
Bu0		U.000	115.511	-30.2	0	0	0	Bus1	0.000	0.000	0.0	0.0	
								Bud2	0.000	MOO	0.0	0.0	
Bm31		66.000	111.111	-9.8	0	0	0	Bw1	0.000	0.000	0.0	0.0	
								Bm33	0.000	0.000	0.0	0.0	
Bus32		11.000	115.811	-60.2	0	0	0	Bu10	0.000	0.000	0.0	0.0	
Bm33		11.000	114.243	-0.1	0	0	0	Bm31	0.000	0.000	0.0	0.0	

IndraSoft a tool for integrating data between different systems or sub-systems. It provides a common interface for data exchange between various applications.

Project: MASTER THESIS
 Location: HOUN CITY-LIBYA
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engineer: SALAH IUSTAFAAL-REFAL
 Filename: HOUN-SUBSTAION220KV

ETAP
 126-0H
 Page: 16
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

System Bank Configuration Bus Information

Bus	ID	kV	Voltage Distortion									
			Fund.	RMS	ASU!!	1IID	TIF	TIHD	TSHD	1IDG	THDS	
Bud		66,000	115.51	115.51	117.11	MS	8.34	0.00	0.00	0.68	MS	
Busl		66,000	114.24	114.14	115.81	0.69	1,1G	MO	0.00	0.69	0.69	
Bu,J		220,000	100.00	100.44	119.56	9.40	11.1SS	-0.00	0.00	9.40	9.40	
Bu,5		110,000	100.00	100.17	117.81	MI	19U9	0.00	0.00	8.62	M?	
Bu,6		11,000	115.51	115.51	117.04	0.68	B4	MO	0.00	0.68	0.GS	
Bm7		66,000	114.14	114.14	115.81	M9	7.77	0.00	0.00	0.69	0.69	
Bu,8		66,000	115.51	115.51	117.05	MS	8.35	0.00	0.00	0.68	MS	
Bus9		11,000	114.24	114.14	115.81	0.69	7.77	0.00	0.00	0.69	-0.69	
Bus4		11,000	115.51	115.51	117.05	0.68	8.35	MO	0.00	0.68	MS	
Bus11		66,000	115.53	115.51	117.11	0.69	11.10L	0.00	-0.00	-0.69	M9	
Bud4		66,000	114.26	114.27	115.86	0.70	8.01	0.00	0.00	0.70	0.70	
Bu,15		11,000	115.53	115.51	117.10	0.69	5.61	0.00	0.00	0.69	0.69	
Bu,16		11,000	114.16	114.27	115.86	0.70	8.01	0.00	0.00	0.70	0.70	
Bus17		66,000	116.53	116.88	119.03	1.00	14.26	0.00	0.00	1.00	1.00	
Bus18		66,000	111.17	114.18	115.89	0.71	8.11	0.00	0.00	0.71	0.71	
Bu,19		11,000	116.55	116.88	119.01	1.00	U.26	0.00	0.00	1.00	1.00	
Bus10		11,000	114.17	114.28	115.89	0.71	S.U	0.00	0.00	0.71	0.71	
Bu,11		66,000	116.13	116.13	119.01	1.19	18.49	0.00	0.00	1.19	1.19	
Bus11		11,000	116.98	116.99	119.11	1.19	18.49	0.00	0.00	1.19	1.19	
Bus11		66,000	118.32	118.32	118.32	I2LSS	1.00	13.18	0.00	0.00	1.00	2.00
Bus15		11,000	115.31	118.14	12.58	1.00	uis	0.00	0.00	1.00	1.00	
Bu,17		66,000	115.88	115.88	117.72	0.77	9.45	0.00	0.00	0.77	0.77	
Bu,28		11,000	115.88	115.88	117.72	0.77	9.45	0.00	0.00	0.77	0.77	
Bu,19		11,000	115.88	115.88	117.72	0.77	9.45	0.00	0.00	0.77	0.77	
Bus,10		66,000	115.81	115.81	117.05	MS	8.38	0.00	0.00	0.GS	0.68	
Bus,11		66,000	114.14	114.14	115.81	0.69	7.80	0.00	0.00	0.69	0.69	
Bus,11		11,000	nssi	nssi	111.0s	0.68	ass	0.00	0.00	0.GS	0.68	
Bus,11		11,000	11.24	11.15	11.11	0.69	1.10	0.00	0.00	0.69	0.69	

#hdK:tt1HD (Total Harmonic Distortion) Exceeds the Limit.
 #Indkats NM (Induced Harmonic Distortion) Exceeds the Limit.

Project: MA.SIER THESIS ETAP Page: 17
 Location: HOIIN CITY LIBYA 12.6.0H Date: 28-06-2016
 Contract: NEAR EAST UNIVERSITY-EEI; O.parmen SN:
 Engineer: SANDMI/STAFAAAL-REFAI Function: Best
 Fileuune: HOIIN SUBSTATION 220kV Config: Normal

DESIGN OF A URGE SCHEQUE SQLARPV SYSTEMS IN THE TANALYSIS OF ITS INTEGRATION TO LIBYAN POWER GRID

System Harmonics Branch Information

Bus	FromBusID	ToBusID	Fund. Amp	Current Distortion										
				RMS Amp	Asum Amp	THD %	TIF	IT Amp-Amp	ITB Amp-Amp	ITu	mm %	TSHD %	THDC %	THDS %
Bus1		Bu.13	1.1.1	2.88	3.13	U7	108.88	313.J1	313.31	0.00	0.00	0.00	6.17	6.17
		Bus2	\$1.17	\$1.37	60.24	8.81	86.23	452M6	4526.65	0.00	0.00	0.00	SS1	8.81
		Bu.8	MO	0.60	0.67	M9	106.75	63.66	63.66	0.00	0.00	0.00	6.09	M9
		B.S.	0.60	0.60	0.67	6.09	106.75	63.66	63.66	0.00	0.00	0.00	6.09	6.09
		B'30	1.19	1.19	1.34	.10	107.01	m.-4.	127.61	0.00	0.00	0.00	6.10	6.10
		Bus3	683.89	685.06	768.76	S.85	99.34	68057.16	68057.16	0.00	0.00	0.00	5.85	~.85
		Bu.6	0	0	0	0	0	0.00	68057.16	0.00	0.00	0.00	0.00	0.00
Bus4			1.61	1.61	2.93	5.PZ	101.39	1~.70	14.70	0.00	0.00	0.00	SSA	5.91
		Bus5	3.19	3.39	3.81	5.95	101.34	347.06	347.06	0.00	0.00	0.00	5.95	~.95
		Bu.7	0.59	0.59	0.66	5.85	99.40	58.62	58.62	0.00	0.00	0.00	5.85	5.85
		Bus7	0.59	0.5	0.66	5.85	99.40	58.62	58.62	0.00	0.00	0.00	5.85	5.85
		»~n	1.1S	1.18	1.32	SJ16	99.66	117.53	117.53	0.00	0.00	0.00	5.86	5.86
		Bu.5	617.93	619.00	705.90	5.85	99.35	62488.11	6US8.71	0.00	0.00	0.00	5.85	5.85
Bus1		Bud	IOS.17	205.S1	230.63	5.88	99.34	20417.15	10-117.15	0.00	0.00	0.00	5.85	5.85
Bu.8		Bin?	ISSIS	188.70	III.77	5.85	99.37	18146.61	18746.61	0.00	0.00	0.00	5.85	5.85
Bu.6		Bus1	0	0	0	0	0	0.00	18746.61	0.00	0.00	0.00	0.00	0.00
B11s7		Bus2	0	0	0	0	0	0.00	167-16.62	0.00	0.00	0.00	0.00	0.00
		Bw1	0	0	0	0	0	0.00	18746.61	0.00	0.00	0.00	0.00	0.00
		Bus9	0	0	0	0	0	0.00	18746.61	0.00	0.00	0.00	0.00	0.00
Bu.5		Btd	0	0	0	0	0	0.00	18746.61	0.00	0.00	0.00	0.00	0.00
		Bus1	0	0	0	0	0	0.00	18746.61	0.00	0.00	0.00	0.00	0.00
		Bus0	0	0	0	0	0	0.00	18746.61	0.00	0.00	0.00	0.00	0.00
Bus9		Bus7	0	0	0	0	0	0.00	18N6.61	0.00	0.00	0.00	0.00	0.00
Bu.10		Bus5	0	0	0	0	0	0.00	18746.61	0.00	0.00	0.00	0.00	0.00
Bu.13		Bud	0	0	0	0	0	0.00	18746.61	0.00	0.00	0.00	0.00	0.00
		Buslti	0	0	0	0	0	0.00	18146.62	0.00	0.00	0.00	0.00	0.00
Bu.U		Bus1	0	0	0	0	0	0.00	18146.62	0.00	0.00	0.00	0.00	0.00
		Budf	0	0	0	0	0	0.00	187-16.62	0.00	0.00	0.00	0.00	0.00
Bud-		Bu.13	0	0	0	0	0	0.00	18146.61	0.00	0.00	0.00	0.00	0.00
Bud6		Bus4	0	0	0	0	0	0.00	18746.62	0.00	0.00	0.00	0.00	0.00
Bu.17		Bu.17	48.73	48.9+	f6,\$0	9.17	85.66	4191.34	4191.34	0.00	0.00	0.00	9.17	9.17
		Bndl	2439	24.50	2857	9.59	104.05	1548.96	25.f5.96	0.00	0.00	0.00	9.59	9.59
		Bus3	24.38	24.44	27.93	8.71	67.97	1661.37	1661.37	0.00	0.00	0.00	8.71	8.77
		Bus9	0	0	0	0	0	0.00	161SJ1	0.00	0.00	0.00	0.00	0.00
BudS		Bus1	0	0	0	0	0	0.00	1661.37	0.00	0.00	0.00	0.00	0.00
		Bus10	0	0	0	0	0	0.00	1661.37	0.00	0.00	0.00	0.00	0.00
Bus9		Bu.17	0	0	0	0	0	0.00	1661.37	0.00	0.00	0.00	0.00	0.00
Bu.17		Bus1S	0	0	0	0	0	0.00	1661.37	0.00	0.00	0.00	0.00	0.00
Bus11		Bus17	II.13	?LLF	IS.01	10.06	87.86	1874.43	1874.43	0.00	0.00	0.00	10.06	10.06
		Bw.23	21.23	?L13	15.01	10.06	87.86	1874.43	1874.43	0.00	0.00	0.00	10.06	10.06
		Bud.2	0	0	0	0	0	0.00	1874.43	0.00	0.00	0.00	0.00	0.00

Project: MSTER THESIS ETAP
 Location: HOUN CTIY -LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY -LEE Department
 Engineer: SAND MUSTAFA AL-REF AI Study Case: HA
 Filenamne: HOUN SUBSTATION 110KV Re.isfor- Base
 Config: l'lonnal

DESIGN OF A LARc SCALE SOLAR.PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION TO LIBYA POWER GRID

Bus	FromBusID	ToBu-sID	current distortion											
			Fund. Amp	RMS Amp	ASUM Amp	T% %	TIF	IT	% %	Ira	IIIID	TSHD %	THDG %	THDS %
Bus21	Bu-21		0	0	0	0	0	0.00	1674.13	0.00	0.00	0.00	0.00	0.00
Bus23	Bu.17		0.01	0.13	0.W	1404.38	2701.48	34M7	349.97	0.00	0.00	0.00	U04.38	1404.18
	Bu.21		0.01	0.13	0.29	1404.38	2702.48	34M7	349.97	0.00	0.00	0.00	U04.38	1404.18
	Bus1S		0	0	0	0	0	0.00	349.97	0.00	0.00	0.00	0.00	0.00
Bus1S	Bns13		0	0	0	0	0	0.00	349.97	0.00	0.00	0.00	0.00	0.00
Bu-17	Bu.17		50.98	51.18	SS.99	8.96	81.49	4476.34	4178.14	0.00	0.00	0.00	8.96	8.96
	Bus1		50.98	S1.1S	SS.99	8.96	87.49	4478.34	4178.34	0.00	0.00	0.00	8.96	8.96
	BUS28		0	0	0	0	0	0.00	4178.14	0.00	0.00	0.00	0.00	0.00
	Bu~?		0	0	0	0	0	0.00	4478.34	0.00	0.00	0.00	0.00	0.00
BuJO	Bu.I		0	0	0	0	0	0.00	4478.34	0.00	0.00	0.00	0.00	0.00
	B1131		0	0	0	0	0	0.00	4478.34	0.00	0.00	0.00	0.00	0.00
Budl	Bus2		0	0	0	0	0	0.00	4178.14	0.00	0.00	0.00	0.00	0.00
	BUS.3		0	0	0	0	0	0.00	4478.34	0.00	0.00	0.00	0.00	0.00
BusJ2	Bu<30		0	0	0	0	0	0.00	4178.14	0.00	0.00	0.00	0.00	0.00
	Bu.35		0	0	0	0	0	0.00	4478.34	0.00	0.00	0.00	0.00	0.00

Project: MASTER IHEYSIS
Location: HOUN CITY-LIBYA
Contract: NEAR EAST UNIVERSITY - EEE Department
Engineer: SAND AL-STAFKA AL-REFAI
Filename: HOUN SII1BSTA110N220kV

ETAP
12.0.OH

P.ge: 19
Date: 28-06-2016
SN:
Rt,isioll: Bast
Config: Normnl

DESIGN OF A LARGE SCALE SOLAR PV SYSTEMA fil Th!PACT A.I.:ALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Tabulation

Linnonic Voltages(% of Fundamental Voltage)

Projekti: MASTER IHEYSIS
Loratööd: HOUN CIJY-LIBYA
Kontakt: !\"EAR EAST U1!\"ER51JY - EEE Department
Ehitaja: SAND MUSTAFA A1-REF A1
Failinimi: HOUN SUBSTATION 220KV

**ETAP
12.6.0H**

Page: 20
Date: 28-06-2016
SN:
Revtsion: Base
Config: Nonnal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AT IDIAPAC, ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Bus Tabulation

Harmonic Voltages (% of Nominal Voltage)

Project: IL-STER THESIS
 Location: HOUN CITY - LIBYA
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engineer: SAND ilfUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP

12.6.0H

Page: 21
 Date: 28.06.2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE-SOURCE SOLAR PV SYSTEM'S IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Filter On-Loading

Filter1			CapacitorC1			InductorL1			CapacitorC2			InductorL2		
ID	Type	Count	Amp.	Opr.	%	Miu.	Opr.	%	hfax.	Opr.	%	Afnx.	Opr.	%
HFI	3	Wyo	0.000	63.074	N/A	0.00	627.63	N/A						
HFZ	3	Wy	0.000	62.408	NJA	0.00	62M4	NIA						

Filter Types: 0 = By-Pass, 1 = High-Pass (Damped), 2 = High-Pass (Undamped), 3 = Single Tuned, 4 = 3rd Order Damped, 5 = 3rd Order C-Type

Project: MASTER THESIS ETAP Page: 22
 Location: HOUN CITY-LIBYA 12.6.0H Date: 28-06-2016
 Contract: NEAR EAST UNIVERSITY • EEE O partneur SN:
 Engineer: SA'AD DURUS TAFA AL-REFAI Revision: Base
 Filename: HOUN SUBSTATION220kV Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ASSESSMENT OF ITS INTEGRATION INTO LIBYAN POWER GRID

Alert Summary Report

% Alert Settings

Critical Marginal.

AW.

Individual Bus V/I/H/J values are used.

Transformer

	Total	90.0	95.0
--	-------	------	------

Filter

	Capacitor kV	90.0	95.0
	Inductor Amp	100.0	95.0

Capacitor

	100.0	95.0
--	-------	------

Cable

	Ampacity	100.0	95.0
--	----------	-------	------

APPENDIX 11

HARMONICS ANALYSIS WITH FILTERS AND PV

Project:	MASTER THESIS	ETAP	Page:	1
Location:	HOUN Cm ² -UBYA	12.6.0.H	Date:	28-06-2016
Contract:	YEAR EAST UNIVERSITY - EEE Department		SN:	
Engineer:	SADM MUSTAFA AL-REF AI	Study Case:	HA	Revision: Base
Filename:	HOUN SUBSTATION 220KV		Config:	Normal

DESIGN OF A LARGE SC-SUE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Electrical Transient Analysis Program

Harmonic study with filters and PV connection

Loading: Optimum P, Q

Generation: Optimum P, Q, V

Number of Buses:	Shunt L	V-Conn-ol	Load	Total
	3	7	30	40

Number of Transformers:	XFMIU	XFMR3	Reacter	Line/Cable	Impedance	Tie PD	Total
	24	0	0	16	0	0	40

Number of Harmonic Sources:	CnTent	~	~	~
	4	0	~	~

Number of Filters: **2**

Method of Solution: Adalivo Newton-Raphson

Maximum No. of Iteration: 99

Precision of Solution: 0.000100000

System Frequency: 50.00Hz

Unit System: Ipfenic

Project: IL\STER THESIS
Location: HOUN CITY -LIBYA
Contract: NEAR EAST UNIVERSITY EEE Department
Enginner: SANDI\NISTAFAAL-REFAI
filename: HOUN SUBSTATION220kV

ETAP
12.60H

Study Case: HA

Page: 2
Date: 28-06-2016
5:N
Revision: Base
Config: Nonna

DESIGN OF A LARGE SCALE SOLAR PV SYSTEMAFFECT PACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Adjustment

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer Impedance:	Yes	Individul	
Reactor Impedance:	Yes	Individul	
Overload Heater Resistance:	No		
Transmission Line Length:	No		
Cable Length:	No		

Temperature Correction

Temperature Correction	Apply Adjustments	Individual /Global	Degree C
Transmission Line Resistance:	Yes	Individul	
Cable Resistance:	Yes	Individul	

ProjW: MASTER THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR EAST LINTERGYCITY - EEE Ieparmmeur
 Engineer: SAID 1,WSTAF A AL-REF AI
 Filenmne: HOUNSUBSTATION220kV

ETAP
 12.60H

Study Co., HA

Page: 3
 Date: 25-06-2016
 S.A:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND THIPICT ANALYSISOFTS INTEGRATION INTO LIBYAN POWER GRID

Bus Input Data

Bus	kV	Sub.:;S	% %Ing.	Angle	Load						o/oLbnits
					ConStat KY-1	CommanZ	Con tant	Gtorih:	VTHD	VHD	
m					MW	Akar	MW	Mnrr	MW	M,ur	
Bu-1	11000	1	98.5	-10.0							10.00
Bus1	66.000	2	100.0	0.0							10.00
BusJ	110.000	1	100.0	0.0							5.00
Bus4	220.000	3	100.0	0.0							10.00
Bus5	110.000	2	100.0	0.0							10.00
Bus6	11.000	1	98.1	-6.0							5.00
Bus7	66.000	1	98.5	30.0							10.00
Bus8	66.000	1	92.0	-88.0							10.00
Bus9	11.000	2	98.1	0.0							10.00
Bus0	11.000	1	97.8	-60.0							10.00
Bus11	66.000	2	100.0	30.0							10.00
Bus12	66.000	1	100.0	0.0							10.00
Bus13	66.000	1	98.1	-30.0							10.00
BusU	66.000	1	98.0	30.0							10.00
BusE	11.000	1	98.1	0.0							10.00
Bml6	11.000	1	98.1	0.0							10.00
Bml7	66.000	1	98.9	-30.0							10.00
Bud8	66.000	1	98.5	0.0							10.00
Bw19	11.000	1	98.1	-50.0							10.00
Bu,20	11.000	2	98.7	0.0							10.00
Bus??	66.000	1	98.9	0.0							10.00
Bus??	11.000	1	98.1	-60.0							10.00
Bu,:?3	66.000	1	99.1	0.0							10.00
Bu,:?S	11.000	1	98.1	-60.0							10.00
Bus27	66.000	1	98.8	0.0							10.00
Bu,VJ	11.000	1	98.4	-60.0							10.00
Bus19	11.000	1	98.4	-20.0							10.00
Bus30	66.000	1	98.5	-10.0							10.00
Bus!!	66.000	1	98.6	30.0							10.00
Bud:?	11.000	1	98.0	-60.0							10.00
Bus31	11.000	1	100.5	0.0							10.00
Bud,f	0.400	1	100.0	-10.0							10.00
Bu\$3S	0.400	1	100.0	,0.0							5.00
Bu,16	0.400	1	100.0	10.0							10.00

Project: HOUN CITY-LIBYA
 Location: HOUN CITY-LIBYA
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engineer: S.U.I. MDSLFA AL-REFAI
 Filename: HOUN SUBSTATION 110KV

ETAP

12.6.0H

Page: 114

Date: 28-06-2016

SN: 11428062016

Re.ision: Base

Config: Nol'mal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM A¹U¹ IN PAGI A¹ALYSIS OF ITS INTEGRATION TO LIBYA'S POWER GRID

Load										
Bus.	ID	kV	Sub-sys	Initial W ¹ Q ¹ I ¹ G ¹	Coef/Item	kV.	Construt Z	Constant I	Gfneic	% Limits
		110.00	~	100.00;0.00						
Bus37										
Bus35		0.100	2	100.0 -30.0						5.00 5.00
Bus39		0.400	2	100.0 10.0						5.00 5.00
Bus40		MOO	2	100.0 30.0						10.00 10.00
Bwl		11.000	1	120.0 -60.0						10.00 10.00
Bus.t2		11.000	2	98.9 0.0						
Total Number of Buses: -10					0.000	0.000	0.000	0.000	0.000	0.000

Generation Bus				Voltage		Generation			Operational Limits	
ID	kV	Typ.	Sub-sys	% Reg.	Ailgt	MW	Mvar	% PF	Mn	Min
Bus1	120.00	Swing	1	100.0	0.0					
Bn-4	110.000	Swing	3	100.0	0.0					
Buss	110.000	Swing	1	100.0	0.0					
Bn:3-1	0.400	Voltage Control	1	100.0	-30.0	1.952			0.000	0.000
Bus3S	0.400	Voltage Control	1	100.0	-30.0	US!			0.000	0.000
Bn:36	0.400	Voltage Control	1	100.0	-30.0	1.952			0.000	0.000
Bm:37	0.400	Voltage Control	1	100.0	-30.0	1.951			0.000	0.000
Bn:15	0.400	Voltage Control	1	100.0	30.0	1.95			0.000	0.000
Bn:39	0.400	Voltage Control	1	100.0	30.0	1.952			0.000	0.000
Bus10	MOO	Voltage Control	1	100.0	30.0	1.952			0.000	0.000
						13.66?	0.00			

Project: IUS1 R THE51S
 Location: HOUN CITY LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Deperneur
 Engineer: SAID MUSTAFA AL-REFAI
 Filename: HOUN STATION 220KV

ETAP
 12.6.0H
 Study Case: HA

Page: 5
 Date: 28-06-2016
 SN:
 Srtslcne: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND ITS INTEGRATION IN LIBYAN GRID

Cable Input Data

Ohms or Ohms / 1000 m per Conductor

Cable	Length												
	ID	Ubrary	Size	Adj.(m)	% Tol	#Phase	T (°C)	R ₁	X ₁	Y ₁	R ₀	X ₀	Y ₀
Cnbl.1		INRCESS	.000	100.0	0.0	1	15	0.076302	0.081400	0.0001616	0.140151	0.w.000	
Cabtl.		ILICUS3	.000	100.0	0.0	1	11	0.016302	0.000000	0.0001616	0.240351	0.m000	

Cable resistances are listed at the specified temperatures

Transmission Line Input Data

Ohms or Mhos / 1000 m per Phase

Line	Length											
	ID	Lnbr.	Str	Adj.(m)	% Tol	Tha, < ---R_1--->	V ₁	R ₀ , ---Y ₀				
LJn.1		674	000.0	0.0	1	75	0.066001	0.mi;;	.000001	0.200011	1.60791,	.0000017
LJn.2		674	000.0	0.0	1	15	0.066001	0.mi69	.000001	0.200637	1.unoh	.0000016
Lin.1		674	2000.0	0.0	1	75	0.066001	0.JII069	.000001	0.200637	1.m.o.u,	.0000016
Lin.2		674	1500.0	0.0	1	75	0.066001	0.34069	.0000034	M00637	1.III041	.0000016
LInt5		674	8000.0	0.0	1	75	0.066001	0.3II069	.000001	0.200637	1.III041	.0000016
Lin.6		674	4000.0	0.0	1	15	0.056001	0.3II069	.0000031	0.100637	1.4!40II	.0000016
LInt7		674	4000.0	0.0	1	75	0.056001	0.3420681	.0000031	0.200637	1.II04-U	.0000016
Lin.8		674	4000.0	0.0	1	75	0.056001	0.3U069	.0000031	0.200637	1.III041	.0000016
Lin.9		674	4000.0	0.0	1	rs	0.06001	0.mo69	.000001	0.200637	1..inoh	.0000016
Lin.10		674	8000.0	0.0	1	75	0.06001	0.mo69	.000001	0.200637	1.u40n	.0000016
Linell		674	8000.0	0.0	1	75	0.056001	0.342069	.0000034	0.200637	1.I40II	.0000016
LIn.12		674	21000.0	0.0	1	15	0.066001	0.342069	.000001	0.200637	1.mor1	.0000016
LIn.13		674	161000.0	0.0	1	75	0.066001	0.JII069	.000001	0.200637	1..I=I	.0000016
LIn.14		674	140000.0	0.0	1	75	0.06001	0.342069	.0000034	M00637	1.424041	.0000016

Line parameters are listed at the specified temperatures

Project: oUSTERTHESIS
Location: HOUN CITY- LIBYA
Contract: NEAR EAST UNIVER.SITT - EEE Department
Engineer: SAND-HIRUST Af A AL-REF AI
Filename: 1 OUN SUBSTATION 220kV

ETAP
 12.6.0ll
Date: 28-06-2016
SN:
Revision: Bas
Study Case: HA
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA>; POWER GRID

2-Winding Transformer Input Data

Transformer	ID	Rating				Z Variation			Tap Setting		Adjusted % Z	Phns. Shift	Type	Augt
		MVA	PrlllkY	Sec. kV	% Z	Xll	+ 5%	- 5%	% ToJ.	:Prlm.	Ste.			
T1		63.000	220.000	66.000	11.50	45.00	0	0	0	0	0	11.5000	Dyn	30.000
T3		<3.000	220.000	66.000	11.50	45.00	0	0	0	0	0	12.5000	Dyn	-30.000
T4		10.090	66.000	11.000	8.35	iae	0	0	0	0	0	8.3500	Dyn	30.000
TS		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	Dyn	30.000
T6		20.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	Dyn	30.000
T7		12.500	11.000	66.000	8.35	13.00	0	0	0	0	0	8.3500	VNd	30.000
TS		12.500	11.000	66.000	8.35	13.00	0	0	0	0	0	8.3500	Dyn	30.000
T9		10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	8.3500	D;h	30.000
T10		10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	8.3500	Dyn	30.000
T11		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	D;H	30.000
TU		10.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	D;H	30.000
TU		10.000	66.000	11.000	8.35	10.00	0	0	0	0	0	8.3500	Dyn	30.000
T14		10.000	66.000	11.000	8.35	10.00	0	0	0	0	0	8.3500	DyU	30.000
T16		20.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	D;h	30.000
T17		10.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	D;h	30.000
T18		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	Dy~	30.000
T19		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	Dyn	30.000
NO		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.2500	VNd	j0.000
N1		3.000	0.400	11.000	6.1;	6.00	0	0	0	0	0	6.2500	VNd	-30.000
T11		3.000	0.100	11.000	6.25	6.00	0	0	0	0	0	6.2500	VNd	-30.000
T13		3.000	0.400	11.000	6.15	6.00	0	0	0	0	0	6.2500	VNd	-30.000
T24		3.000	0.100	11.000	6.15	6.00	0	0	0	0	0	6.1500	VNd	-30.000
T15		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.1500	VNd	j0.000
T26		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.1500	VNd	-30.000

2-Winding Transformer Grounding Input Data

Transformer	ID	R.mnJ[Conn.	Primary				Secondary				Grounding
				TP"	kV	Amp	Ohm	T-pt	kV	Amp	Ohm	
T1		63.000	220.000	66.000	DIY				Solid			
TS		6.000	110.000	66.000	DIY				Solid			
T4		10.000	66.000	11.000	DIY				Solid			
T5		10.000	66.000	11.000	D/Y				Solid			

Project: ~IASTER THESIS ETAP
 Location: HOUN CITY LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Eugueens SAID ;MSR..U-A AL-REFAI Study Case: HA
 Filename: HOUN SUBSTATION 220kV Config: Normal

DESIGN OF A LIGHT SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

2-Lines Transformer Modeling Input Data

Grounding

Transformer	ID	Rating	Coun.	Primary				Secondary			
				TJ-pt	kV	Amp	Obm	Iine	EV	Amp	Obm
T6		20.000	66.000	11.000	D/Y			Solid			
TI		10.000	11.000	66.000	D/Y			Solid			
TS		12.000	11.000	66.000	D/Y			Solid			
T9		10.000	66.000	11.000	D/Y			Solid			
TIO		10.000	66.000	11.000	D/Y			Solid			
TI!		10.000	66.000	11.000	D/Y			Solid			
TI2		10.000	66.000	11.000	D/Y			Solid			
TI3		10.000	66.000	11.000	D/Y			Solid			
TU		10.000	66.000	11.000	D/Y			Solid			
Tl6		20.000	66.000	11.000	D/Y			Solid			
TI7		20.000	66.000	11.000	D/Y			Solid			
TIS		20.000	66.000	11.000	D/Y			Solid			
TI9		20.000	66.000	11.000	D/Y			Solid			
T20		3.000	0.400	11.000	D/Y			Solid			
II1		3.000	MOO	11.000	D/Y			Solid			
!22		3.000	MOO	11.000	D/Y			Solid			
n1		3.000	MOO	11.000	D/Y			Solid			
!24		3.000	MOO	11.000	D/Y			Solid			
ns		3.000	MOO	11.000	D/Y			Solid			
Tl <i>d</i>		3.000	UOO	11.000	D/Y			Solid			

Project: MASTER TiltSIS -ETAP
 Location: HOUNCHIY • LIBYA 12.6.0H Date: 28-06-2016
 Contract: NEAREAST UNIVERSITY EEE Department SN:
 Engineer: SANDMUSTAFAAL-REFAI Rollision: Base
 Filename: HOUNSUBSTATION220kV Config: Nominal

DESIGN OF A LARGESCALE SOLAR PV SYSTEM AND THIPAC ANALYSIS OF ITS INTEGRATION IN TOUBYA POWER GRID

Ckt/Branch		Connected Bus ID		% Positive Sequence Impedance (IOOH/VABase)		
ID	T/Pt	From Bus	To Bus	R	X	Z
T1	IWXFIR	Bus1	Boil	0.0	19.84	19.84
T3	2WXFMR	BU\$	1..Z	0.44	19.34	19.84
T4	IWXFMR	Bus1	&6	6.40	83.18	83.50
TS	IWXFIR	Bus7	&9	2.50	49.94	50.00
T6	IWXFMR	Bu.S	Bud 0	2.50	49.94	50.00
T7	2WXFIR	Bus.1l	Buul	5.12	66.60	66.80
TS	2WXDJR	Bu.41	Bus11	8.11	66.60	66.80
T9	IWXFIR	Bu.13	Bus1-	6.40	83.28	83.50
T10	2VXFIR	Bu.H	&d6	MO	83.18	\$,.80
T11	2WXFIR	Bu17	Bus1?	1~	49.94	50.00
T12	2WXFMR	Bu18	Bu20	2.50	49.94	SMO
T13	2WXFIR	Bu.1ll	BusU	6.40	83.25	S>.50
T14	IWXFIR	Bus13	B-1S.	6.40	83.25	83.50
T16	IWXFIR	Bua7	Bus?8	1.50	49.94	50.00
T17	2W:a:MR.	Bus17	&29	1.50	49.94	50.00
T18	IWXFAIR	Bu10	Bus32	1.50	49.94	51.00
T19	ZWXFMR	Bus.II	Bus33	1.50	49.94	51.00
no	IWXFIR	&s34	Bu11	34.25	105.50	208.33
T1!	IWXFIR	Bus35	1..11	34.15	101.1M	208.33
T12	2WXFIR	Bus16	1..11	34.28	101.80	208.31
T13	2WXFIR	Bu17	Bus41	8.11	205.50	208.11
T14	2WXFMR	Bu18	Bu1!	~,5	205.50	208.11
T15	2WXFMR	Bus.19	BnN?	34.25	205.50	208.11
/26	IWXFMR	Bu.140	Bu'42	34.25	205.50	208.33
C.~1,1.	Cablt	Bus11	Bu,1	0.01	0.07	0.03 0.0716998
Cable-1	Cab!*	Bud!	Bus1	0.02	0.01	0.03 0.0716998
Llud	Liut	Bus1	ir,u	1.48	16.58	16.71 0.2607629
Lieu!	Liu•	Bud	Bu.,13	1.48	15.16	15.36 0.28.1226
Llu,3	Li..	Bu~	Bu,18	?96	18.06	18.30 oT11M
Lint,1	Lint	BU:Z7	Bu,17	L93	11.78	ii.94 0.2109015
Une5	Lne	Bus1	1..,11	1.01	6.28	6.37 0.117S141
Lindi	Liu•	Bus?	Bu.,7	0.51	3.14	3.18 0.0589071
Llu,7	Lint	ir,1	Buss	0.51	1.14	3.18 0.0589071
Lint8	Liu,	Bu.Z	it,1	0.51	1.14	3.18 0.0589071
Llu,9	Lint	Bu1	ir,s	0.51	1.14	3.18 0.0589071
LludO	Liu,	Bu,1	Bus1!	1.03	6.28	6.31 0.1178142
i,iu,u	Line	Bud	Bus30	LOI	6.28	6.31 0.1178142

Project: AUSTER THESIS
 Location: HOUN CITY-LIBYA
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engineer: SANDI IFIJSTAFA AL-REFAF
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 StudyCas.: HA
 Page: 9
 Date: 28-06-2016
 SN:
 Revision: Base,
 Config: Noriaal

DESIGN OF A LARGE SCALE SOLARPVSYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWERGRID

Ckt/Bi-and	ID	Connected	Bus ID	% Positive Sequence Impedance (100 MVA Base)			
				From Bus	To Bus	R	X
LindZ		Line	Bus17	Bus11		7.70	16.49
Liud13		Line	Bus7	Bus11		20.70	126.43
Liud4		Line	Bus21	Bus21		18.00	109.94
						16.71	111.40
						0.30926Z2	2.3710100
							2.0617480

Project: iUSTER THESIS
Location: HOUNOT-LIDYA
Contract: NEAR EAST UNIVERSITY - EEE Department
Engbeer: SAND IJWSTAFIA AL-REFAI
Filename: HOUN' SUBSTATION 220kV

ETAP
12.6.0H

Page: 10
Date: 28-05-201~
SN:
Revlsln: Base
Conflg: Normal

DESIGN OF A LARGE SC-E SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Diagonal Connections

CKT/Brauch			Connected	Bus ID	% Impedance, - Z.ro Sl'q, 100 M:VAl			
ID	Tut	From Bus	To Bu-	RO	XO	Zo	ve	
Tl	IWXfmr	Bn,3	Bus1					
T3	:?WXfmr	Bus5	Bus1					
n	?WXfmr	Bu,l	But6					
TS	IWXfmr.r	Bus7	Bus9					
T6	IWX!mr	Bus8	Bu,10					
T7	:?VXfmr	Bu<I?	Bindl					
TS	?WXfmr	Bu<ll	Bu<ll					
19	IWXfmr	Bud3	Bus18					
TIO	2WX1mr	Bu,U	Bud6					
TU	ZWXfinr	Bu,17	Bad9					
TII	ZWXfmr	Bu,18	Bind20					
TB	IWXfmr	Bus21	Bual					
TU	?WX!mr	Bm23	BQ\$IS					
T16	IWX!mr	Bu17	Bus18					
TU7	IWXFmr	Bus:27	Bus19					
TIS	IWXfmr	Bu,30	BLPI					
TIS	IWX!mr	Bu0l	Biu33					
no	2WXfmr	Bu34	Bu<II					
TZI	2WX!mr	Bu,35	Bit'4!					
n1	IWXfmr:	Bu,36	Bu<il					
ru	IWXfmr	Bu,37	Bu<ll					
n,	:?VXfmr	Bu,38	Bus41					
TIS	IWXfmr	Bu,39	Bm-R?					
Tl6	IWX!mt	Bus40	Bin.al					
Cnbld	Cablt	Bud!	Bud	0.06	0.08	0.67		
Cnhitl	Cat,l,	Bus12	Bnsl	0.06	0.08	0.01		
Lille!	Liu,	Bus?	BusU	8.86	60.19	60.94	0.1410145	
Lind:	U.,	Bnd	Bud3	8.89	6M9	63.71'	0.1341983	
Lim3	Liu,	Bus?	Bus18	10.59	75.19	15.93	0.1599155	
Liu,4	Liut	8"17	Bnl7	6.91	49.04	49.52	0.1041992	
Un,\$	Liu,	Bud	Bus17	1.68	%6.1S	26.41	0.0556262	
Liut6	Line	Bus%	Bui?	1.84	13.08	1S.N	0.0278131	
Lne7	Line	Bus1	BuS	U4	U.08	13.11	0.0218131	
LiutS	Liu*	Bu?	Bus7	1.84	13.08	13.21	0.0278131	
Line,9	U1**	Bu,s	BmS	1.84	13.08	1S.11	0.0278131	
Line-10	Lfit	Bus1	Bu31	MS	26.15	26.41	0.0556262	

Project: MASTER THESIS
 Location: HOUN CITY -LIBYA
 Conract: NEAR EALJ UNIVERSITY - EEE Department
 Engineer: SA.ND IWSTAF A At-REFAI
 Filename: HOUNSUB,TATION220K

ETAP
 12.6.0H
 Study Case: HA

Page: 11
 Date: 28-06-2016
 SN:
 Redision: Base
 Config: Nonnal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND Thfi>ACTANAL~IS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Ckt/Branch		Connected Bus ID		% Impedance, Zero Seq., 100 MVAb			
ID	Type	From Bus	To Bu-	~R0	~X0	~Z0	~Y0
Lind1	Liu	Bus1	Bus30	3.68	16.15	16.41	0.0556261
Lind2	Liu	Bus17	Bus21	9.61	68.65	69.33	0.1.60189
Lind3	Ltne	Bus17	Bus23	74.16	516.33	S31.5.1	J.1194780
Lin14	Line	Bus11	Bus23	61.48	457.68	46.10	0.9734598

Project: ILSTER. THESIS
 Location: HOUN CITY - LIBYA
 Contract: JI,EAR EAST UNIVERSITY - EEE Depnrtmenr
 Engineer: SAND MUSTAFA AL-REF AI
 Filename: HOUN SLIBSTATION 220kV

ETAP
 12.6.0H
 StudyCase: HA

Page: 12
 Date: 28-06-1016
 SN:
Re-dsioi: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Machine Input Data

~Lidine	Connected Bus			Rating (Base)			% Negati've Seq. Imp.			Grounding			% Z. ro Seq. Imp.		
	ID	Type	ID	I~	kV	~	XiR	R?	Xl	Cowl.	Type	Amp	XiR	RO	~
U1	Grid	Bus1		22.101	220.000		10.00	Mso	99.0	Wl,	Solid	10.00	1.5<48	356.111	
U2	(Md	B"4		22.101	120.000		10.00	9.950	99.50	Wr,	Solid	10.00	17.738	177.38	
U3	Grid	BusS		22.101	110.000		10.00	9.950	99.50	Wj*	Solid	10.00	17.738	177.38	

Project: MASTER THESIS

ETAP

Page: 13

Location: HOUN(tY •LIBYA

12.6.0H

Date: 28-06-2016

Contract: NEAREASTUNIVERSITY -EEE, Deparment

SN:

Engiu*: SANDIUISTAFALJIEFAJ

Revison: Base

Filename: HOUNSUBSTATION20kV

Study Caso: HA

Coofig: Nonna!

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND ITS INTEGRATION INTO LIBYAN POWER GRID

Harmonic Library**Current Harmonic Source in %**

Manufaturer: Typkal-IEEE																		
Model:	Order	Freq.	Mog.	Oekr	Fr.q.	lbg.	Ordtr	Freq.	Mog.	Ordtr	Freq.	F.fag.	Ordtr	Freq.	Mag.	Ordtr	Freq.	h.fag.
	1.00	-!L so.00	100.00	11.00	-!L ss.00	-!L sjo	-!L 11.00	-!L 650.00	6.70	-!L 13.00	-!L ns.00	-!L 1.50	-!L 25.00	-!L mo.00	-!L z.30	-!L 1.50	-!L 11.00	-!L 0.20
	37.00	1850.00	0.60	47.00	Z.150.00	0.10	49.00	1410.00	0.10									

Manufaturer: TypicaHEEE																		
Model:	Order	Fr.q.	Mog.	Ordtr	Fr.q.	lbg.	Ordtr	Freq.	Mog.	Ordtr	Freq.	Mog.	Ordtr	Freq.	lbg.	Ordtr	Freq.	Mag.
	1.00	• 80.00	100.00	11.00	• SS.00	• S10	• 13.00	• 610.00	• 6.70	• le.00	• 150.00	• -r.50	run ~	• 130	• 3100	• im'00	• 0.50	
	37.00	iss.00	MO	47.00	1.1.00	0.20	49.00	us.00	0.10									

Manufaturer: Typical-IEEE																		
Model:	Order	fr.q.	lbg.	Ordtr	fr.q.	lbg.	Order	fr.q.	Afag.	Ordtr	Freq.	~fag.	Order	fr.q.	Mag.	Ol-dtr	Freq.	fag.
	1.00	• 80.00	100.00	11.00	• 55.00	• 8.30	• 13.00	• 650.00	• 6.70	• 13.00	• 1150.00	• 1.80	run ~	• 130	• 3100	• m0.00	• 0.50	
	37.00	1850.00	MO	47.00	Z.150.00	0.10	49.00	1.1.00	0.10									

Manufaturer: Typkal-IEEE																		
Model:	Order	Fr.q.	lbg.	Ordtr	ff"4	ll.g.	Order	Fr.q.	Mag.	Ordtr	Fr.q.	~l.g.	Ordtr	Freq.	Afag.	Oekr	Fr.q.	Mag
	1.00	• 80.00	100.00	11.00	• ss.00	• ase	• 13.00	• ~8.00	• MO	• 1.4.00	• mo.00	• 1.80	• 25.00	• ns.00	• 1.1.0	• 1.1.00	• 11.9.00	• 0.50
	37.00	iss.00	Mo	47.00	1.1.00	0.20	49.00	us.00	0.10									

Project: L\STER INSSIS ETAP Page: 14
 Location: HOUN CITY -LIBYA 12.6.6H Date: 28-06-2016
 Contract: N'EAR EAST UNIVERSITY- EEE Department
 Engineer: SANDIDSTAFAAL-Ref.\I Study Case: HA Revision: Base
 Filenmne: HOUNSUBSTATION220kV Config: Nonna!

DESIGN OF A LARGESCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Hannouk Source from Library

Hannouk Source Information						
BusID	Dev ID	Manuf.actrtr	Modl	Fund.Fltg.	Mod.Fltg.	
Bu,3~	In,11	Currtut	Tlirk-L-IEEE	lIPulstl	0.00	MO
BmJ6	Im,15	Current	Typical-IEff	il Pulul	0.00	0.00
Bu,37	Im,1S	Curnut	Tijlical-IEEE	UPulu2	0.00	0.00
Bu,39	Im,21	currnt	Typical;IEEE	OPuhZ	0.00	0.00

Project: IIU&IER1HE-IS
 Location: HOUNCITY-LIBYA
 Contract: NEAR EASTUNIYERSITY- EEE Department
 Engineer: SAJID LIUSLIFA AL-REFAI
 Filename: HOUN SUBSTATION220kV

ETAP
 12.60H
 Study Case: HA

Page: 15
 Date: 28-06-2016
 SN:
 Revision: Bas.
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Filter Input Data

FilterType: Single-Tuned

Filter ID	Connected Bus ID	Capacitor Cl			Inductor L1			
		kV	lnrxkV	ln-n	Xl	Q Fact,	lnfaxI	
HFZ	Bus1	66.000	100.000	420.7	88.5804	90.00	100.0	0.0000
HF1	Bus1	66.000	100.000	140.1	ZS7.0066	70.00	100.0	0.0000

Project: ~USTER THESIS
 Location: HOUN CITY - LIBYA
 Country: NEAR EAST UNIVERSITY - EEE Department
 Author: SAID JIWSLAFA AL-REFAI
 File Name: HOUN SIESTATIONZ20KV

ETAP
 12.6.0H

Study Case: HA

Page: 16
 Date: 28-06-2016
 SN:
 Rating: Best
 Config: Nonna!

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Fundamental Load Flow Report

Bus	Voltage			Generation		Load		ID	Load Flow			Xf(M)
	ID	kV	%l%	MW	Mvar	MW	Mvar		PF	Amp	%PF	
Bus1		66.000	101J68	-29.1	0	0	0.000	-0.144	Bus1	7.726	0.622	67.1 -99.1
									Bud3	0.000	-1.790	2.5 0.0
									Bus7	0.000	-S.174	-6.7 -0.3
									Bm8	0.000	-OMO	M 0.0
									BnsS	0.000	-0.060	0.1 0.0
									Bus30	0.000	-0.120	1.0 0.0
									Bus3	7.712	SJIS	81.1 81.3
									Bus6	0.000	0.000	0.0 0.0
Bus1		66.000	100.193	30.7	0	0	0.000	-0.426	Bus1	-5.799	OJS.1	50.7 -99.8
									Bus1	0.000	-1.162	1.3 0.0
									Bus15	0.000	-0.340	3.0 0.0
									Bus7	0.000	-1.059	0.8 0.0
									Bus11	0.000	-0.059	AS 0.0
									Bus5	5.199	0.881	51.2 98.9
*Bus3		110.000	100.000	0.0	-7.708	-5.157	0	0	Bin1	R7.708	RS.157	1.1 S.11
*Bus5		220.000	100.000	0.0	-5.798	-0.511	0	0	Bus1	.798	-0.813	15.4 99.0
Bus6		11.000	101.068	-59.1	0	0	0	0	Bus1	0.000	0.000	0.0 0.0
Bus7		66.000	100.194	30.7	0	0	0	0	Bus2	0.000	0.000	0.0 0.0
									Bus2	0.000	0.000	0.0 0.0
									Bus5	0.000	0.000	0.0 0.0
Bus8		66.000	101.069	-29.1	0	0	0	0	Bin1	0.000	0.000	0.0 0.0
									But1	0.000	0.000	0.0 0.0
									Bud0	0.000	0.000	0.0 0.0
Bus9		11.000	100.194	0.7	0	0	0	0	Bus1	0.000	0.000	0.0 0.0
Bus10		11.000	101.1169	-59.1	0	0	0	0	Bus8	0.000	0.000	0.0 0.0
Bus11		116.000	100.194	30.7	0	0	0	0	Bus1	S.111	-0.455	\$0.8 -99.1
									Bus42	-1.199	0.455	\$0.8 -99.1
BwlZ		66.000	101.1169	-19.1	0	0	0	0	Bus1	7.726	-0.695	67.1 -99.6
									Bus41	-7.126	0.691	67.1 -99.6
Bu,13		66.000	101.090	-29.1	0	0	0	0	Bus1	0.000	0.000	0.0 0.0
Bu,14		66.000	100.215	30.7	0	0	0	0	Bu,15	0.000	0.000	0.0 0.0
									Bus1	0.000	0.000	0.0 0.0
Buds		11.000	101.090	-59.1	0	0	0	0	Bud1	0.000	0.000	0.0 0.0
Bus16		11.000	100.215	0.7	0	0	0	0	BusU	0.000	0.000	0.0 0.0
Bus17		116.000	101.980	-29.1	0	0	0	0	Bus27	-0.007	4.911	42.6 -0.1

Project: IWTI:R THESIS
 Location: HOUNCITY LIBYA
 Contract: EAR EA>T LR(TVERSITT EEE Deparrus+nt
 Eulgueei: SANDMUSTAFAAL-RUAJ
 Filename: HOUN SUBSTATION 220kV

ETAP

Page: 17
 Date: 28-06-2016
 SN:
 Reli-ion: Base
 Coullg: Normal

DESIGN OF A LARxE SC.UX SOLAR PV i,-sn:~IALi'D ThIPACT ANALYSIS OF ITS INTEGRATIONTH TO LIBYAN PO\ERGRID

Bus	ID	KV	T-Etag	Geufl'ation		Load		ID	UadFlow				
				Ang.	MW	Mvar	MW	M, m	MW	%frar	Amp	%Pf	%Tap
									Bus21	0.001	.1SS	ZL1	-0.1
									Bus23	0.003	-1.48.i	IL3	-0.1
									Bus19	0.000	0.000	0.0	0.0
BusS		66.000	10-0.2:U	30.7	0	0	0	0	Bus?	0.000	0.000	0.0	0.0
									Bm1O	0.000	0.000	0.0	0.0
Bus9		11.000	101.1Si	-sd>Z	0	0	0	0	Bus17	0.000	0.000	0.0	0.0
Bus10		11.000	100.M	0.,	0	0	0	0	Bus\$	0.000	MOO	0.0	0.0
Bu21		0.000	1013.-	-29.3	0	0	0	0	Btsl7	-0.002	1.17J	1U	-0.1
									BusH	0.002	-1.173	18.6	-0.1
									Bu12	0.000	0.000	0.0	0.0
Bus11		11.000	102.356	.S9.3	0	0	0	0	Bu-zl	0.000	0.000	0.0	0.0
Bm:13		66.000	103.530	-29.4	0	0	0	0	Bus?	0.000	-0.001	0.0	16.2
									Bus?!	0.000	0.001	0.0	-16.1
									Bus15	0.000	0.000	0.0	0.0
B-2\$		11.000	103.530	-59.4	0	0	0	0	Bnsl3	0.000	0.000	0.0	0.0
Bu-27		66.000	101.392	-19.1	0	0	0	0	Bus17	0.0U	-5.170	44-	.12
									Bust	-0.01	5.170	44-	.0.1
									Bus1S	0.000	0.000	0.0	0.0
									Bu29	0.000	0.000	0.0	0.0
Bu-28		11.000	101.302	.S9.Z	0	0	0	0	Bus17	0.000	0.000	0.0	0.0
Bu-29		11.000	10LJ91	-59.1	0	0	0	0	Bu-27	0.000	0.000	0.0	0.0
Bus30		66.000	101.05	-19.1	0	0	0	0	Bud	0.000	0.000	0.0	0.0
									Bus32	0.000	0.000	0.0	0.0
Bus.il		66.000	100.197	30.7	0	0	0	0	Busl	0.000	Q.000	0.0	0.0
									Bus3l	0.000	0.000	0.0	M
Bus!		11.000	101.071	-59.1	0	0	0	0	Bus,10	0.000	0.000	0.0	0.0
Bus3l		11.000	100.197	0.7	0	0	0	0	Bus31	0.000	0.000	0.0	0.0
Bus,14		0.400	101.713	-14.0	1.951	0.000	0	0	But-ti	1.957	0.000	2769.6	100.0
Bu,55		0.400	101.111	.u.o	1.951	0.000	0	0	8U,U	1.952	0.000	2769.6	100.0
8t,d6		0.400	101.113	.u.o	1.952	0.000	0	0	Bu<II	1.952	0.000	2769.6	100.0
Bus7		MOO	101.713	.u.o	1.952	0.000	0	0	Bus41	1.952	0.000	2769.6	100.0
Bus38		0.400	100.847	JS.1	1.951	0.000	0	0	BuJW?	1.952	0.000	2791.4	100.0
Bus,19		MOO	100.847	JS.1	1.951	0.000	0	0	Bus4l	1.952	0.000	Z19ü	100.0
Bus40		0.400	100.511	SS.1	1.951	0.000	0	0	8U,'2	1.952	0.000	2791.4	100.0
Bus41		11.000	101.133	-56.?	0	0	0	0	Bud?	7.756	-0.303	402.8	.99.9
									Bnd<1	1.939	0.076	100.7	-99.9
									Bus3S	-1.939	0.076	100.7	.99.9
									BuJ6	-1.939	0.076	100.7	-99.9
									Busn	-1.919	0.076	100.7	-99.9

Project: MASTER THESIS
Location: HOUN CITY - LIBYA
Contract: NEAR EAST UNIVERSITY - EEE Department
Engineer: SAND MUSTAFA AL-REFAI
Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H

Page: 18
Datec: 28-06-2016
SN:
Revision: Ba"
Config: Nonna.I

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus	Voltage			Generation			Load	LoadFlow			XFMR	
	ID	V	~	P	Q	2	Mw	ID	MW	2	~	
Bus4.2		11.000	100.263	2.9	0	0	0	Bm11	S.S17	-1.231	301.7	-99.9
								Bm38	-1.919	0.077	101.6	-99.9
								Bw19	J.939	0.077	101.6	-99.9
								Bm10	-1.939	num	101.6	-99.9

" Indicates a voltageC; r=atfd but ((voltage-
indicates bus "is load m>max(half) than OJ MVA

Project: iL\STER THESIS
 Location: HOUNCnY-LIBYA
 Contract: NEEAR EAST UnIVERSITY'EE Department
 Eugin.: SANDUSTAFAAL-REFAI
 Filename: LOUN StJISTATION 220KY

ETAP
12.6.0H

Study Case: HA

Page: 19
Date: 28-06-2016
SN:
Revision: BMF-
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

System Information

Bus ID	kV	Voltage Distortion									
		Fund.	RMS	ASUM	TID	TR	THD	TSHD	THDG	THDS	
Bus-1	6MOO	101.07	101.09	103.78	1.85	52.15	0.00	0.00	us	1.85	
Bm1	66.000	100.19	100.10	101.86	!AO	31.80	0.00	0.00	1.40	1.10	
Bus1	110.000	100.00	100.02	102.60	1.19	50.48	0.00	0.00	1.79	1.79	
Bu-S	1:20.000	100.00	100.01	101.59	1.3:	30.51	0.00	0.00	1,	1.34	
Bu.6	11.000	101.07	101.09	101; Is	1.85	Sz.15	M-0	0.00	1.85	J.85	
Bu.7	66.000	100.19	100.20	101.86	1.40	31.81	0.00	0.00	1.40	!AO	
Buss	66.000	101.07	101.09	103.79	1.85	52.31	0.00	0.00	1.85	1SS	
Bus9	11.000	100.19	100.10	101.86	1.40	31.85	0.00	0.00	1.40	1.40	
Bud 0	11.000	101m	101.09	103.79	1.85	52.31	0.00	0.00	1.85	LBS	
Bus.II	66.000	100.19	100.10	101.86	1.40	31.80	0.00	0.00	1.40	10	
Bud!	66.000	101.07	101.09	103.78	1.85	52.15	MO	0.00	1.85	1.SS	
Bind3	66.000	101.07?	101.11	104.01	1.93	1.6.50	0.00	0.00	1.93	1.93	
Bu:IIU	66.000	100.11	100.23	101.97	1.45	33.17	MO	0.00	U5	1.45	
BudS	11.000	101.09	1E1.11	104.01	1.93	56.50	0.00	0.00	1.93	1.93	
Bu.16	11.000	100.12	100.H	101.n	1.45	33.17	0.00	0.00	U5	1.45	
Bu'17	66.000	101.98	102.00	104.34	1.97	44.U	0.00	0.00	1.97	J.97	
Bu.18	66.000	100.11	100.23	102.02	1.47	33.81	0.00	0.00	1.47	1.47	
Bu.19	11.000	101.98	102.00	104.34	1.97	44.U	0.00	0.00	U7	1.97	
Busl0	11.000	1(10.22	100.21	102.02	1.47	33.81	0.00	0.00	U1	1.47	
Busll	66.000	102.16	102.38	105.45	1.06	,1.63	0.00	0.00	1.06	2.06	
Busll	11.000	102.36	101.38	105.45	Z.06	51.63	0.00	0.00	1.06	2.06	
Bm13	66.000	10M3	103.88	105.69	1.97	43.05	0.00	0.00	1.97	1.97	
Bu.25	11.000	103.53	103.55	105.69	1.97	4M8	0.00	0.00	1.91	J.97	
Bus7	66.000	101.39	101.41	103.91	1.88	46.11	0.00	0.00	1.88	1.88	
Bus.28	11.000	101.39	101.41	103.91	1.88	46.12	0.00	0.00	1.88	1.88	
Bu'29	11.000	101.39	101.41	103.91	1.88	46.1B	0.00	0.00	1.88	1.88	
Bu.30	66.000	101.07	101.09	103.82	1.86	52.81	0.00	0.00	1.86	1.86	
Bm31	66.000	10D.20	100.21	101.87	1.40	31.02	0.00	0.00	U1	1.41	
Bus32	11.000	101.07	101.09	103.82	1.86	52.81	0.00	0.00	1.86	1.86	
Bm33	11.000	10D.10	100.11	101.87	1.40	32.01	0.00	0.00	U1	1Al	
Bu.34	0.100	101.71	101.87	11SSS	5.56	266.09	0.00	0.00	586	5.56	
Bm35	0A00	101.11	101.75	107.60	1.50	1H.38	1.00	0.00	1.50	2.50	
Bus36	0.400	101.71	101.87	11SSS	5.56	266.09	0.00	0.00	5.56	5.56	
BuR7	0.100	101.71	101.87	11SSS	5.56	266.09	0.00	0.00	5.56	5.6	
Bm38	0.100	100.85	100.86	103.95	J.80	46.03	0.00	0.00	1SO	1SO	
Bu39	0.100	100.85	100.97	m.47	4.91	192.81	0.00	0.00	4.91	4.91	
Bus40	0.400	100.85	100.86	103.95	1.80	46.03	0.00	0.00	1SO	1.80	
Bus.41	11.000	1E1.1S	101.17	107.4?	2.69	152.51	0.00	0.00	2.69	2.69	
Bus.42	11.000	100.26	100.18	103.87	1.93	49.42	0.00	0.00	1.91	1.91	

#Industries THD a<1alHarmook:Distortion)G(aer rhr Unit.
#J'Jidig;tuIHD (Indi:ridualH3nnookDis.tortion)(xe>ds the Lim.it.

Project: MASTÈR THESIS
 Location: HOUN CITT' - LIBYA
 Connect: EAR EAST UNIVERSITY - El-E Department
 Engineer: S.A. IDA - ITSTAFIA AL-RIFAI
 Filename: HOIN SUBSTATION 220kV

ETAP
 12.6.0H

Page: 20
 Date: 28-06-2016
 SN:
 Revision: Bas
 Config: Nomnl

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Sy (in) Harmonics Branch Information

Bus	F1-omBu-ID	To Bu ID	Current Distortion									
			Fund.	RMS	ASh/M	nm	TIR	rr	MI	rrs	THID	TSID
Bus1	BUS1Z		67.09	67.13	71.92	3.70	98.60	6619.1	6619.1	0.00	0.00	0.00
	Bud3		2.51	2.61	3.76	27.98	1043.89	121.26	2W.26	0.00	0.00	0.00
	Bus27		48.65	45.69	49.33	4.34	197.18	9010.11	9010.11	0.00	0.00	4.34
	Bus8		0.52	0.54	0.71	27.13	984.55	m.29	s11.w	0.00	0.00	0.00
	BmS		(1.52	0.54	0.71	17.13	984.55	\$31.29	S31.19	0.00	0.00	0.00
	Bu30		1.04	1.08	1.54	17.23	991.11	1010.01	1070.0,	0.00	0.00	0.00
	Bu3		81.18	81.13	SUS	0.12	7.60	61MI	616-61	0.00	0.00	0.00
	Bu6		0	0	0	0	0	0.00	6!MI	0.00	0.00	0.00
Bus2	Bus11		50.74	50.75	S2.8S	1.69	42.14	2133.63	:2133.63	0.00	0.00	0.00
	Bus1t		2.29	2.29	1.88	18.83	466.01	10SJ.93	1083.93	0.00	0.00	0.00
	Bus1S		2.97	3.02	3.76	18.99	73.1	1430.-0	W.10	0.00	0.00	0.00
	Bu7		(1.52	0.53	MS	18.19	4SLS1	:237.6-1	237.6-1	0.00	0.00	0.00
	Bu7		0.2	0.51	0.65	18.49	452.59	237.64	m.64.	0.00	0.00	0.00
	Bus31		1.03	1.08	1.19	18.53	4-2Z!	m.02	.77.02	0.00	0.00	0.00
	Bu-S		81.11	81.11	S1.4S	0.19	8.61	441.11	441.11	0.00	0.00	0.39
BusJ	Bus1		U.34	24.34	24.44	0.32	7.60	184.98	18498	0.00	0.00	0.32
	Bus5		11..16	15.36	15.43	0.19	8.61	132.19	132.9	0.00	0.00	0.39
	B"6		0	0	0	0	0	0.00	132.39	0.00	0.00	0.00
	Bus7		0	0	0	0	0	0.00	131.39	0.00	0.00	0.00
	Busl		0	0	0	0	0	0.00	131.3~	0.00	0.00	0.00
	Bus9		0	0	0	0	0	0.00	132.39	0.00	0.00	0.00
B"8	Bus1		0	0	0	0	0	0.00	132.19	0.00	0.00	0.00
	Bu!		0	0	0	0	0	0.00	132.39	0.00	0.00	0.00
	Bus0		0	0	0	0	0	0.00	132.39	0.00	0.00	0.00
Bu11	Bw7		0	0	0	0	0	0.00	132.39	0.00	0.00	0.00
	Busb		0	0	0	0	0	0.00	131.39	0.00	0.00	0.00
	Bu11		S0.79	50.80	SL35	1.58	41.SS	Il:27.24	2117.1s	0.00	0.00	1.58
	Bns4l		50.19	50.80	SZJS	1.88	41.88	IU7.U	2117.U	0.00	0.00	1.58
	Bus12	Bud	67.14	67.19	"2.02	3.19	95.13	6'32.11	6432.11	0.00	0.00	3.79
	B"41		67.U	67.19	71.02	3.79	95.73	6432.11	6432.11	0.00	0.00	J.79
Bud3	Ihl1		0	0	0	0	0	0.00	6132.11	0.00	0.00	0.00
	Bud5		0	0	0	0	0	0.00	643.2.II	0.00	0.00	0.00
	Bud1	Ba-1	0	0	0	0	0	0.00	SE1.11	0.00	0.00	0.00
	Bud6		0	0	0	0	0	0.00	6-H.2.U	0.00	0.00	0.00
Bus15	Bu11		0	0	0	0	0	0.00	6132.11	0.00	0.00	0.00
	Bus16	Busu	0	0	0	0	0	0.00	6432.11	0.00	0.00	0.00
	Bus17	Bw17	0.264	12.68	45.77	M9	226.17	%51.15	%52.15	0.00	0.00	4.09
	Bu\$11		11.34	11.39	?US	7.01	n1.S1	8798.41	S798.111	0.00	0.00	7.01
	Bw13		21.30	21.31	ll.61	Z65	161.77	3441.68	3447.68	0.00	0.00	L65
	Bu\$19		0	0	0	0	0	0.00	3447.68	0.00	0.00	0.00

Prejer: JUSTER 11IES15
 Location: HOUN CITY -LIBYA
 Construc NEAR EAST UNIVERSITY -EEE Departmeut
 Engineer: SAID JUSTAYA AL-REYAI
 Filename: HOUN SUBSTATION220kV

ETAP

12.6.0H
 Study Case: HA
 Revison Base
 Config: Nominal

Page: 21
 Date: 28-06-2016
 SN:
 TSHD THDG THDS %
 THD THDS %


DESIGN OF A LARGE SCALE SOL.inPV SYSTEM AT THE LIBPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA > POW:RGRID

Bus	From Bus ID	To Bus ID	Fwd.	Rwd.	ASvhl	THD	Current Distortion			TSHD	THDG	THDS %
							TIF	IT	ITB	ITR		
Bus1	Bus1	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	0.00
	BUS20	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	0.00
Bus9	Bud7	0	0	0	0	0	0.00	0.00	0.00	0.00	0.00	0.00
Bu-20	But8	0	0	0	0	0	0.00	3.147.68	0.00	0.00	0.00	0.00
Bus11	Bud7	18.57	16.6!	11.U	6.94	399.58	7439.84	7439.84	0.00	0.00	0.00	6.94
	Bus13	18.57	18.6!	11.U	6.94	399.58	7439.84	7439.84	0.00	0.00	0.00	6.94
	But7	0	0	0	0	0	0.00	U9.84	0.00	0.00	0.00	0.00
Bus2?	Bns11	0	0	0	0	0	0.00	7439.84	0.00	0.00	0.00	0.00
Bus3	But7	M1	0.38	0.57	4660.62	2817.38	1068.16	1068.26	0.00	0.00	0.00	4660.62
	Bus1	0.01	0.38	0.57	4660.62	2847.38	1068.6	1068.26	0.00	0.00	0.00	4660.62
	Bus5	0	0	0	0	0	0.00	1068.26	0.00	0.00	0.00	0.00
Bus15	BUS23	0	0	0	0	0	0.00	106M6	0.00	0.00	0.00	0.00
Bus17	Bus17	44.61	11.65	45.ZI	4.30	213.40	9528.12	9528.12	0.00	0.00	0.00	4.30
	Bus1	44.61	11.65	48.ZI	4.30	213.40	9528.12	9528.12	0.00	0.00	0.00	4.30
	Bus3	0	0	0	0	0	0.00	9528.11	0.00	0.00	0.00	0.00
	Bus9	0	0	0	0	0	0.00	9528.11	0.00	0.00	0.00	0.00
Bus15	Bns17	0	0	0	0	0	0.00	9528.11	0.00	0.00	0.00	0.00
Bus9	Bus17	0	0	0	0	0	0.00	9528.11	0.00	0.00	0.00	0.00
Bus10	Bud	0	0	0	0	0	0.00	9528.11	0.00	0.00	0.00	0.00
	Bus3	0	0	0	0	0	0.00	9528.11	0.00	0.00	0.00	0.00
Bus11	Bus2	0	0	0	0	0	0.00	-IS.12	0.00	0.00	0.00	0.00
	Bus38	0	0	0	0	0	0.00	-IS.12	0.00	0.00	0.00	0.00
Bu-2	Bus10	0	0	0	0	0	0.00	9528.11	0.00	0.00	0.00	0.00
Bus33	Bus34	0	0	0	0	0	0.00	9528.11	0.00	0.00	0.00	0.00
Bus34	BuU	2169.58	2773.10	3041.73	S.11	129.85	160095.00	360095.00	0.00	0.00	0.00	S.11
Bus15	Bu41	2769.58	2169.59	2784.39	0.21	8.90	U636.1U	246.56.24	0.00	0.00	0.00	0.27
Bu-3	Bus11	1769.	273.10	3041.73	S.11	119.55	360095.00	360095.00	0.00	0.00	0.00	S.11
Bus12	Bus41	1169.55	1131.10	3041.73	S.11	129.85	160095.00	360095.00	0.00	0.00	0.00	S.11
Bus15	BuW1	11.55	11.35	1803.04	0.21	5.17	14430.55	W30.58	0.00	0.00	0.00	0.23
Bu19	Bus11	2793.38	2797.01	3070.48	5.11	131.97	371924.50	J71924.50	0.00	0.00	0.00	5.11
Bus40	BuW2	2793.38	2793.38	1861.01	0.23	5.17	U430.58	W30.58	0.00	0.00	0.00	0.23
Bu-11	Bus12	401S.1	401.14	m.10	3.79	95.73	38591.68	38591.68	0.00	0.00	0.00	3.79
	Bus34	100.71	100.84	NAS1	SU	U1>.85	13094.37	13094.37	0.00	0.00	0.00	S.11
	Bus15	100.71	100.71	101.25	0.27	8.90	896.59	896.59	0.00	0.00	0.00	0.17
	Bus36	100.11	100.84	11E.SI	S.11	129.85	13094.37	13094.37	0.00	0.00	0.00	5.11
	Bus37	100.71	100.84	NAS1	5.11	129.85	13094.37	13094.37	0.00	0.00	0.00	S.11
Bu-12	Bud1	304.73	304.77	314.11	1.58	41.88	12763.43	12763.43	0.00	0.00	0.00	1.58
	Bus38	101.53	101.58	101.93	0.13	5.17	574.15	SI4.75	0.00	0.00	0.00	0.23
	Bm9	101.58	101.71	111.65	5.11	132.97	13524.53	1383.51	0.00	0.00	0.00	5.11
	Bus10	101.58	101.58	101.93	0.23	5.17	SI4.75	54.75	0.00	0.00	0.00	0.23

Project: MASTER THESIS
 Location: HOUN CITY: LIBYA
 Contract: NEAR EAST UNIVERSITY • EEE Department
 Engineer: SAJID MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Page: 22
 Date: 28-06-2016
 5°N:
 Reratio: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM LOAD IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID



Project: -L\STER THESIS ETAP
 Location: HOUN CITY-LIBYA 12.6.0H
 Contract: EAR EAST UNIVERSITY EEE Department
 Engineer: SA'IDI -STAFAL AL-REF AL
 Filename: HOUN St'BSTA110N220kV Study Case: HA Page: 13 Date: 28-06-2010
 SN: Revision: Bas Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Tabulation

Ramouic Voltage (% of Fundamental Voltage)

Bus ID:	Bus16													
Fund.kV:	11.04													
Or-dtr	Freq.	Mng.	Ordtr	Freq.	-lag.	Or-dtr	Freq.	Mng.	Ordtr	Freq.	Mng.	Order	Freq.	Ifa.
--	-1.11	-1L	--	-1.11	-1L	--	-1.11	-1%	--	-1.11	-1L	--	-1.11	--
47.00	2350.00	0.01	49.00	240.00	0.00									
Bus JD:	Bus7													
Fund.kV:	61.06													
Or-dtr	Freq.	Ifa.	Ordtr	Freq.	-lag.	Or-dtr	Freq.	Ifa.	Ordtr	Freq.	Ifa.	Order	Freq.	Mng.
--	-1.11	-1L	--	-1.11	-1L	--	-1.11	-1%	--	-1.11	-1L	--	-1.11	--
11.00	550.00	0.01	13.00	650.00	1.97	23.00	1150.00	0.10	35.00	1250.00	0.08	37.00	1350.00	0.05
47.00	1350.00	0.01	49.00	240.00	0.01									
Bus ID:	Bus8													
Fund.kV:	66.14S													
Order	Freq.	Mng.	Order	Freq.	Mng.	Onitr	Frtq.	Ilg.	Order	Freq.	Mng.	Order	Frtq.	Mng.
--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%
11.00	550.00	0.00	13.00	650.00	1.97	23.00	1150.00	0.16	35.00	1250.00	0.03	37.00	1350.00	0.01
47.00	1350.00	0.01	49.00	240.00	0.01									
Bus JD:	Bus11													
Fund.kV:	11.218													
Order	Freq.	Mag.	Older	Freq.	-Lag.	Order	Faq.	Iflg.	Or-dtr	Freq.	Mag.	Order	Freq.	Mag.
--	-1.11	-1L	--	-1.11	-1L	--	-1.11	-1%	--	-1.11	-1L	--	-1.11	-1%
11.00	550.00	0.01	13.00	650.00	1.97	23.00	1150.00	0.10	35.00	1250.00	0.05	37.00	1350.00	0.05
47.00	1350.00	0.01	49.00	240.00	0.01									
Bus ID:	Bus1													
Fund.kV:	66.11S													
Order	Frtq.	Mng.	Order	Freq.	Ilg.	Order	Frtq.	Mng.	Or-dtr	Freq.	Ilg.	Order	Frtq.	Mng.
--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%
11.00	550.00	0.00	13.00	650.00	1.88	23.00	1150.00	0.13	35.00	1250.00	0.10	37.00	1350.00	0.01
47.00	1350.00	0.00	49.00	240.00	0.00									
Bus ID:	Bus20													
Fund.kV:	11.01S													
Order	Freq.	Mng.	Order	Freq.	Ilg.	Order	Freq.	Ilg.	Or-dtr	Freq.	Mng.	Order	Freq.	Ilg.
--	-1.11	-1L	--	-1.11	-1L	--	-1.11	-1%	--	-1.11	-1L	--	-1.11	-1%
11.00	550.00	0.00	13.00	650.00	1.45	23.00	1150.00	0.16	35.00	1250.00	0.03	37.00	1350.00	0.01
47.00	1350.00	0.01	49.00	240.00	0.01									
Bus ID:	Bw11													
Fund.kV:	67.55S													
Order	Freq.	Ilg.	Or-dtr	Freq.	Mng.	Order	Freq.	Ilg.	Or-dtr	Freq.	Ilg.	Order	Freq.	Mng.
--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%
11.00	550.00	0.01	13.00	650.00	1.95	23.00	1150.00	0.19	35.00	1250.00	0.10	37.00	1350.00	0.01
47.00	1350.00	0.01	49.00	240.00	0.00									
Bus ID:	Bru1													
Fund.kV:	11.759													
Order	Frtq.	Mng.	Order	Freq.	Mag.	Or-dtr	Frtq.	Ilg.	Or-dtr	Frtq.	Ilg.	Order	Frtq.	Ilg.
--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%	--	-1.11	-1%
11.00	550.00	0.00	13.00	650.00	1.78	23.00	1150.00	0.39	35.00	1250.00	0.00	37.00	1350.00	0.00
47.00	1350.00	0.00	49.00	240.00	0.00									

Project: iuster THESIS ETAP Page: 24
Location: HOUNCITY-LIBYA 12.MH Date: 28-06-2016
Country: NEAR EAST UNIVERSIT EEE Deparment S.I:
Engineer: SAJJAD MUSAF A AL-REFAI Study Case: HA Revitsten: Base
Filename: HOUN SUBSTATION 220kV Config: Normal

Bu Tabulation

Hall no:nic_V-1_Higes (% of Fundamental Voltage)

Bn. ID:	Busl3																
Fund. kV:	68.330																
Order	Freq.	Mag.	Order	Fftq.	Mag. %	Order	Fftq.	Mag. %	Order	Freq.	Mag. %	Order	Fftq.	Mag. %	Order	Fftq.	Afag. %
--	!!!	jL	--	13.00	~.00	1.91	2.10	nsaen	e.es	25.00	1250.00	aes	.is.00	11.00	1.00	15.00	0.00
11.00	550.00	0.01	13.00	6.00	1.91	2.10	n/a	naen	e.es	25.00	1250.00	aes	.is.00	11.00	1.00	15.00	0.00
17.00	2350.00	0.00	49.00	44.GLO	0.00	--	--	--	--	--	--	--	--	--	--	--	--
Bus ID:	Bm15																
Fund. kV:	11.ISS																
Order	fftq.	Mag.	Order	Fftq.	Mag.	Order	fftq.	Mag.	Order	Freq.	Mag.	Order	Fftq.	Mag.	Order	Freq.	Mag.
--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%
11.00	550.00	MI	13.00	650.00	1\$7	25.00	1150.00	0.08	25.00	m0.00	0.08	35.00	1750.00	jL	0.00	11.00	isse.cu
47.00	1180.00	0.10	49.00	14S0.00	0.00	--	--	--	--	--	--	--	--	--	--	--	--
Bus ID:	Bus27																
Fund. kV:	66.919																
--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%
11.00	550.00	0.02	13.00	~.00	1.84	23.00	1150.00	0.17	25.00	1250.00	0.31	35.00	1750.00	0.05	31.00	1850.00	0.03
47.00	2350.00	0.01	49.00	1.180.00	0.01	--	--	--	--	--	--	--	--	--	--	--	--
Bus ID:	Bus8																
Fund. kV:	11.m																
--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%
11.00	550.00	0.01	13.00	6.50.00	1.54	23.00	1150.00	0.17	25.00	m0.00	0.32	35.00	1750.00	0.0,	31.or	1850.00	0.03
47.00	m0.00	0.01	49.00	2450.00	0.01	--	--	--	--	--	--	--	--	--	--	--	--
Bus ID:	Busl9																
Fund. kV:	11.ISS																
--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%
11.00	550.00	0.0?	IM0	650.00	1.54	23.00	1150.00	0.11	1.00	m0.00	0.32	35.00	17.00.00	0.05	31.00	14130.00	0.03
47.00	2350.00	0.02	49.00	2450.00	0.01	--	--	--	--	--	--	--	--	--	--	--	--
Bus ID:	Bw3																
Fund. kV:	120.000																
Order	Freq.	Mag.	Order	Ftnq.	Mag.	Order	Freq.	Mag.	Or'dtr	Frtq.	tg.	Ordu	Ftnq.	Afag.	Ordr	Frtq.	Il.g.
--	!!!	jL	--	!!!	~	--	!!!	~	--	!!!	jL	--	!!!	jL	--	!!!	~
11.00	550.00	0.02	13.00	1.80	~.00	1.69	23.00	m0.00	0.30	25.00	m0.00	0.49	35.00	17.00	0.01	37.00	1850.00
47.00	2150.00	0.01	49.00	24.50.00	0.02	--	--	--	--	--	--	--	--	--	--	--	--
BmID:	Bus30																
Fund. kV:	66.707																
--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%
11.00	550.00	0.0?	13.00	~.00	1.76	1J.00	1150.00	0.31	15.00	1250.00	0.52	35.00	17S0.00	0.05	37.00	1850.00	0.00
17.00	2350.00	MI	19.00	U;0.00	0.01	--	--	--	--	--	--	--	--	--	--	--	--
Bu..ID:	Bus11																
Fund.kV:	66.130																
--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%	--	Hz	%
11.00	550.00	0.00	13.00	6.0'0.00	1.39	23.00	1150.00	0.u	25.00	m0.00	0.10	35.00	17S0.00	0.01	37.00	1850.00	0.01

Project: ~M.STER THE1,1S ETAP Page: 25
 Location: HOUNCIY-LIBYA 12.6.0H Date: 28-06-2016
 Contract: NEAR EA.5T UNIVERSIY - Ee: Department SN:
 Engineer: SA\(\D{?}\)USTAFAAL-REFAI Re:ision: Base
 Filename: HOUNI SUBSTATION220KV Config: Nonna!

DE.SIGN OF A LARGE SCALESOLARPV SYSTEM \(\D{?}\)D nIPACT ANALYSIS OF ITS INTEGR-TIQNJI, TO LIBYA." POWER & RID

BUS Tabulation

Hannonic Volages (% ofFundamental Voltage)

BusID:	Bus31	Fund. kV:	66.130	Order	Frtq.	ifag.	Ordtr	Freq.	Mag.	Ordtr	Frtq.	Abg.	Ordtr	Freq.	Mag.	Ordtr	Feeq.	ifag.	Order	Frtq.	Mng.	
				---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---		
				47.00	1350.00	aee	49.00	z.150.00	0.00	47.00	1350.00	0.00	47.00	1350.00	0.00	47.00	1350.00	0.00	47.00	1350.00	0.00	
BusID:	Bus32	Fund. kV:	11.118	Order	Frtq.	Mag.	Order	Freq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	
				11.00	550.00	0.01	13.00	~.00	1.76	z.1.00	m0.00	0.32	25.00	m0.00	0.82	35.00	1750.00	0.05	37.00	1850.00	0.00	
				47.00	ZSS0.00	-0.03	49.00	1450.00	0.07													
BusID:	Bw3	Fund. kV:	11.0H	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	
				11.00	SS0.00	0.00	13.00	650.00	1.19	23.00	mso.00	0.14	IS0.00	U50.00	0.10	35.00	1750.00	0.02	37.00	mo.00	0.01	
				47.00	1350.00	-0.00	49.00	2451.00	0.00													
BusID:	Bu..1.1	Fund. kV:	0.407	Order	Freq.	Mag.	Order	Frtq.	Mng.	Order	Frtq.	Mat.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mng.	
				11.00	550.00	3.18	13.00	650.00	IS0	23.00	mo.00	2.11	18.00	1250.00	2.6J	SS0.00	1150.00	1.21	n.00	mo.00	1.00	
				47.00	2350.00	0.46	49.00	2450.00	o.s0													
BusID:	Bu..35	Fund. kV:	0.407	Order	Freq.	Mag.	Order	Frtq.	Mng.	Order	Frtq.	Avg.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mng.	
				11.00	550.00	1.42	18.00	~.00	0.54	23.00	1150.00	1.10	25.00	12:50.00	1.36	35.00	1750.00	0.45	37.00	1850.00	0.J?	
				47.00	mo.00	0.16	49.00	2.1so.00	0.17													
BusID:	Bu..36	Fund. kV:	0.407	Order	Freq.	ifag.	Ordtr	Freq.	Mng.	Ordtr	frtq.	ALig.	Onkr	Frtq.	llag.	Ordtr	Freq.	ALig.	Ordtr	Freq.	Mng.	
				11.00	550.00	3.18	13.00	~.00	1.90	z.1.00	1150.00	1.71	?2.00	1150.00	1.63	16.00	1750.00	1.21	37.00	1850.00	1.00	
				47.00	2350.00	0.46	49.00	2450.00	o.s0													
BusID:	Bus37	Fund. kV:	0.407	Order	Freq.	Mag.	Order	Frtq.	Mng.	Order	Frtq.	ifat.	Oul-r	fifq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mng.	
				11.00	550.00	J.18	18.00	6.00	1.90	z.1.00	1150.00	2.11	?too	11.50.00	1.63	35.00	1750.00	1.11	37.00	mo.00	1.00	
				47.00	z.150.00	M6	49.00	2450.00	0.50													
BusID:	Bus38	Fund. kV:	D.403	Order	Freq.	Mag.	Order	Frtq.	Mng.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mag.	Order	Frtq.	Mng.	
				11.00	550.00	0.49	B.00	650.00	IS	z.1.00	1150.00	0.15	2.00	1250.00	0.2	11.50.00	1.63	35.00	1750.00	1.11	37.00	1850.00
				47.00	2.00.00	0.06	49.00	2450.00	0.06													

Project: iLISTER THESIS ETAP Page: 26
Location: HOUN CITY -LIBYA 12.6.0H Date: 28-06-2016
Contract: NEAR EAST UNIVERSITY - EEE Department SN:
Engineer: SAND MUSTAFA AL-REFAI Relisious Base
Filename: HOUN SU:STATION220kV StudyC5: HA Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Tahnfation

Haumouk Voltages(% off Widamntal Voltage)

Project: iLL4.STER THESIS ETAP
 Location: HOON CITY-LIBYA 12.6.0H
 Contrat: NEAREASTUNIVERSITY-EEID-portiontnt
 Engineer: SAND MUSLFA AL-REF AI StudyCase: HA
 Filename: HOUN SUB-TATION 220kV
 Page: 27
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEMAID IMPACT ANALYSIS OF ITS INTEGRATION INTO UBYAN POWER GRID

Bus Tabulation

Hannonic Voltage S (% of Fundamental Voltage)

Bus-ID:	BusS	Fund. kV:	66.706	Order:	Freq.	Mag.	Ordet:	Freq.	Mag.	Ordet:	Freq.	Mag.	Ordet:	Freq.	Mag.	Ordet:	Freq.	Mag.	Ordet:	Freq.	Mag.	Ordet:	Freq.	Mag.
11.00	550.00	0.02	1.00	650.00	~	1.1s	2.00	1150.00	0.31	25.01	11.~00	0.51	35.00	1750.00	0.05	37.00	1850.00	0.00	47.00	100.00	0.03	49.00	1450.00	0.01
BusID:	Bu.9	Fund.kV:	11.011																					
11.00	550.00	0.00	13.00	150.00	1.39	23.00	1150.00	0.01	2.00	1250.00	0.01	3.00	1750.00	0.01	37.00	1850.00	0.01	J1.00	100.00	0.00	19.00	150.00	0.00	

Project: ~USTER THESIS
 Location: HOUN crvv -LIBYA
 Contract: I'EAR EAST UNIVERSITY .EEE, Department
 Engineer: SA'1) MUSTAF'A AL-REF'AI
 Filename: HOUN Str/BSTATION 220kV

ETAP
12.6.0H

Page: IS
 Date: 28-06-2016
 SN:
 Retion: Base
 Onfig: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM IMPACT ANALYSIS OF ITS INTEGRATION LIBYAN POWER GRID

Bus Tabulation

Harmonics Voltages (% of Nominal Voltage)

Bus ID: Bus1		Harmonics Voltages (% of Nominal Voltage)																				
Nom. kV:	66.000	Order	Freq. Hz	Mag. %	Ordr	Frtq. Hz	Mag. %	Ordr	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Ordr	Freq. Hz	Mag. %	Ordr	Freq. Hz	Mag. %	Ordr	Freq. Hz	Mag. %
		11.00	550.00	0.02	1J.00	~.00	1.77	11.00	1150.00	0.32	25.00	1150.00	0.01	35.00	1750.00	0.08	37.00	1850.00	0.00			
		47.00	1150.00	0.03	49.00	2450.00	0.0?															
Bus ID: Bu10																						
Nom. kV:	11.000	Order	Freq. Hz	Mag. %	Ordr	Frtq. Hz	Ifag. %	Ordr	Freq. Hz	:Ung. %	Order	Freq. Hz	Mag. %	Ordr	Freq. Hz	Ibg.	Order	Freq. Hz	Mag. %			
		1L~~	11.00	550.00	0.01	13.00	650.00	1.77	11.00	1150.00	0.32	25.00	1150.00	0.01	35.00	1150.00	0.08	37.00	1850.00	0.00		
		47.00	mo.oo	0.01	49.00	2450.00	0.01															
Bus ID: Bu11																						
Nom. kV:	66.000	Order	Freq. Hz	Mag. %	ONltr	Freq. Hz	Ilg. %	Ordr	Freq. Hz	Alg. %	Order	Freq. Hz	~fag. %	Order	Freq. Hz	Ibg.	Order	Freq. Hz	Atg.			
		11.00	550.00	0.00	1J.00	650.00	1.39	11.00	1150.00	0.13	25.00	1250.00	0.10	35.00	1750.00	0.01	37.00	1850.00	0.01			
		47.00	2350.00	0.00	49.00	US0.00	0.00															
Bus ID: Bus12																						
Nom. kV:	66.000	Order	Freq. Hz	~lag. %	Ordr	Frtq. Hz	Mag. %Hi	ONl,r	Freq. Hz	Mng. %	Order	Freq. Hz	~J. %	Ordu	Freq. Hz	Abg.	Ord,r	Freq. Hz	Abg.			
		11.00	550.00	0.02	1J.00	U.00	650.00	!SJ	11.00	1150.00	0.32	25.00	1250.00	0.8B	35.00	1750.00	0.66	37.00	1850.00	0.00		
		47.00	2350.00	0.08	49.00	2450.00	0.04															
Bus ID: Bu13																						
Nom. kV:	66.000	Order	Freq. Hz	~lag. %	Ordr	Frtq. Hz	Mag. %Hi	ONl,r	Freq. Hz	Mng. %	Order	Freq. Hz	~J. %	Ordu	Freq. Hz	Abg.	Ord,r	Freq. Hz	Abg.			
		11.00	550.00	0.02	1J.00	U.00	650.00	!SJ	11.00	1150.00	0.32	25.00	1250.00	0.8B	35.00	1750.00	0.66	37.00	1850.00	0.00		
		47.00	2350.00	0.08	49.00	2450.00	0.04															
Bus ID: Bu14																						
Nom. kV:	66.000	Order	Freq. Hz	Ma.	Ordr	Frtq. Hz	Mag.	Or-dr	Freq. Hz	M.I.g.	Order	Freq. Hz	M.I.g.	Ortr	Frtq. Hz	Ibg.	Ordr	Frtq. Hz	Mng.			
		11.00	ssaoa	0.00	1J.00	6.00	0.44	1J.00	1150.00	0.18	25.00	1250.00	0.11	SSEE	1750.00	0.01	35.00	1850.00	0.02			
		47.00	mo.oo	0.01	49.00	2450.00	0.00															
Bus ID: Bus15																						
Nom. kV:	1.000	Order	Freq. Hz	Mag.	Or.r	Freq. Hz	Mag.	ONl,r	Freq. Hz	Iflag. %	Order	Freq. Hz	~g.	Ord,r	Freq. Hz	Alag.	ONfor	Freq. Hz	Mag.			
		11.00	ss.oo	0.02	1J.00	U.00	650.00	1.83	11.00	1150.00	0.35	25.00	1250.00	0.58	SJS.0	1750.00	0.06	37.00	1850.00	0.00		
		41.00	1350.00	0.05	49.00	mo.oo	0.04															

Project: MASTER THESIS
 Location: HOUN CITY-LIBYA
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engineer: SAJID MUSTAFA AL-REFAI
 Filename: HOIIN SUBSTATION 220KV

ETAP 12.6.0H
 Page: 29 Date: 28-06-2016
 SN: Rfdion: Base
 Study Case: HA Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND DIPACf ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Information

Barmonk Voltages (V°) <Nominal Voltage)

Bus ID: Bus6		Barmonk Voltages (V°) <Nominal Voltage)																		
Nom. kV:	11.000	Order	Freq.	%lag	Ordn	Frtq.	Mag.	Order	Frtq.	%lag	Ordntr	Frtq.	Mag.	Order	Freq.	Mag.	Order	Freq.	Mag.	
11.00	ssso.oo	0.00	13.00	650.00	11	650.00	0.01	23.00	1150.00	0.15	11.00	1150.00	0.11	35.00	mo.oo	0.03	37.00	1850.00	0.00	
47.00	2350.00	0.01	19.00	2450.00		0.00														
Bus ID: Bus7		Barmonk Voltages (V°) <Nominal Voltage)																		
Nom. kV:	66.000	Order	Freq.	%lag	Ordntr	Freq.	Mag.	Order	Freq.	%lag	Ordntr	Freq.	Mag.	Order	Freq.	%lag	Order	Freq.	Mag.	
11.00	\$50.00	0.01	13.00	650.00	11	650.00	0.01	23.00	1150.00	0.10	11.00	1150.00	0.05	35.00	1750.00	0.05	37.00	1850.00	0.08	
47.00	2350.00	0.01	49.00	Z180.00		0.01														
Bus ID: Bus8		Barmonk Voltages (V°) <Nominal Voltage)																		
Nom. kV:	66.000	Order	Freq.	%lag	Ordntr	Freq.	Mag.	Order	Freq.	%lag	Ordntr	Freq.	Mag.	Order	Freq.	%lag	Ordntr	Freq.	Mag.	
11.00	ssso.oo	0.00	13.00	650.00	11	650.00	0.16	11.00	1150.00	0.16	11.00	1150.00	0.11	35.00	11so.oo	0.01	11.00	1150.00	0.02	
47.00	2350.90	0.01	49.00	2450.00		0.01														
Bus ID: Bus9		Barmonk Voltages (V°) <Nominal Voltage)																		
Nom. kV:	11.000	Order	Freq.	%lag	Ordntr	Freq.	Mag.	Order	Freq.	%lag	Ordntr	Freq.	Mag.	Order	Freq.	%lag	Ordntr	Freq.	Mag.	
11.00	ssso.oo	0.01	13.00	650.00	11	650.00	0.01	23.00	1150.00	0.10	25.00	mo.oo	0.05	35.00	11so.oo	0.01	11.00	1150.00	0.05	
47.00	2350.00	0.01	49.00	Z450.00		0.01														
Bus ID: Bus2		Barmonk Voltages (V°) <Nominal Voltage)																		
Nom. kV:	66.000	Order	Freq.	%lag	Ordntr	Freq.	Mag.	Order	Freq.	%lag	Ordntr	Freq.	Mag.	Order	Freq.	%lag	Ordntr	Freq.	Mag.	
11.00	\$50.00	0.00	13.00	650.00	11	650.00	0.01	23.00	1150.00	0.14	11.00	1150.00	0.10	35.00	11so.oo	0.01	31.00	1150.00	0.01	
47.00	2350.00	0.01	49.00	Z450.00		0.01														
Bus ID: Bus20		Barmonk Voltages (V°) <Nominal Voltage)																		
Nom. kV:	11.000	Order	Frtq.	Hz	Mng.	Ordn	Freq.	Hz	Mng.	Order	Frtq.	Hz	Mng.	Ordn	Freq.	Hz	Mng.	Ordn	Freq.	Mng.
11.00	ss50.00	0.00	13.00	650.00	11	650.00	0.01	23.00	1150.00	0.16	21.00	1250.00	0.12	35.00	1750.00	0.03	37.00	1850.00	0.02	
47.00	2350.00	0.01	49.00	2450.00		0.01														
Bus ID: BusZ1		Barmonk Voltages (V°) <Nominal Voltage)																		
Nom. kV:	66.000	Order	Frtq.	Hz	Mng.	Ordntr	Freq.	Hz	Mng.	Order	Frtq.	Hz	Mng.	Ordntr	Freq.	Hz	Mng.	Ordntr	Freq.	Mng.
11.00	ss50.00	0.01	11.00	650.00	11	650.00	0.01	25.00	1150.00	0.40	25.00	1150.00	0.31	35.00	1750.00	0.05	37.00	1850.00	0.07	
47.00	2350.00	0.01	49.00	2450.00		0.01														

Project: MASTER THESIS
 Location: HOUN CIIT -LIBYA
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engineer: S.A.D.i.uSTAFA AL-REFAI
 Filename: HOUNSUBSTATION 220kV

ETAP
 12.6.0H
 Page: 30
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A URGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA's POWER GRID

Bus Tahsilat

Harmonic Voltages (0.01% of Nominal Voltage)

Bus ID:		Bus22		Nom. kV:		11.000		Order		Freq. Hz		Mag. %		Order		Freq. Hz		Mag. %		Order		Freq. Hz		Mag. %		Order		Freq. Hz		Mag. %		Order		Freq. Hz		Mag. %		Order		Freq. Hz		Mag. %	
11.00		550.00		0.01		13.00		650.00		1.99		23.00		1150.00		0.40		15.00		1250.00		0.52		35.00		1750.00		0.09		37.00		1850.00		0.07									
47.00		2350.00		0.01		49.00		2456.00		0.00																																	
Bus ID:		Bus23		Nom. kV:		16.000																																					
11.00		550.00		0.01		13.00		650.00		2.04		23.00		mo.oo		0.05		25.00		1250.00		0.05		35.00		mo.oo		0.00		37.00		1850.00		0.00									
47.00		2350.00		0.00		49.00		2450.00		0.00																																	
Bus ID:		Bus25		Nom. kV:		11.000																																					
11.00		550.00		0.01		13.00		650.00		1.04		23.00		1150.00		0.05		15.00		1250.00		0.05		35.00		1750.00		0.00		37.00		1850.00		0.00									
47.00		2350.00		0.00		49.00		2450.00		0.00																																	
Bus ID:		Bus27		Nom. kV:		66.000																																					
11.00		550.00		0.01		13.00		650.00		1.87		23.00		1150.00		0.18		25.00		1250.00		0.11		35.00		1750.00		0.66		37.00		1850.00		0.03									
47.00		2350.00		0.07		4MO		2450.00		0.01																																	
Bus ID:		Bu.28		Nom. kV:		11.000																																					
11.00		S.S0.00		0.01		13.00		650.00		1.87		23.00		1150.00		0.18		25.00		1250.00		0.11		35.00		1750.00		0.06		37.00		1850.00		0.01									
47.00		HSS0.00		0.02		49.00		2450.00		0.01																																	
Bus ID:		Bus29		Nom. kV:		11.000																																					
11.00		550.00		0.01		13.00		650.00		1.87		23.00		1150.00		0.18		25.00		1250.00		0.33		35.00		1750.00		0.06		37.00		1850.00		0.03									
47.00		2350.00		0.01		49.00		2450.00		0.01																																	
Bus ID:		Bus3		Nom. kV:		220.000																																					
11.00		550.00		0.02		15.00		650.00		1.69		23.00		1150.00		0.30		15.00		1250.00		0.49		35.00		1760.00		MI		37.00		1850.00		0.00									
41.00		2350.00		0.03		49.00		2450.00		0.01																																	

Project: ~U.STER THESIS
 Location: HOUN CITY -LIBYA
 Comracc : NEAR EAST UNIVERSITY - EEE-Deparment
 Engineer: SAID MUSTAFA AL-REUI.
 Filename: HOUN SUBSTATION 220KV

ETAP
 U.6.0H
 Study Caw: HA
 Reisou: Base
 Config: Normal

Page: 31
 Date: 28-06-2016
 SN:
 DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION IN LIBYA POWERGRID

Bus ID: Bus30 Nom. kV: 66.000

Harmonic Voltages(% of Nominal Voltage)														
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
11.00	ssceee	0.01	13.00	650.00	1.78	23.00	1150.00	0.32	28.00	1250.00	0.52	33.00	1150.00	0.01
47.00	2350.00	0.03	49.00	1450.00	0.03							37.00	1850.00	0.00

Harmonic Voltages(% of Nominal Voltage)														
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
11.00	550.00	0.00	13.00	650.00	1.40	23.00	1150.00	0.14	28.00	1250.00	0.10	35.00	1750.00	0.02
47.00	2350.00	0.00	49.00	2450.00	0.00							37.00	1850.00	0.01

Harmonic Voltages(% of Nominal Voltage)														
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
11.00	550.00	0.01	13.00	650.00	1.18	23.00	1150.00	0.11	28.00	1250.00	0.11	35.00	1750.00	0.05
47.00	2350.00	0.03	49.00	1450.00	0.03							37.00	1850.00	0.00

Harmonic Voltages(% of Nominal Voltage)														
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
11.00	550.00	0.00	13.00	650.00	1.10	23.00	1150.00	0.04	28.00	1250.00	0.10	35.00	1750.00	0.05
47.00	2350.00	0.03	49.00	1450.00	0.03							37.00	1850.00	0.00

Harmonic Voltages(% of Nominal Voltage)														
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
11.00	550.00	0.00	13.00	650.00	1.10	23.00	1150.00	0.04	28.00	1250.00	0.10	35.00	1750.00	0.05
47.00	2350.00	0.03	49.00	1450.00	0.03							37.00	1850.00	0.00

Harmonic Voltages(% of Nominal Voltage)														
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
11.00	550.00	0.23	13.00	650.00	1.93	23.00	1150.00	0.16	28.00	1250.00	2.68	35.00	1750.00	1.23
47.00	2350.00	0.47	49.00	2450.00	0.51							37.00	1850.00	1.01

Harmonic Voltages(% of Nominal Voltage)														
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
11.00	550.00	0.32	13.00	650.00	0.54	23.00	1150.00	1.33	28.00	1250.00	1.38	35.00	1750.00	0.46
47.00	2350.00	0.16	49.00	2450.00	0.17							37.00	1850.00	0.39

Harmonic Voltages(% of Nominal Voltage)														
Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mag. %
11.00	550.00	0.11	13.00	650.00	1.93	23.00	1150.00	2.16	28.00	1250.00	1.68	35.00	1750.00	1.18
47.00	2350.00	0.47	49.00	2450.00	0.17							37.00	1850.00	1.01

Pag.: 32
Date: 28-06-2016
SN:
Rnisiou: Basti
Cu(g: Normal

DE-DESIGN OF A LARGE SCALE SOUR PV SYSTEM AT MID IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Bu Tabplation

Hanoouk Voltages(% of Nominal Voltage)

Bus ID:		Bus37																	
Nom. kV:		MOO																	
		Hi	%			Hz	%			Hz	%			Hi	%				
11.00	11.00	3.00	3.23	13.00	650.00	1.93	23.00	1150.00	1.16	18.00	mo.oo	1.68	3:00	1150.00	1.18	37.00	1850.00		
		1350.00	0A7	49.00	1,80.00	e.SI													
Bus ID:		Bus38																	
Nom. kV:		0.400																	
		Fr.tg	L	M.g.	Ordr	Freq.	M.g.	Ordr	Freq.	M.g.	Ordr	Freq.	M.g.	Ordr	Freq.	!fag.	Ordr	Freq.	
		2!				Hz			Hz			Hz			Hz			Hz	
11.00	11.00	550.00	0.80	IJ.00	650.00	1.70	23.00	1150.00	0.M	25.00	1250.00	0.28	35.00	1750.00	a1S	37.00	1850.00	0.13	
		1350.00	0.06	9.00	1,80.00	0.06													
Bus ID:		Jlm39																	
Nom. kV:		0.400																	
		Hz	%			Hz	%			Rt	%			Hz	%			Hz%	
11.00	11.00	550.00	2.31	13.00	650.00	s.n	23.00	1150.00	J.77	28.00	1250.00	1.64	35.00	1750.00	0.9	37.00	1850.00	0.77	
		mo.oo	0.38	49.00	2450.00	0.41													
Bus ID:		Bus4																	
Nom. kV:		220.000																	
		Hz	%			Hz	%			Rt	%			Hz	%			Hz%	
		Hz	%			Hz	%			Rt	%			Hz	%			Hz%	
Bu. ID:	Bus40																		
Nom. kV:		MOO																	
		Ordr	f"!L	M.g.	Ordr	Freq.	M.g.	Ordr	Freq.	M.g.	Ordr	Freq.	M.g.	Ordr	Freq.	f"!L	M.g.		
		Hz	Hz	%		Hz	%			Hz		Hz	%			Hz			
11.00	11.00	550.00	0.80	13.00	650.00	J.70	23.00	1150.00	0.16	15.00	1150.00	0.8	35.00	1750.00	e.1S	37.00	1850.00	0.13	
		mo.oo	0.06	49.00	2450.00	0.06													
Bus ID:		Bus41																	
Nom. kV:		11.000																	
		Order	Freq.	Mng.	Onltr	Ff!!L	Mag.	Ordr	Frtq.	If.ig.	Ordr	Frtq.	--	Ordr	Frtq.	2!	Mng.		
		Rt	%		2!	-L				~			--		2!	-L			
11.00	11.00	2.00	1.81	13.00	650.00	0.83	23.00	1150.00	25.00	1750.00	35.00	1750.00	0.49	37.00	1850.00	1.81	0.41		
		2350.00	0.17	49.00	2450.00	0.19													
Bu. ID:	Bus42																		
Nom. kV:		11.000																	
		Order	Freq.	Mng.	Ordr	Freq.	Ma.	Ordr	Frtq.	Itng.	Ordr	Frtq.	M-g.	Ordr	Frtq.	-2!	Mng.		
		1h	Hz	%		Hz	,6		Hz	%		Hz	%		Hz	-L			
11.00	11.00	\$50.00	0.53	13.00	650.00	1.81	23.00	1150.00	0.17	15.00	1250.00	0.??	35.00	1750.00	0.16	37.00	1850.00	0.13	
		1350.00	0.06	9.00	2.550.00	0.07													
Bu. ID:	BusS																		
Nom. kV:		220.000																	
		Hz	%			Hz	%			Rt	%			Hz	%			Hz%	
11.00	11.00	550.00	0.00	U.00	650.00	1.33	23.00	mo.00	0.13	15.00	mo.00	0.09	35.00	1750.00	O.01	37.00	1850.00	0.01	

Project: MASTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAR EAST UNIT EEE Department
 Engineer: SAND JUST AIA ALREFAI
 Filename: HOUN-SUBSTATION 220KV

ETAP
 12.6.0H
 Study Case: HA

Page: 33
 Date: 28-06-2016
 SN:
 Relision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Bus Tabnlation

Bus ID:	Buss	Barometric	Voltages (0% of Nominal Voltage)														
	Nom. kV: 220.000																
Order	Freq. Hz	Mag. %	Order	Freq. Hz	!fag. %	Ord,r	Freq. Hz	!ag. %	Order	Freq. Hz	!fag. %	Ordtr	Freq. Hz	JUg. %	Order	Freq. Hz%	!fag.
41.00	2350.00	0.00	4-.00	2450.00	0.00												
Bus ID:	Bus6																
	Nom. KV: 11.000																
11.00	550.00	0.01	13.00	150.00	1.77	23.00	1150.00	0.32	15.00	1250.00	0.51	3.00	1150.00	0.65	37.00	1850.00	0.00
47.00	2350.00	0.03	49.00	2450.00	(up?)												
Bus ID:	Bus7																
	Nom. kV: 66.000																
Order	Freq. Hz	M-ag. %	Order	Freq. Hz	Mtg. %	Order	Freq. Hz	!ng. %	Order	Freq. Hz	Mag. %	Ordtr	Freq. Hz	!bg. %	Order	Freq. Hz	hing. %
11.00	550.00	0.00	13.00	~.00	1.88	23.00	1150.00	0.14	25.00	1250.00	0.10	35.00	1750.00	0.02	37.00	1850.00	0.01
47.00	2350.00	0.00	49.00	2450.00	0.00												
Bus ID:	Bus11																
	Nom. kV: 66.00-																
Order	Freq. Hz	Mag. %	Or&r	Freq. Hz	!fag. ss	Orotr	Freq. Hz	!fag. %	Order	Freq. Hz	M-ag. %	Ordn	Freq. Hz	Mag. %	Order	Freq. Hz	!fag. %
11.00	55.00	0.07	13.00	~.00	1.71	23.00	1150.00	0.31	25.00	1250.00	0.51	35.00	1750.00	0.05	37.00	1850.00	0.00
47.00	2350.00	0.03	49.00	2450.00	0.0!												
Bus ID:	Bus9																
	Nom. KV: 11.00																
Order	Freq. Hz	Ung. %	Order	Freq. Hz	Mag. %	Order	Freq. Hz	Mng. %	Order	Freq. Hz	?fag. %	Ordtr	Freq. Hz	Mtg. %	Order	Freq. Hz%	Mng.
11.00	55.00	0.00	13.00	65.00	1.39	23.00	1150.00	0.14	25.00	1250.00	0.10	35.00	1750.00	0.01	37.00	1850.00	0.01
47.00	2350.00	0.00	49.00	2450.00	0.00												

Project: AIASTER I.M.S.I.S
 Location: HOUN Cin' - LiliYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAJID IlfiSTAFA AL-REF AI
 Filename: HOUN SUBSTATION 220kV

ETAP

Page: 34
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AT IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Filter Overloading

Filter-ID	T1L	Conu0-riou	Capacitor C1			Inductor L1			Capacitor C2			Inductor L2		
			hfa ^a , kY	Opr, kV	%	Ibx, Amp	Opr, Amp	%	hLis, kY	Opr, kV	%	Mnx, Amp	Opr, ~	%
ID1	3	Wyt	100,000	64.674	6.17	100.00	1.31	2.3						
HF2	3	Wye	100,000	57.193	57.1	100.00	4.12	4.1						

Filter-TypII: O=By-P-, 1=High-Pav; (D=tnpt-d), 2=High-P:m (Unchmped), 3= Singl Taud, 4=>J'd Ordu Damped, 5.. 3rd Ordtr C-Type

Project: I'USTER THESIS
Location: HOUN CITY- LIBYA
 Conti-act: NEAR EAST UNIVERSITY- EEE Department
 Engineer: SANDIIFI STAF ARIREFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: HA

Page: 35
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nonnal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM!A!IDIMPACT ANUYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Alert Summary Report

% Alert Settings

Critical Marginal

IndMdual Bus VTBD / VJHD values are used.

<u>Transformer-</u>			
Total	100.0		9M
<u>Filter</u>			
Capadior kV	100.0		98.0
Inductor Amp	100.0		9M
<u>Capacitor</u>			
Illax kV	100.0		98.0
<u>Cable</u>			
Ampadty	100.0		95.0

APPENDIX 12

TRANSIENT STABILITY ANALYSIS WITHOUT PV

Project:	IIFASTER THESIS	ETAP	Page:	1
Location:	HOUN CITY -LIBYA	12.6.0H	Date:	28-06-2016
Contract:	NEAREASTUNIVERSITY-EEE Department		SN:	
Engineer:	SANDJIUSTAFA AL-REHJ	Study Case:	TS	Redsiou: Base
Filename:	HOUN SUBSTATION220kV			Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND its IPACI ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Electrka1 Transient Analysis Program

Transient Stability Analysis (Without PV)

Initial Loading Category (1): Design

Initial Generation Category (1): Design

Load Diversity Factor: None

Number of Buses:	String	V-Conn-ol	Load	Total				
	3	0	19	42				
Number of Branches	XFMR2	TFMR3	Reactor	Line/Cable				
	26	0	0	16				
Number of Machines	&urhrmnoid-Generator	Power Grid	Synchronous Motor	Induction Machines	Lumped Load	Tie PD	SPDI	Total
	0	3	0	0	U	10	0	52

Method of the Initial LF Solution: Adaptive Neillou-Raphson

Maximum Number of Iterations: 1000

Solution Precision for the Initial LF: 0.000100000

Acceleration Factor for the Initial LF: 0.00

Time Increment for Integration Steps (At): 0.0010

Time Increment for Plots: 20 times At

System Frequency: 50.00Hz

Frequency Dependent Models for Machines and Network are Not Used

Unit System: Meck

Project: MASTER THESIS

ETAP

Page: 2

Location: HOUN CITY -LIBYA

12.6.0H

Date: 28-06-2016

Contract: NEAR EAST UNIVERSITY• EEE Department

SN:

Engineer: SAND [f]STAFAA AL-REFAI

Revision: Base

Ellenajae: HOUN SUBSTATION 220KV

Revision: Base
Config: Nonnal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AL ID LI PACI AI U YSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Adjustments

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer Impedance:	Yts	hdMdual	
Reactor Impedance:	Yes	hdhdidual	
Overload Heater Resistance:	No		
Transmission Line Length:	No		
Cable Length:	No		

Temperature Correction	Apply Adjustments	Individual /Global
Transmission Line Resistance:	Yes	hdMdual
Cable Resistance:	Yes	hdhdidual

Project: ILASTER THESIS
 Location: HOUN CTIY - LIBYA
 Contr'act: NEAR EAST UIVERSITY -EEE Department
 Engineer: SAND ~WSTAF A AL-REFAI
 Filename: HOUN SUBSTATION 220KV

ETAP

Page: 3
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Bus Input Data

Bus	ID	kV	Sub-sys	Initial Voltage		Constant kVA		Con. trnZ		Const; mtl		Gnttic	
				%ligr.	Ang.	MW	lh-ar	MW	Afrnr	MW	lh-tr	MW	lh-fr
Bud		65.000	I	99.1	-5.1								
Bus1		65.000	I	98.9	-1.9								
Bus2		210.000	I	100.0	0.0								
Bm4		220.000	I	100.0	0.0								
Bus5		210.000	I	100.0	0.0								
Busi		11.000	I	98.1	-8.1	0.000	0.995	0.000	0.249				
Bns7		66.000	I	98.5	-1.9								
Bu-a		65.000	I	99.0	-5.1								
Bus9		11.000	I	98.1	-2.5	0.00	0.991	0.100	0.148				
Bus 0		11.000	I	97.5	-1.2	5.600	3.471	1.400	0.868				
Bud1		66.000	I	99.1	-1.2								
Bud1		65.000	I	99.4	-1.1								
BusJ		65.000	I	98.5	-M								
Bus4		66.000	I	98.0	-1A								
BusIS		11.000	I	98.1	-5.5	4.800	2.915	1.200	0.744				
Bud6		11.000	I	98.3	-SA	4.800	1.975	1.100	0.744				
Bus17		66.000	I	98.9	-S								
Busts		66.000	I	98.5	-1~								
Bm19		11.000	I	98.7	-4.4	4.400	0.000	1.100	0.000				
BusIO		11.000	I	98.7	-3.3	1.800	0.000	0.700	0.000				
Bus21		65.000	I	98.9	-7.5								
BusZl		11.000	I	98.4	-10.4	4.800	0.000	1.200	0.000				
Bd8		66.000	I	99.3	-7.9								
Bus24		65.000	I	100.0	0.0								
Bus2-		11.000	I	98.1	-5.8	1.600	0.991	0.400	0.248				
Bus26		11.000	I	100.0	0.0	4.000	1.419	1.000	0.610				
But27		66.000	I	98.8	-5.8								
Bu.28		11.000	I	98.4	-6.7	2.400	1.481	0.600	0.12				
Bu.29		11.000	I	98.4	-5.7	2.400	1.487	0.600	0.37				
Bu.JO		66.000	I	98.5	-SS								
Bu.31		65.000	I	98.6	-Z.1								
8ui31		11.000	I	98.0	-5.7	8.800	5.455	1.200	1.561				
Bi"33		11.000	I	100~	J.5	4.000	1.m	1.000	0.610				
Bus.).&		MOO	I	100.0	I.I								

Project: MASTER THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAR EAST LIBYAN POWER GRID
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SHI STATION 220kV

ETAP
 12.6.0H
 Page: 4
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus	ID	kV	Sub-sys	Initial Voltage	% Mag.	Avg.	Load					
							Constant VA		Comm/Z		Constant I	
							MW	Mvar	MW	Mvar	MW	Mvar
Bus3		MOO	1	100.0	1.1							
Bus36		0.100	1	100.0	1.1							
Bus17		MOO	1	100.0	1.1							
Bus18		0.400	1	100.0	3.3							
Bus19		MOO	1	100.0	3.1							
Bus10		0.100	1	100.0	3.3							
Bus41		11.000	1	98.9	1.2							
Bm13		11.000	1	98.6	1.0							
Total Number of Buses: 42							11.999	25.785	13.000	6.446	0.000	0.000
Note: Dynamically modeled motor loads are not included in the bus motor load. See much larger motor load report for details.												

GeneratorBus	ID	kV	Type	Voltage		Generation			Var Limits	
				MW	Mvar	% PF	Max	Min		
Bus3		210.000	Syncing	1	100.0	M				
Bus4		210.000	Swing	1	100.0	0.0				
Bm5		120.000	Syncing	1	100.0	0.0				
							0.000	0.000		

Project: MASTER THESIS
 Location: HOUN CITY LIBYA
 Contrmtr: NEAR EAST UNITER.5ITY • EEE Department
 Engin ee.: SAND INISR.U'A AL-REF AI
 Filename: HOUN SUBSTATION 21OKV

ETAP
 12.6.0H
 Study Case: TS

Page: 5
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A URGE SCALE SOUR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

Line/Cable Input Data

Line/Cable	JD	Ubmy	Siu	Ohms or Siemens per 10-00 m per Conductor (Cable) or per Phase (Line)								
				L<ngth	Adj.(m)	%Tol.	#IPhi.s.t	T (°C)	R1	X1	V1	R0
Cable1		HMCUSS3			100.0	0.0	1	75	0.076302	0.087400	0.0001646	0.240351
Cable1		HMCUSS3			100.0	0.0	1	75	0.076303	0.087400	0.0001046	0.140351
Lind			m00.0		0.0	1	15	0.056003	0.374255	0.0000031	0.200077	1.360791
Line2		ff1	19300.0		0.0	1	75	0.056001	0.342069	0.0000034	0.200637	1.424041
LineJ		ff1	13000.0		0.0	1	75	0.056001	0.342062	0.0000034	0.200637	1.424041
LineI		ff1	18000.0		0.0	1	75	0.056001	0.342069	0.0000034	0.200m	1.424041
LineS		ff1	8000.0		0.0	1	75	0.056001	0.342069	0.0000034	0.200617	1.424041
Line6		ff1	4000.0		0.0	1	75	0.056001	0.342069	0.0000034	0.200657	1.424041
Line7		ff1	4000.0		0.0	1	15	0.056001	0.342069	0.0000034	0.200637	1.424041
Line8		ff1	4000.0		0.0	1	75	0.056001	0.1.12019	0.0000034	0.100637	1.424041
Line9		ff1	4000.0		0.0	1	75	0.056001	0.341069	0.0000034	0.100637	1.414041
Line10		ff1	8000.0		0.0	1	75	0.056001	0.341069	0.0000034	0.100637	1.424041
Line11		ff1	8000.0		0.0	1	75	0.056001	0.341062	0.0000034	0.100637	1.424041
Line12		ff1	21000.0		0.0	1	75	0.056001	0.341061	0.0000034	0.100637	1.424041
Line13		ff1	161000.0		0.0	1	75	0.056001	0.342062	0.0000034	0.100637	1.424041
Line14		ff1	140000.0		0.0	1	75	0.056001	0.341062	0.0000034	0.100637	1.414041

Line- / Cable- resistances are listed at the specified temperatures.

Project: -L'ESTER THESIS
 Location: HOUN CITY -LIBYA
 Contractor: THE EAST UNIVERSITY-Egypt Department
 Engineer: SAND MUSTAFA AL-REFAI
 filename: HOUN STATION210kV

ETAP
 12.6.0H
 Page: 6
 Date: 28-06-2016
 SN:
 Revisions: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

2- Vinding Transfonner Input Data

Transfonner	ID	Rating			Z Variation			%Tap Setting		Adju,sted		Phase Shift		
		MVA	Prim.V	Sn.kV	%Z	XIR	+5%	-5%	%Tol.	Prim.	see.	%Z	Typ,	Ang!
T1		63.000	220.000	66.000	11.5%	45.00	0	0	0	0	3.750	11.5%	Dyn	0.000
T1		63.000	110.000	66.000	12.5%	45.00	0	0	0	0	0.625	11.5%	Dyn	0.000
TJ		63.000	110.000	66.000	12.5%	45.00	0	0	0	0	0.625	11.5%	Dyn	0.000
T4		10.000	66.000	11.000	MS	13.00	0	0	0	0	0	8.3300	Dyn	0.000
TS		10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	Dyn	0.000
T6		10.000	66.000	11.000	10.00	20.00	0	0	0	0	1.1150	10.0000	Dyn	0.000
T1		11.500	11.000	66.000	8.33	13.00	0	0	0	1.1150	0	8.3300	VNd	0.000
TS		11.500	11.000	66.000	8.33	13.00	0	0	0	1.1150	0	8.3300	VNd	0.000
T9		10.000	66.000	11.000	8.33	13.00	0	0	0	0	4.375	8.3300	Dyn	0.000
NO		10.000	66.000	11.000	8.33	13.00	0	0	0	0	4.375	8.3300	Dyn	0.000
TII		10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	Dyn	0.000
T12		10.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	Dyn	0.000
TU		10.000	66.000	11.000	8.33	13.00	0	0	0	0	0	8.3300	VNd	0.000
T14		10.000	66.000	11.000	8.33	13.00	0	0	0	0	0	8.3300	VNd	0.000
TIS		10.000	66.000	11.000	8.33	16.00	0	0	0	0	3.750	8.3300	Dyn	0.000
T16		20.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	VNd	0.000
T17		20.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	Dyn	0.000
TIS		10.000	66.000	11.000	10.00	20.00	0	0	0	0	3.750	10.0000	VNd	0.000
T19		10.000	66.000	11.000	10.00	20.00	0	0	0	0	3.750	10.0000	Dyn	0.000
TIO		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.1500	VNd	0.000
rn		1.000	0.400	11.000	6.15	6.00	0	0	0	0	0	6.1500	VNd	0.000
rn		1.000	0.400	11.000	6.15	6.00	0	0	0	0	0	6.2500	VNd	0.000
UJ		1.000	0.400	11.000	6.15	6.00	0	0	0	0	0	6.1500	VNd	0.000
TLS		1.000	0.400	11.000	6.15	6.00	0	0	0	0	0	6.2500	VNd	0.000
us		1.000	0.400	11.000	6.15	6.00	0	0	0	0	0	6.2500	VNd	0.000
T26		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.2500	VNd	0.000

2- Vinding Transformer Grounding Input Data

Transformer	ID	Rating			Primary			Secondary			Grounding		
		MVA	Prim. kV	Sec. kV	T-Pf	T-Pt	kV	Amp	Ohm	Twr	kV	Amp	Ohm
T1		63.000	110.000	66.000	11/Y					S.Ud			
T1		~.000	110.000	66.000	11/Y					S.Cld			

Project: MASTER THESIS ETAP Page: 7
 Location: HOUN CITY LIBYA 12.6.0H Date: 28-06-2016
 Contract: NEAR EAST UNIVERSITY EEE Department SN:
 Engineer: SAJID MUSTAFA AL-REFAI Re.ion: Base
 Filename: HOUN SUBSTATION 220KV StudyCase: TS Config: Normal

DESIGN OF A LARGESCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

2-Viewing True former Grouping Input Data

Transformer	Rating			Conn.	Primary			Secondary					
	ID	MVA	kV		Str.kV	Typ.	kV	Amp	Ohm	T.pct	kV	Amp	Ohm
T3		6000	220.000	66.000	D/Y					Solid			
T4		10.000	66.000	11.000	D/Y					Solid			
TS		20.000	66.000	11.000	D/Y					Solid			
T6		10000	66.000	11.000	D/Y					Solid			
T7		12.500	11.000	65.000	D/Y					Solid			
TS		10000	11.000	66.000	D/Y					Solid			
T8		10.000	66.000	11.000	D/Y					Solid			
T10		10.000	66.000	11.000	D/Y					Solid			
T11		20.000	66.000	11.000	D/Y					Solid			
T12		20.000	66.000	11.000	D/Y					Solid			
TB		10.000	66.000	11.000	D/Y					Solid			
TU		10.000	66.000	11.000	D/Y					Solid			
TIS		10.000	66.000	11.000	D/Y					Solid			
T16		20.000	66.000	11.000	D/Y					Solid			
T17		20.000	66.000	11.000	D/Y					Solid			
T18		20.000	66.000	11.000	D/Y					Solid			
T19		10.000	66.000	11.000	D/Y					Solid			
T20		3.000	0.400	11.000	D/Y					Solid			
T11		3.000	MOO	11.000	D/Y					Solid			
T11		3.000	0.400	11.000	D/Y					Solid			
T13		3.000	0.400	11.000	D/Y					Solid			
T14		3.000	0.400	11.000	D/Y					Solid			
T15		3.000	0.400	11.000	D/Y					Solid			
T16		3.000	MOO	11.000	D/Y					Solid			

Project: ILLISTER THESIS
 Location: HOUN CITY - LIBYA
 Contract: EAR EAST INIVERSITY - EEE Department
 Engineer: SAND IIDSTAF A-REFAI
 Filename: HOUN SUBSTATION 220KV

ETAP
 12.6.0H
 Study Cns*: TS

Page: 8
 Date: 28-06-2016
 SN:
 Relisln: Base
 Config: Normal

DESIGN OF ALARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION IN LIBYA'S POWER GRID

Branch Connections

Ckt/Bnch	ID	Tr/t	Connected Bus ID		% Impedance, Pos. Seq., 100 kVA Base			
			From Bus	To Bus	R	X	Z	y
T1	2wxnm.	Bu<1		Bus1	0.46	zass	10.59	
T1	IWXFMR	Bu<1		Bus1	0A4	~.96	19.97	
T3	IWXFIR	Bu~		Bus2	M4	19.96	19.97	
T4	2WXFIR	B1d		Bus6	6A0	S\,15	83.50	
TS	IWXFIR	Bus1		Bus9	1S0	49.9J	50.00	
T6	IWXBIR	Bu,s		Bus10	2.5J	S0.56	SASS	
T7	2wxam	BusJ2		Bu,11	S.06	65.77	65.97	
TS	IWXFMR	Bu<11		Bus12	S.06	65.77	65.97	
T9	IWXOIR	Busl3		Bu,15	MS	SUO	S7.15	
TIO	2WXFMR	B1ul,t		Busl6	6.6S	86.90	87.15	
T11	zwxnm.	Bu-47		Bus19	2.50	49.94	50.00	
T12	IWXnia	Bu,18		Bu-48	1S0	49.94	50.00	
T13	IWXBIR	Bus21		BU\$22,	6.40	83.25	8.150	
T14	IWXnm	Bu-!1		Bus25	6.40	83.25	63.50	
T15	IWXnm	Bu4		Bu,26	6.64	86.38	8MJ	
T16	IWXEIR	Bu,27		Busl\$	2.51	S0.2\$	SOS!	
T17	IWXFMR	Bu-Z7		Bu,29	ZS1	50.25	SOS!	
T18	IWXFIR	B11'1)		Bus3:?	1 ~	51.81	51.88	
T19	IWXFIR	B11<11		Bus33	1S9	51.81	51.88	
no	IWXFMR	Bu'44		Bu,U	34.25	108.50	108.33	
n1	IWXFMR	BusJS		Bu41	3-12\$	20\$.50	208.33	
n1	IWXFIR	Bu,36		Bu,41	3.125	205.50	208.33	
T23	IWXFIR	BusJ7		Bu,41	3.125	205.50	108.33	
T24	IWXBIR	BusJS		Bu,J1	34.1S	205.50	208.33	
ns	IWXBIR	Bus39		Bu-47	3-15	205.50	208.33	
T16	IWXNM	Bu,40		Bu,42	J.JZS	105.50	>208.33	
Cabtl	Cablt	Butll		Bus1	0.02	0.01	0.03	0.0716998
Cabtl	Cablt	Bu,12		Bus1	0.0Z	0.01	0.03	0.0716998
Lind	Lint	Bu'l		BusU	2.48	16.58	16.77	0.1607619
Lint2	1M:	Busl		Bld3	IAS	IS.16	/SS6	0.1SJ1167
Lin,3	Lint	Bus1		Busl8	11	18.06	18.30	0.S387157
Lin,4	Lint	Bu,a,7		Bus1	1.93	11.78	11.94	0.2209015
Lin,5	Lin,	Bu,l		Bu,17	1.03	6.ZS	6S7	0.1178142
Lin,6	Lint	Bu,Z		Bus7	0.51	3.U	3.18	0.0589071
Lin,7	Lint	Bu,l		Bu-8	0.51	3.U	J.18	0.OS89071
Lin,8	Lint	Bu'l		Bu8:7	0.51	.1.U	3.1&	0.0-<9071
Lin,9	Lin,	Busl		Bus\$	0.SI	3.U	3.1S	0.0S89071

Project: I.IASTERIHEYSIS
 Location: HOUNCITY-LIBYA
 Contracr: NEAREAST UI\IV:ERSIT\ EEE Department
 Engineer: SAND \|USTAFAAL-REFAI
 Filename: HOUNSUBSTATION220kV

ETAP
 12.6.0H

Study Case: TS

Page: 9
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGNOF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA POWER GRID

Ckt/Busndi		CouMrted Bus ID		% Impedance, Pos. Seq., 100 JIIVA Base			
ID	Type	From Bus	To Bus	R	X	Z	Y
Lind 0	Lin ^f	BusZ	BusJl	1.03	6.18	6.37	0.1175U
Lind1	Lin ^s	Busl	BusJO	1.03	6.28	6.47	0.1185U
Line1?	Lin ^s	BusJ7	BusJl	2.70	16.49	16.71	0.10916U
Line13	Lin ^s	BusJ7	Bw23	20.70	116.43	118.11	2.1710100
Lin_U	Lin ^s	Bus21	BusJ	18.00	109.94	111.40	2.0617480
S\11	Ti_Swfuh	Busl	Bus2				
SW1	TloSlirth	BusJ7	BusS				
SWS	TieSnirth	Busl3	Busl4				
SW4	Ti_Snirth	BusJ7	BusS				
SWS	TjtStTiteb	Busl3	Busl_4				
SW6	TjtSldtch	Bus25	Bus26				
SW7	TjtSnirth	Bus-Z8	Busl9				
sws	TjtSnite-h	BusJO	BusJl				
SW9	Tjt Snith	Bus32	BusJ3				
S\110	TjtSnirth	Bus41	BusJ2				

Project: MASIER THESIS ETAP Page: 10
Location: HOUN CTTY -LIBYA 12.6.0H Date: 28-06-2016
Cctracrt: NEAREA.51' UNIVERSITY -EEE Department SN:
Enginieer: SAND ~WSTAFKA AL-REFAI R.(dslo)u: Base
Filename: HOUN SUBSTATION 220kV Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Brauer's Conventions

Ckt/Brnch		Connected Bus ID		% Impedance, Zet-o Seq. * 100 MV Ab			
ID	Typ.	From Bus:	To Bus	RO	XO	Z0	YO
T1	2WXFMR	Bu,3	Bud				
T2	2WXFMR	Bus4	Bml				
T3	2WXFMR	BnsS	Bud				
T4	2WXFMR	Busl	Bu-6				
T5	2WXFAIR	Bus7	Bm9				
T6	2WXFMR	Bn,S	Bud 0				
T7	2\ XFMR	Bus42	Bndl				
TS	2WXFMR	Bus.tl	Bu12				
Tb	2WXFAIR	Bud,l	BmHi				
no	2WXFMR	Busu	Bud6				
T!	2WXFAIR	Bml7	Bus19				
T11	ZWXFMR	Bus8	Bus20				
T13	2WXFMR	Bus21	Bud?				
TU	1VX!AIR	Bus3	BmlS				
T15	2wxnm	Bus,U	Bus26				
T16	2wxnm	Bus27	Bml8				
T17	2\ XFMR	Bus27	Bud9				
T18	IWXFIIR	Bud-	Bud?				
TJ9	IWXFIIR	Bus31	Bus33				
TIO	2WX!AIR	Bus,l	Bus41				
TII	IWXFMR	Bus\$	Bu,41				
T12	IWXFMR	Bus,.)6	Bu,41				
TJ1	IWXFMR	Bu,37	Buic,n				
T24	2WXFMR	Bus38	Bu-12				
T25	IWXFIIR	Bu,39	Bu5-l				
T26	IWXBIR	BusJ0	Bus42				
Cnbld	C.bl,	Budl	Bu-?				
C••1,2	C,blt	Busl	Bud				
Lino!	Lin•	Bus?	Bu,U				0.molus
LintZ	Utt	Bud	Bud3				0.1341983
Lltt:I	Lin,	Bus2	BudS				0.1\$99?SS
LIn-4	Lht	Bin27	Bud7				0.10J299?
UntS	Llu,	Bud	Bus2,7				0.OJS...<tm
LInt6	Un,	Buss?	Bu1,7				0.0778131
Liuc7	Lint	Bu,l	8U\$8				0.0278131

Project: M&STER THESIS

ETAP

Page-: 1

Location: HOUNCITY-LIB\A

12.6.0H

Date: 28-06-2016

Coutraet: NEAR.EASTUNIVERSITY -EEE Department

SN:

Engineer: SAID MUSTAFA AL-REFAI

Revision: Base

filename: HOUNSUBSTATION20kV

Config: No imat

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Project: USTER THESIS ETAP Pgno: 12
 Location: HOJIN CITY LIBYA 12.6.0H Date: 28-06-2016
 Contract: NEAR EAST UNIVERSITY EEE Department SN:
 Engineer: SA.¹ intSTAFA AL-REJAI RTy, lsiou: Base
 File Name: HOUN SUBSTATION 220kV C01,fig: Nonnnl

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM At'l>ll!PACT ANALYSIS OF ITS INTEGRATION INTO LIBT!At'i POWER GRID

Synchronous Machine Parameters

ID	Type	Motor	Rating		Per Unit Values (%)						Zero Seq. Z (%)				
			MVA	kV	R _s	X _d	X _{d'}	X _q	X _{q'}	X _{q''}	X _{q'''}	X ₁	X _{IR}	RO	XO
U1	PowrGrid	NIA	2.001	220.000	9.94	99.50							35.65	3.48	
U1	PowrGrid	NIA	2.101	120.000	9.95	99.50							17.7	171.38	
U3	PowrGrid	NIA	1.101	110.000	9.95	99.50							17.74	117.38	

Machine ID	Connected Bus m	Time Constants (Sec.)				H (Sec.) D (Wpu/H) & Saturati				Generator or Loading				Group<ung	
		Td0"	Td0'	Tq0"	Tq0'	H	%D	S100	S100	Sbruk	M.W	M.r	Cou	Typ	Amp
Generator Motor															
ID	R1'M WR' H	R1'M WR' H	R1'M WR' H	R1'M WR' H	R1'M WR' H	RPM	WR	H							

WR²: kg.m² H,MW,S²IMVA

MacWne ID	Typ*	Shaft Tol'slon.			
		D1	D2	K1	K2

D1, D2: MW(pu).Spdd(pu) K1, K2: MW (pu)IRadiam

Project: IIASTER THESIS ETAP
 Location: HOUN CTRV LIBYA 12.6.0H
 Contract: NEAR EAST UNIVERSID' -EEE Department
 Engineer: SANDMUSHFA AL-REFAI Study Case: TS
 Filename: HOUN SUBSTATION 220kV Revision: Base
 Config: Normal

DE51GN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Lump-rl Load Input Data

Conventional Type

ID	kV	kVA	kW	kvat	% PF	Amp	Load		Ta	Gamma
							%Motor	0A-Static		
Lump1	11.000	1243	0	1243	0.01	65.3	\$0	20	0	0
Lump10	11.000	5882	5000	3098	85.000	108.7	80	20	0	0
Lump11	11.000	3529	3000	1859	85	18.2	80	10	0	0
Lump12	11.000	3-29	3000	1859	85	18.2	80	20	0	0
Lump13	11.000	12942	11000	6818	85.000	679.3	80	20	0	0
Lump14	11.000	5553	5000	3099	85.000	308.8	80	10	0	0
Lump2	11.000	2383	2000	1240	85	123.5	80	20	0	0
Lump3	11.000	8236	7000	4339	85.000	432.0	80	20	0	0
Lump4	11.000	7058	6000	3718	85	370.5	80	10	0	0
Lumps	11.000	1055	6000	3718	85	170.5	80	10	0	0
Lump6	11.000	5500	5500	0	100	188.	80	10	0	0
Lump7	11.000	3500	3500	0	100	183.7	80	10	0	0
Lump8	11.000	6000	6000	0	100	314.9	80	20	0	0
Lump9	11.000	2382	2000	1239	85	123.8	80	20	0	0

Project: MASTER THESIS
 Location: HOUN CITY LIBYA
 Contr.n(t): EEAR EA&T UNIVERSIT' - EEE Department
 Engineer: SA.ND ~IUSTAFA.A.L-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.70H
 Study Case: TS

Page: 14
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLARPV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER("RID

LOAD FLOW REPORT QWithout PV)@T = 0.000

Bus	ID	kV	Voltage-		Generation		Load		Load ID	Load flow			Xfltr
			Mng.	Ang.	MW	Ahrtr	PfW	Afrn		MW	lfrar	Amp	
Bus1					0	0	0	0	Bus13	6.01T	3S6.1		STI ---
									Bus27	19.518	1.1\$5	1.1.6	99.S
									Bus3	3.479	Z.276	36.1	SM
									Bus8	3.479	1.276	36.1	83.7
									Bud0	!MI?	7.-	118J	81.9
									Bu3	..L, M	-18.606	417.3	91.9
									Bm6	0.001	1.247	11.0	0.1
Bus1		66.000	98.852	-27.6	0	0	0	0	Bus14	6.009	3.9?2	63.S	83.3
									Bnd8	3.488	-0.1"6	3M	-99.S
									Bn7	0.994	-0.872	1E.1	86.7
									Bus?	0.9741	(1.571	10.1	86.7
									Bus31	5.022	3.198	51.7	8.4
									Bu13	-16.507	.5.089	161.7	-89.8
"Bus3		Z10.000	100.000	-39.5	0	0	0	0	Bud	-13382	23.466	129.9	88.0
									U1	-&.US?	-2.1166	II9.?	88.0
*BuW		220.000	100.000	0.0	0	0	0	0	U1	0.000	0.000	0.0	0.0
"Bus5		10.000	100.000	z~.6	0	0	0	0	Bm2	16.S1?	8.783	49.1	88.3
									U)	-16.5.21	11.M	49.1	88.3
Bu6		11.000	98.071	-1.1.6	0	0	0	0.000	Bud	0.000	-1.234	66.0	0.0
Bus7		66.000	98.818	-27.5	0	0	0	0	Bus!	0.994	.f.629	10.4	84.5
									Bu?	0.974	-0.678	10.4	8.5
									B.~	J.981	L25-	20.8	84.S
Bu8		66.000	99.021	-44.7	0	0	0	0	Bud	-3.478	-2.329	37.0	83.1
									Bud	-3.478	-2.21?	37.0	83.1
									Bush0	6.986	4.657	73.9	83.1
Bu-		11.000	98.U6	-28.1	0	0	1.986	J.2\$1	Bm1	-US-i	-1.231	J14.9	85.0
B*FO		11.000	97.770	-46.1	0	0	6.938	4.301	Bu.S	-6.381	-1.101	436.2	85.0
Bud3		66.000	98.344	..1S.1	0	0	0	0	Bud	-6.004	-4.158	65.0	82.2
									BusS	6.004	4.158	65.0	82.2
Busu		66.000	98.015	-28.0	0	0	0	0	Bu12	-8.976	-1.1S,	65.1	S2.1
									Bud6	S.996	4.1SS	65.1	S2.1
BudS		11.000	98.69?	-48.0	0	0	S.968	J.699	B"13	S.968	,"69	37341	85.0
Bnd6.		11.000	98.339	1LO	0	0	S.960	J.694	Bu,U	-S.60	-M9	374.2	85.0
Bus17		66.000	98.917	-46.11	0	0	0	0	Bu.127	-13.472	1.810	II1.7	-97.9
									Bus!	6.60?	-1.319	59.5	-98.I
									Bus23	J.390	-1.W	IM	-6.6
									Bu.19	S.480	0.153	48.5	100.0

Project: MASTER THESIS
 Location: HOUN CITY - LIBYA
 Contract: NEAR EAST UNIVER.SIT'T'E EEE Departmneur
 Engineer: SAND MUSTAFA A.L-REFAI
 Filename: HOUN Sh'BSTATION 220kV

ETAP
 12.6.0H
 Page: 15
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE-SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS ON ITS INTEGRATION INTO LIBYAN POWER GRID

LOAD FLOW REPORT (Without P\T_aeee)

Bus ID	hV	Voltage		Generation		Load		ID	Load Flow			XThR %Tap	
		%Mag.	Ang.	MW	Mvar	Afarr	Bu1,1		MW	I'für	Amp		
Bus1	11.000	7.111	-11.1	0	0	5.471	0.000	11<17	3.481	0.061	30.9	100.0	
BU<11b	11.000	98.740	-47.9	0	0	5.471	0.000	11<17	-5.412	0.000	296.9	100.0	
BU<20	11.000	98.661	-28.9	0	0	3.481	0.000	BU<18	.8.1S1	0.000	185.1	100.0	
Bus21	<1.000	98.938	-47.0	0	0	0	0	BU<7	-6.590	1.09.2	59.1	98.7	
								BU<3	0.604	1.1SS	13.5	+39.6	
								Bus11	5.986	0.106	\$3.0	99.9	
Bus12	11.000	98.111	-49.9	0	0	5.962	0.000	BU<11	-5.962	0.000	318.0	100.0	
11<23	<1.000	99.26	-47..	0	0	0	0	BU<17	J..85	-0.656	13.5	90.4	
								BU<11	0.603	=asn	7.6	69.6	
								BU<5	1.988	1.111	10.8	84.1	
BU<15	11.000	98.077	-48.3	0	0	1.981	1.1SE	BU<3	J.984	-1.230	m.9	85.0	
BU<27	65.000	98.847	-45.1	0	0	0	0	BU<7	13.509	-2.797	122.1	.91.9	
								BU<1	-19.478	J.026	112.6	111.9	
								BU<28	2.984	1.911	31.1	8.11	
								BU<1	2.981	1.912	3U	8-11	
BU<28	11.000	98.478	-46.2	0	0	1.981	1.1SE	BU<7	-ZSS1	-1.848	187.0	85.0	0.625
BU<19	11.000	98.428	-46.1	0	0	1.981	1.1SE	BU<21	-2.981	J.848	187.0	85.0	0.625
BU<30	66.000	98.515	-15.0	0	0	0	0	BU<1	-10.961	-7.688	118.9	81.9	
								BU<32	10.961	7.688	11U	81.9	
BU<31	66.000	98.594	-27.7	0	0	0	0	BU<1	-5.019	J.290	\$3.1	SM	
								BU<33	S.019	3.190	53.1	SM	
BU<12	11.000	98.036	-18.2	0	0	10.914	6.765	BU<30	-10.914	-6.765	687.5	85.0	3.750
BU<33	11.000	100.463	ZS>1	0	0	5.009	3.105	BU<31	-5.009	3.105	307.9	85.0	3.750
U1	110.000	291.911	0.0	\$4.612	133.771	0	0	BU<3	546/Z	133.771	129.9	37.8	
U1	110.000	100.000	0.0	0	0	0	0	BU<1	0.000	0.000	0.0	0.0	
U3	20.001	162.988	0.0	18.099	24.547	0	0	(1 BU<5	18.011	24.547	49.1	59.J	

*Indicates a 'voltage' regulated bus (Voltage controlled by string type machine connected to it)

indicates a load bus (load connected to it)

Project: MASTER IHESIS
 Location: HOUN CITY-LIBYA
 Contact: NEAR EAST UNIVERSIT Dili Deparlineil
 Engineer: SAND MUSTAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP 12.6.0H
 Study Case: TS
 P-gt: 16
 Date: 28-06-2016
 SN:
 Rwdou: Base
 Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

LOAD FLOW REPORT (Without PV) at T = 0.800

Bus	ID	Voltage	Gt-eration	Load	Load Flow						XFLR 81.9	
					MW	Afr.	ID	MW	Il,1Ir	Amp	%PF	
Bus1		7.000 ~ -38.	--0 --0 --0	--0 ~	Bu, U							
					Bu,27		30.507	-10.755	146.1	.94.3		
					BusS		5.446	3.266	15.,	88.8		
					BusL		5.446	3.166	28.7	88.8		
					BU,20		11.m	10.1174	92.9	SJ.6		
					Bn,1		-68.374	-13.S15	314.II	98.0		3.750
					B-4,6		0.001	1.929	8.7	0.0		
Bus2		166.000 98.S&I -17.S	0 0 0	0	Bu,DJ		6.009	3.992	63.8	83.3		
					BudS		3.488	-0.246	30.11	-99.8		
					Bu,7		0.994	0.512	10.1	86.7		
					Bus7		0.994	0.472	10.1	86.7		
					Bu,1		5.022	3.198	SL7	SLU		
					Buss		-16.507	-5.089	16.7	89.8		E.SIS
Bn,3		120.000 1SS,SS9 -33.1	0 0 0	0	0 Bud		68.435	16.194	98.0	97.1		
					U1		-6U35	-16.594	98.0	SL71		
Bus4		120.000 100.000 0.0	0 0 0	0	0 JIZ		0.000	0.000	0.0	0.0		
Bus5		100.000 100.000 -1.<6	0 0 0	0	0 BusZ		16.512	8.783	49.1	88.3		
					UJ		-16.S11	8.783	49.1	88.3		
Bus6		11.000 192.967 -35.3	0 0 0.000	1.910	BusL		0.000	1.120	52.1	0.0		
Bus7		(6.000) 98.S78 -17.5	0 0 0	0	Bu,2		-0.994	0.629	10.J	84.5		
					BusZ		-0.994	-0.629	10.4	SL1		
					Bu,9		1.987	1.259	10.8	84.1		
Bus8		66.000 193.717 -35.3	0 0 0	0	0 Bud		-5.446	-3.415	19.Z	SL?		
					Bu,1		-5.446	-3.483	19.Z	54.1		
					Bu,10		10.891	6.166	SLU	SLU		
Bu,9		11.000 98146 -28.1	0 0 1.966	1.731	Bu,7		-1.986	-1.731	134.9	88.0		
Busl0		11.000 19.f10? -36.1	0 0 10.880	67.U	Bu-		-10.880	4744	346.0	85.0	LMO	
Busl3		(5.000) 193.ll? -38.8	0 0 0	0	0 Bud		9.555	-6.197	5L6	83.11		
					Bud5		9.555	6.197	51.6	83.9		
Bu,14		66.000 98.015 -18.0	0 0 0	0	0 BusL		-5.996	-U55	65.1	SL2		
					Bus16		5.996	-U55	65.1	SL2		
Busl5		11.000 198.606 -36.7	0 0 9.533	5.908	Bud3		-9.533	-5.908	29.4	85.0		1.m
Busl6		11.000 98.539 -31.0	0 0 5.960	3.69.f	Bu,11		-5.960	-3.694	374.1	88.0		4.375
Bns7		66.000 19.f744 -36.0	0 0 0	0	Busl7		-2.L105	15.770	1HS	SL1		
					BusL		10.341	-7.831	58.3	-79.7		
					Bn,31		2.193	-S.031	37.4	-26.3		
					Bn,19		8.571	0.097	38.5	100.0		

Project: IUSI~~E~~ER THESIS
 Location: HOUN' CITY -LIBYA
 Contract: YEAR EAST UNIVERSITY -EEE Depnrtment
 Engineer: SAJID MUSTAFA AL-REF AI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Stnly Case: TS

Page: 17
 Date: 28-06-2016
 SN:
 Rejction: Base,
 Config: Nonn;ll

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND THIPAC ANALYSIS OHTS INTEGRATION LIBYAN POWER GRID

LOAD FLOW REPORT<Without PV1@_T=0.800>

BlcS	ID	kV	Voltage			Oeneraden		Load		ID	Load flow			Xf!IR		
			%~Ldg.	Ang.	M, m	M, m	H/W	H/V	Bu.Z		SW	Mvar	Amp	%PF		
Bus:																
			98.9m	-1.1	0	0	0	0	Bu.0		3.m	0.062	30.9	100.0		
Bnd9		11.000	194.6ZL	-36.7	0	0	8.561	0.000	Bnd7		5.56J	0.000	131.0	100.0		
BinW		11.000	98.66J	-28.9	0	0	0	J.181	(1.000)	Buds		1.48I	MOO	ISS.1	100.0	
Bus21		<000	195.217	-163	0	0	0	0	Bm:17		-10.229	6.778	55.1	SIS		
									Bu-3		0~;S	-6.920	31J	-13.7		
									Bus11		9.371	0.191	42.0	100.0		
Bus11		11.000	194.868	.J1.5	0	0	9.37	0.000	Bu.11		-98.57	0.000	252.0	100.0		
Bm13		<16.000	19U1S	-36.6	0	0	0	0	Btd1		-1.1SS	Q.998	lo.7	90.9		
									Bus11		-0.953	-0.973	6.1	70.0		
									But1-		3.136	1.97I	16.5	84.7		
Bus1-		11.000	195.883	-36.9	0	0	3.134	L942	Bu.tn		-1.134	-1.9.1?	98.8	85.0		
Bus17			193.919	-35.6	0	0	0	0	Bu.17		21.141	-16.85	120.6	-79.0		
									Bus1		10.478	10.S10	145.4	-94.8		
									Bus1S		4.669	2J3.1	2.1.9	8.1.7		
									Bu.29		4.669	2.93I	14-	8.1.7		
Bus16		11.000	194.375	-SS.6	0	0	4.667	LS91	Bus7		-4.667	-2.89I	11.SZ	85.0	0.625	
Bw:29		11.000	194.375	-16.0	0	0	4.661	LS91	Bu.??		-4.667	-2.89?	US.?	85.0	0.61S	
Bu<10		<16.000	19J41	35.5	0	0	0	0	Bud		-17.399	-11.343	94.0	83.8		
									Budi		17.399	11.34.1i	94.0	S3.8		
Bus34		<16.000	98.994	-27.7	0	0	0	0	BuZ		-S.019	-1.290	S.1.1	83.6		
									Bus.3		5.019	3.190	SM	83.6		
Bus32		11.000	197.370	-16.8	0	0	17J70	10.767	Bus30		11.sro	-10.767	5.13.S	85.0	3.750	
Bus38		11.000	100.461	-19.1	0	0	0	0.009	3.105	Bu<11		-S.009	3.10S	307.9	IS»	1.750
U1		120.000	291.912	o.o	74.714	19.386	0	0	Jlu.3		74.714	79.386	98.0	68.5		
U2		210.000	100.000	o.o	0	0	0	0	Bu-l		0.000	0.000	0.0	0.0		
U3		210.000	m.988	o.o	18.099	24.~	o	0	Bur:1		18.099	ZJ.SN	49.1	S9J		

* Indicates a voltage regulated bus (voltage controlled or Sizing type machine connected to it)

indicates a bus with a load mbw.td of mere than 0.1 MVA

Project: ?L4.5"TER. THESIS

ETAP

Page: 18

Location: HOUN CITY LIBYA

12,6,0H

Date: 28.JJ6-2016

Counncu NEAR EAST UNIVERSITY- EEE Department

SN:

Engineer: SALEM MUSTAFA AL-BILU

$$S_1 + S_2 = -$$

Revlsion: Base

Elliptical: HOUNSLUBSTATION 220kV

Config: Nounal

nES|GN OT A LARGE SCALE SOLAR PV SYSTEM AND IMPAcT ANALYSIS OF ITS INTEGRATION IN TO LIBYAN POWER GRID

LOAD FLOW REPORT (Without PV) ® I = 1.00n-

Bus	Voltage-			Generation			Load			Load flow			XFluffi	
	M	I	S	% Mag.	Aug.	MW	Mrm	MW	Mvar	MW	Ihr	Amp	%PF	
Bus1	66.000	0.000	0.000	~	--0	--0	--0	--0	--0	Bm13	0.000	0.000	--0.0	0.0
										Bus1	0.000	0.000	0.0	0.0
										Bu1S	0.000	0.000	0.0	0.0
										Bu-S	0.000	0.000	0.0	0.0
										B-130	0.000	0.000	0.0	0.0
										Bu,3	0.000	0.000	511.2	0.0
										Bm6	0.000	MOO	0.0	0.0
										Bu14	0.000	0.000	0.0	0.0
										Bm15	0.000	0.000	0.0	0.615
Bcl	16.000	0.000	90.0		0	0	0	0	0	Bud4	0.000	0.000	0.0	0.0
										Bm1S	0.000	0.000	0.0	0.0
										Bu17	0.000	0.000	0.0	0.0
										Bu\$1	0.000	0.000	0.0	0.0
										Bud1	0.000	0.000	0.0	0.0
										Bu15	0.000	0.000	0.0	0.0
Bw3	10.000	11.164	4>		0	0	0	0	0	Bwl	0.168	7.579	161.2	2.2
										U1	0.168	-7.79	162.1	2.2
Bu14	10.000	100000	0.0		0	0	0	0	0	U2	0.000	0.000	0.0	0.0
Bu15	220.000	0.000	90.0		0	0	0	0	0	Bml	0.000	0.000	0.0	0.0
										U3	0.000	0.000	94.8	0.0
Bus6	11.000	0.000	90.0		0	0	0	0	0	Bud	0.000	0.000	0.0	0.0
Bu17	66.000	0.000	90.0		0	0	0	0	0	Bu12	0.000	0.000	0.0	0.0
										Bu14	0.000	0.000	0.0	0.0
										Bus9	0.000	0.000	0.0	0.0
Bus8	66.000	0.000	90.0		0	0	0	0	0	Bud	0.000	0.000	0.0	0.0
										Bud	0.000	0.000	0.0	0.0
										Bu10	0.000	0.000	0.0	0.0
Bus9	11.000	0.000	90.0		0	0	0	0	0	Bu-7	0.000	0.000	0.0	0.0
Bud0	11.000	0.000	90.0		0	0	0	0	0	Bu-s	0.000	0.000	0.0	20
Bad3	66.000	0.000	90.0		0	0	0	0	0	Bu15	0.000	0.000	0.0	0.0
										Buds	0.000	0.000	0.0	0.0
Bu14	16.000	0.000	90.0		0	0	0	0	0	Bm?	0.000	0.000	0.0	0.0
										Bud6	0.000	0.000	0.0	0.0
Bm1S	11.000	0.000	90.0		0	0	0	0	0	Bu13	0.000	0.000	0.0	4.375
Bud6	11.000	0.000	90.0		0	0	0	0	0	Bud\$	0.000	0.000	0.0	4.37.
Bu17	66.000	0.000	90.0		0	0	0	0	0	Bu-17	0.000	0.000	0.0	20
										Bm11	0.000	0.000	0.0	0.0
										Bus23	0.000	0.000	0.0	0.0
										Bud9	0.000	0.000	0.0	0.0

Project: MASTERS THESIS
 Location: HOUN CITY -LIBYA
 Contract: NEAR EA.SI UNIVERSM- EEE Department
 Engineer: SAJ(1) IUSIAFA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP

Page: 19
 Date: 28-06-2016
 SN:
 R-lusion: Base
 Config: Nonnnl

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND OPTIMIZATION OF ITS INTEGRATION INTO LIBYAN POWER GRID

LOAD FLOW REPORT QV without PVs @ I= 1.000-

Bus	Voltage			Generation		Load		ID	Load Flow				XBIR	% Top
	ID	V	% Mdg.	Ang.	MW	M. nr	MW	Jh-nr	MW	Ifarr	Amp	%PF		
Bu,18		66.000	0.000	90.0	0	0	0	0	Bu,z	0.000	0.000	0.0	0.0	
									Bu,20	0.000	0.000	0.0	0.0	
Bu,19		11.000	0.000	90.0	0	0	0	0	Bu,17	0.000	0.000	0.0	0.0	
Bu,20		11.000	0.000	90.0	0	0	0	0	Bud8	0.000	0.000	0.0	0.0	
Bu,21		66.000	0.000	90.0	0	0	0	0	Bu,17	0.000	0.000	0.0	0.0	
									Bu,23	0.000	0.000	0.0	0.0	
									Bu,1z	0.000	0.009	0.0	0.0	
Bu,1z		11.000	0.000	90.0	0	0	0	0	Bu,11	0.000	0.000	0.0	0.0	
Bu,H		66.000	0.000	90.0	0	0	0	0	Bn,17	0.000	0.000	0.0	0.0	
									Bu,21	0.000	0.000	0.0	0.0	
									Bus15	0.000	0.000	0.0	0.0	
Bu,2s		11.000	0.000	90.0	0	0	0	0	Bm23	0.000	0.000	0.0	0.0	
Bus17		66.000	0.000	90.0	0	0	0	0	Bu,17	0.000	0.000	0.0	0.0	
									Bu,!	0.000	0.000	0.0	0.0	
									Bu,28	0.000	0.000	0.0	0.0	
									Bu,29	0.000	0.000	0.0	0.0	
Bu,28		11.000	0.000	90.0	0	0	0	0	Bi~27	0.000	0.000	0.0	0.0	0.6ZS
Bus29		11.000	0.000	90.0	0	0	0	0	Bu27	0.000	0.000	0.0	0.0	MZS
Bus30		66.000	0.000	90.0	0	0	0	0	Bud	0.000	0.000	0.0	0.0	
									Bu'3Z	0.000	0.000	0.0	0.0	
Bus31		66.000	0.000	90.0	0	0	0	0	Bu,2	0.000	0.000	0.0	0.0	
									Bu,33	0.000	0.000	0.0	0.0	
Bu'3l		11.000	0.000	90.0	0	0	0	0	Bu'30	0.000	0.000	0.0	0.0	3.7SO
Bus33		11.000	0.000	90.0	0	0	0	0	Bu'3l	0.000	0.000	0.0	0.0	M 3.7SO
U1	??0.000	291.17	0.0	17.71	179.600	0	0	0	Bu,1	17.171	119.600	167.2	9.6	
U2	??20.000	100.000	M	0	0	0	0	0	Bu,4	0.000	0.000	0.0	0.0	
U3	??20.000	1152.988	(D)	S,SE	58.410	0	0	0	Bm5	58.412	58.41C1	9~5	10.6	

* Indicates a voltage regulated bus (Voltage controlled or swing type, machine connected to it)

indicates a bus with a load/loss width of more than 0.1 MVA

Project:	MASTER THESIS	ETAP	Page:	20
Location:	HONI CITY- LIBYA	12.6.0H	Date:	28-06-2016
Contract:	NEAR EAST UNIVERSITY - EEE Department		SN:	
Engineer:	SAYED MUSTAFAAL-REFAI	StudyCase: TS	Region:	Base
Filename:	HOON SUBSTATION220kV		Config:	Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Dysunk Stabiliti'

The tabulated plot data is not printed since the option of "Skip Tabulated Plots" is checked.
To print tabulated plot data go to the Transient Stability Study Case Editor and in the Info Page uncheck the "Skip Tabulated Plots" option.

Project: MASTER THESIS

ETAP

Page:

Location: HOUN CITY-LIBYA

Dato: 28-06-2016

Contract: "EAR EAST Ltd" UNIVERSITY - LEE Department

SN:

Engineer: SAND MUSTAFA AL-REFAI

SIV.

Engineer: SAND MUSTAFA AL-KELAI
Filename: HOUN SUBSTATION 220kV

StudyCase: TS

Revision. *Bast*

DESIGN OF A LARGE SCALE SOL-VRPV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S RPTD ERGRID

Systein Islanding Index

Tim.(Stc.)	ElementID	Type	Zon.No.
0.000	Bud	Bus	2
0.000	Bu,10	Bus	2
0.000	Bu,13	Bus	2
0.000	Busl~	Bus	1
0.000	Bu,15	Bu,	2
0.000	Busl6	Bus	1
0.000	Bud7	Bus	2
0.000	Busl8	Bus	1
0.000	Bu,<9	Bus	2
0.000	Bus2	Bu,	1
0.000	Busl0	Bus	1
0.000	Bu12l	Bus	2
0.000	Busll	Bu,	2
0.000	Bus-23	Bus	2
0.000	Bus25	Bus	2
0.000	Bus27	Bus	2
0.000	Bus28	Bus	2
0.000	Bus29	Bus	2
0.000	Bus3	Bus	2
0.000	Bus30	Bus	2
0.000	Bu'31	Bus	1
0.000	Bus32	Bus	2
0.000	Bu'33	Bu,	1
0.000	Bu;;1	Bus	3
0.000	Bus\$	Bus	1
0.000	Bus6	Bu,	2
0.000	Bu,;7	Bu,	1
0.000	Bu,S	Bu,	2
0.000	Bus9	Bus	1
0.000	U1	Powr Grid (Rtf)	2
0.000	U1	Powtr Grid (Rtf)	3
0.000	U3	Power Grid (Ref)	1

Project: **I'USIBR THESIS** ETAP
 Location: **HOUN CITY -LIBYA** 12.6.0H
 Contract: **NEAR EAST UNIVERSITY ~E Department**
 Engineer: **SAND MUSTAFA AL-REFAI**
 Filename: **ROUN ~!STATION 220kV** Study Case: **TS**
 Page: **22**
 Date: **28.06.2016**
 SN:
 Revision: **Base**
 Config: **No1n-I**

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND THE ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Action Summary

EventID	ThmtSec.)	Dt(i-Typt	Dtd('tID	Action
t_tm2	0.300	Bu,	Bus1	3 Phase Fault
event2	0.800	Bu,	Bu\$	jph.,Fault

APPENDIX 13

TRANSIENT STABILITY ANALYSIS WITH PV

Project: ETAP
 Location: HOUN CITY -LIBYA
 Conn-acr: YEAR EAST UNIVER-SITY - EEE Department
 Engineer: SAND IWSTAFIA AL-REFAI
 Filename: HOUN SUBSTATION220kV

Version: 17.6.0H
 Study Case: TS

Png.: 1
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT 'A' "Af'SIS OF ITS!<TEGRATION <TO LIBYAN PO'ITER GRID

Electrical Transient Analyzer Program

Transient Stability Analysis (With PV)

Initial Loading Category (I): Design

Initial Generation Category (I): Design

Load Diversity Factor: None

Number of Buses:	Smog	V-Control	Load	Total
	3	7	32	42

Number of Branches:	XFMR2	XFMR3	Re-Mtof	Line/Cable	Impedance	Tie PD	SPDT	Total
	26	0	0	16	0	10	0	52

Number of Machines:	Synchronous Generator	Power Grid	Synchronous Motor	Induction Machine	Lumped Load	Total
	0	3	0	0	14	17

Method of the Initial LF Solution: Adapted T. Nezuou-Raphson

Maximum Number of Iterations: 1000

Solution Precision for the Initial LF: 0.0001000000

Acceleration Factor for the Initial LF: 0.00

Time Increment for Integration Steps (At): 0.0010

Time Increment for Plots: 20dimes6.t

System Frequency: 50.00Hz

Frequency Dependent Models for Machines and Network are Not Used

Unit System: Metric

Project: IIIASTER THESIS
Lormion: HOUN CITYCLIBYA
Contract: NEAR EAST UNIVERSITY- EEE Department
Engineer: SANDIUSTAFAAL-REFAI
Filename: HOUN SUBSTATION 220KV

ETAP
12.6.0H

Page: 2
Date: 28-06-2016
SN:
Re\is\on: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA's POWER GRID

Adjustments

Tolerance	Apply Adjustments	Individual /Global	Percent
Transformer' Impedance:	Yes	IndMdual	
Reactor Impedance:	Yes	IndMdual	
Overload Heater- Resistan α :	No		
Transmissiou Line Length:	No		
Cable Length:	No		

Temperature Corr. \downarrow cation	Apply Ad~	IndMdual /Global	Degree C
Transmisstion Line Resistanc e :	Yes	IndMdual	
Cable Resistance:	Yes	IndMdual	

Project: MA.SIER THESIS
 Location: HOUN OIT - LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SANDI IDSTAFAAAL-REFAI
 Filename: HOT.IN SUBSTATION220kV

ETAP
 12.6.0H
 Study Case: TS

Page: 3
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: No1nal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND ITS INTEGRATION INTO LIBYAN POWER GRID

Bus Input Data

Bus	ID	IV	Sub-sys	InitCap, kVA	Load		ConstantZ	Consfault	Generic
					MW	Mn,r			
Bus0		66.000	I	99.1	-4.2				
Bus1		66.000	I	100.1	-1.1				
Bus2		100.000	I	100.0	0.0				
Bus4		100.000	I	100.0	0.0				
Bus5		220.000	I	100.0	0.0				
Bus6(i)		11.000	I	95.3	-4.2	0.000	0.995	0.000	0.2-9
Bus7		66.000	I	99.0	-1.2				
Bus8		66.000	I	99.1	-1.2				
Bus9		11.000	I	98.4	-1.8	1.600	0.92	0.100	M4S
Bus10		11.000	I	98.0	-6~	5.600	3.471	1.000	0.868
Bus11		66.000	I	99.1	-1.2				
Bus12		66.000	I	99.4	-1.2				
Bus13		66.000	I	98.6	-1.7				
Bus14		66.000	I	98.2	-1.7				
Bus15		11.000	I	99.0	-7.6	4.800	1.915	1.100	0.744
Bus16		11.000	I	98.6	-4.7	4.800	2.975	1.100	0.744
Bus17		66.000	I	99.2	-5.9				
Bus18		66.000	I	99.0	-1.6				
Bus19		11.000	I	98.1	-7.5	4.400	0.000	1.100	0.000
Bus20		11.000	I	98.3	-1.1	1.800	0.000	0.700	0.000
Bus21		66.000	I	99.2	-6.5				
Bus22		11.000	I	98.7	-9.4	4.800	0.000	1.200	0.000
Bus23		66.000	I	99.5	-6.9				
Bus24		66.000	I	100.0	0.0				
Bus25		11.000	I	98.1	-7.9	1.600	0.991	0.400	0.115
Bus26		11.000	I	100.0	0.0	4.000	1.779	1.000	0.620
Bus27		11.000	I	99.1	-4.9				
Bus28		11.000	I	98.1	-<8	2.400	1.487	0.600	0.111
Bus29		11.000	I	98.7	-5.8	2.400	1.487	0.600	0.111
Bus30		66.000	I	98.8	-1.6	U81			
Bus31		66.000	I	98.8	-U				
Bus32		11.000	I	9~	-7.8	8.800	5.455	2.200	W64
Bus33		11.000	I	100.7	-as	4.000	2.419	1.000	0.610
Bus34		0.100	I	100.0	i.1				

Project: HUNSTER THESIS
 Location: HOUN CITY-LIBYA
 Contract: NEAR Mif University - Efil Department
 Engineer: SAJID STAFIA AL-JIBFAI
 Filename: HOUN SUBSTATION Z20kV

ETAP

12.6 OH

Page: 4
 Date: 28-06-2016
 SN:
 Revision: Bas
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Bus	ID	KV	Sub-sys	Initial Voltage	% Mag. Ang.	Load					
						ConstantVA		ConstantZ		ConstantI	
						MW	MVar	MW	MVar	MW	MVar
Bu<5		0.100	1	100.0	1.1						
Bu<16		0.100	1	100.0	1.1						
Bu<17		0.400	1	100.0	1.1						
Bu<18		0.400	1	100.0	3.3						
Bu<19		0.400	1	100.0	3.3						
Bu<40		0.100	1	100.0	3.3						
Bu>11		11.000	1	98.9	1.1						
Bm4l		11.000	1	98.6	1.0						
Total Number of Buses: 42				SI.M	25.185	13.000	6A46	0.000	0.000	0.000	0.000

Note: Details of all motor loads are provided in the bus motor load summary and motor pages for detail.

Generator Bus	ID	KV	1) Pt	Sub-yr.	Voltage		Power ration		Thermal Limits	
					MW	Mvar	%PF	Max	Min	
Bu<1		220.000	Sning	1	100.0	0.0				
Buw		220.000	Sning	1	100.0	0.0				
Bu\$		220.000	Sning	1	100.0	0.0				
Bu<14	MOO	Volttag Control	1		100.0	1.1	1.960	0.899	0.000	
Bu35	MOO	Voltage Control	1		100.0	1.1	1.960	0.899	0.000	
Bu<16	MOO	Volttag CouwoJ	1		100.0	1.1	1.960	0.899	0.000	
Bu<17	MOO	Volttag Control	1		100.0	1.1	1.960	0.899	0.000	
Bus8	0.400	Voltage Control	1		100.0	3.3	1.960	0.899	0.000	
Bu39	MOO	Vohag;>Cont'lol	1		100.0	3.3	1.960	0.899	0.000	
Buu0	MOO	Volta: << Couh'OI	1		100.0	3.3	1.960	0.899	0.000	
					13.719	0.000				

Project: MASTER THESIS
 Location: HOUN CITY LIBYA
 Current: EAR EAST JNIV:ER.SITY • M.M.II; Department
 Engineer: SA!YD MUSTAFAAL-R-EFAI
 Filename: HOUN st!STATION 220kY

ETAP
 12.6.0H
 Study Case: TS

Page: 5
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOURCE PVSYSTDI AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA POWER GRID

Line/Cable Input Data

Ohms or Siemens per 1000 m per Conductor (Cable) or per Phase (Line)

Line/Cable ID	Library	S in	Length:										
			Adj(0)	t-Tol	#Phasr	T(°C)	R1	X1	Y1	R0	X0	Y0	
Cab_1el	IMCUS1	JQ0	100.0	0.0	1	75	0.076302	0.087400	0.0001646	0.240351	0.215110		
u..1	11MCUS3	J00	100.0	0.0	1	75	0.076302	0.056008	0.374255	0.000031	0.200077	1.360791	0.000017
Lin1'1	674	19300.0	0.0	1	75	0.056001	0.342069	0.0000014	0.200637	1.424041	0.000016		
Lin1'3	674	23000.0	0.0	1	75	0.056001	0.3-12069	0.0000004	0.200631	1.424041	0.000016		
Lin1'4	614	15000.0	0.0	1	75	0.056001	0.3-12069	-0.0000084	0.200631	1.424041	0.000016		
LineS	614	8000.0	0.0	1	75	0.056001	0.3-2069	0.0000084	0.200637	1.424041	0.000016		
U.'6	674	4000.0	0.0	1	IS	0.056001	0.3-1%69	0.0000084	0.100637	1.424041	0.000016		
u...	614	40000.0	0.0	1	75	0.056001	0.3-12069	0.0000011	0.100637	1.424041	0.000016		
Linu:8	674	4000.0	0.0	1	15	0.056001	0.1J2069	0.0000034	0.200637	1.4:24041	0.000016		
u..9	674	4000.0	0.0	1	75	0.056001	0.3-12069	0.0000081	0.200637	1.414041	0.000016		
u..10	674	8000.0	0.0	1	75	0.056001	0.3-12%9	0.0000084	0.200637	uuon	0.000016		
Line11	674	8000.0	0.0	1	75	0.056001	0.342069	0.0000014	0.200637	U14011	0.000016		
Line11	674	21000.0	0.0	1	75	0.056001	0.3-12069	0.0000084	0.100637	1.424041	0.000016		
Lin1d3	674	161000.0	0.0	1	15	0.056001	0.3-11%9	0.0000084	0.100637	1.424041	0.000016		
U.'14	614	140000.0	0.0	1	75	0.056001	0.34116-	0.0000014	0.200637	J..124041	0.000016		

Line/ Cable n.U.-rancit: m tiftdajhtSpriifid ttppmtnmt\$.

Project: 11L4.SIJ:R JHESIS
 Located: HOJN CITY - LIBYA
 Client: NEAR EAST UNIVERSITY CEE Department
 Engineer: S.I.N.D M.USTA/AJA/REFAI
 Firm: HOJN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: TS

Page: 6
 Date: 28-06-2016
 SN:
 Revision: Basti
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM | © HEPAGT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

2-Winding Transformer Input Data

Transformer	ID	Rating				Z Variation			% Tap Setting		Adjusted %Z	Phase Shif		
		MVA	Prim. kV	Sec. kV	%Z	X/R	+5%	-S%	%Tol.	Ptun.	Set.			
T1		63.000	220.000	66.000	12.70	45.00	0	0	0	0	3.750	11.5000	Dyn 0.000	
T1		63.000	220.000	66.000	ILSO	-5.00	0	0	0	0	M15	11.5000	Dyn 0.000	
T3		6.000	220.000	66.000	1ASE	45.00	0	0	0	0	(1.6)S	U.5000	Dyn 0.000	
T4		10.000	66.000	11.000	S.35	11.00	0	0	0	0	0	8.3700	Dyn 0.000	
TS		10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	Dyn 0.000	
T6		10.000	66.000	11.000	10.00	10.00	0	0	0	0	1.150	10.0000	Dyn 0.000	
T7		11.000	66.000	66.000	S.35	11.00	0	0	0	0	-1.150	0	8.3500	YNd 0.000
TS		10.000	11.000	66.000	8.3S	13.00	0	0	0	0	-1.150	0	8.3500	VNd 0.000
T9		10.000	66.000	11.000	2SS	13.00	0	0	0	0	4.315	8.3500	Dyn 0.000	
T10		10.000	66.000	11.000	8.35	11.00	0	0	0	0	-3.75	8.3500	Dyn 0.000	
T11		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	Dyn 0.000	
T12		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	10.0000	Dyn 0.000	
T13		10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	8.3700	Dm 0.000	
TU		10.000	66.000	11.000	8.35	U.00	0	0	0	0	0	8.3700	Dyu 0.000	
TIS		10.000	66.000	11.000	8.35	13.00	0	0	0	0	0	3.730	8.3700	Du 0.000
T6		10.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	Dyu 0.000	
T7		20.000	66.000	11.000	10.00	10.00	0	0	0	0	0	10.0000	Dyn 0.000	
TIS		10.000	66.000	11.000	20.00	0	0	0	0	0	3.750	10.0000	Dy11 0.000	
T19		20.000	66.000	11.000	10.00	20.00	0	0	0	0	0	3.750	10.0000	D-E 0.000
no		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.1500	YNd 0.000	
n1		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.1500	YNd 0.000	
n2		3.000	0.400	11.000	6.15	6.00	0	0	0	0	0	6.2700	VNd 0.000	
TZ3		3.000	0.400	11.000	6.15	6.00	0	0	0	0	0	6.2700	VNd 0.000	
T1		MOO	0.400	11.000	6.15	6.00	0	0	0	0	0	6.2700	VNd 0.000	
ns		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.1500	VNd 0.000	
T26		3.000	0.400	11.000	6.25	6.00	0	0	0	0	0	6.2700	VNd 0.000	

2-Winding Transformer Grounding Input Data

Transformer	ID	Rating				Conn.			Primary:		Secondary			
		MVA	~	~	~	Tn,<	k.Y	~	~	~	2	kV	Amp	Olum
T1		63.000	220.000	66.000	Dil						Solid			
n		ssnee	no.000	66.000	Dil!						Solid			

Project: MASTER THESIS
 Location: HOUN CITY-LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SANDI WSTAF A AL-REF AI
 File-name: HOUN\SUBSTATION220kV

ETAP
 12.6.0H
 Study Case: TS

Page: 7
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

2-Windfu "Transformer Grounding" Input Data

Transformer	ID	Rating	Conn.	Grounding				Secondary
				Tir<	R	~	-211	
T3	63.000	210.000	66.000	Off			Solid	
T4	1MOO	66.000	11.000	Dil'			Solid	
TS	20.000	66.000	11.000	Dil'			Solid	
T6	20.000	66.000	11.000	Dil'			Solid	
T7	IZ.800	11.000	66.000	Dil'			Solid	
ta	12.800	11.000	66.000	DIY			Solid	
T9	10.000	66.000	11.000	Dil'			Solid	
T10	10.000	66.000	11.000	Dil'			Solid	
T11	20.000	66.000	11.000	DIY			Solid	
T11	20.000	66.000	11.000	Dil'			Solid	
T13	10.000	66.000	11.000	Dil'			S.Ud	
T14	10.000	66.000	11.000	Dil'			Solid	
T15	10.000	66.000	11.000	Dil'			Solid	
T16	20.000	66.000	n.ooo	DIY			Solid	
T17	20.000	66.000	11.000	Dil'			S.Ud	
T18	20.000	66.000	11.000	Dil'			Solid	
T19	20.000	66.000	11.000	DIY			Solid	
no	3.000	MOO	11.000	Dil'			S.Ud	
T11	3.000	MOO	11.000	Dil'			Solid	
T22	3.000	0.400	11.000	DIY			Solid	
T23	3.000	0.400	11.000	Dil'			Solid	
T24	3.000	0.400	11.000	Dil'			Solid	
T25	3.000	MOO	11.000	DIY			Solid	
T26	3.000	0AO0	11.000	Dil'			Solid	

Project: oL.SITR THESIS
 Locatlen: HOUN(UV - LIBYA
 Contract: EAREAST U\IVERSITY-EEE Department
 Engineer: SAI'D,WSTAFAAL-R.IFAI
 filename: HOUNSUBSTATION220kV

ETAP
 12.6.0H
 Study Case: TS

Page: 8
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGESCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Branch Connections

ID	Type	Connected Bus ID		% Impedance, Pos. Seq., 100 kVA Base			
		From Bus	To Bus	R	X	Z	Y
T1	IWXF!!R	Bus1	Bus1	0.46	20.58	20.9	
T1.	IWXf!!R	Bus1	Bus1	0.44	19.96	19.97	
T3	IWXFA1R	Bus2	Bus1	0.44	19.96	19.97	
T4	2WXF!!R	Bus2	Bus6	6.40	83.15	83.50	
T5	2WXFMR	Bus7	Bus9	1.50	49.94	50.00	
T6	2WXF!!R	Bus8	Bus10	1.53	50.56	50.63	
T7	2WXFAIR	BusU	Bus11	5.06	65.77	65.97	
TS	2WXF!!R	Bus1	Bus12	5.06	65.77	65.97	
T9	IWXf.MR	Bus3	Bus8	6.68	6.90	81.15	
TIO	ZWXF!!R	Bus4	Bus6	6.65	M.90	S1.15	
TU	ZWXF!!R	Bus17	Bus9	1.50	49.94	50.00	
TU	ZWXDitR	Bus18	Bus20	1.50	49.94	50.00	
T13	2WXE!!R	Bus11	Bus11	6.40	83.15	83.50	
TU	ZWXF!!R	Bus23	Bus8	6.40	\$3.25	83.50	
TIS	IWXE!!R	Bus24	Bus16	6.64	6.38	86.63	
TJ6	2VXF!!R	Bus27	BusZS	1.51	50.15	50.31	
TI7	IWXFMR	Bus27	Bus29	1.51	S.15	50.31	
TIS	zw.XFMR	Bus30	Bus31	1.59	51.81	51.88	
T19	IWXF!!R	Bus131	Bus133	2.59	51.81	51.88	
no	IWX!!M	Bus41	Bus41	34.25	205.50	208.33	
T1!	IWXE!!R	Bus35	Bus41	34.25	205.50	208.43	
T22	IWXn!!R	Bus36	Bus31	34.25	205.50	208.33	
T13	IWXE!!R	Bus17	Bus11	34.25	100.0	208.33	
T1*	2WXFMR	Bus18	Bus41	34.25	205.50	208.33	
TSS	IWXFMR	Bus19	Bus12	34.25	205.50	208.33	
T16	?WXFMR	Bus40	Bus17	34.25	105.50	208.33	
Cab1tl	Cable	Bndl	Bus2	0.01	0.01	0.03	0.0716998
Cab1t2	Cable	Bus1?	Bus1	0.01	0.01	0.03	0.016998
Line1	Liu.	Bus1	BusU	~48	16.58	16.17	0.2607619
Line1	Liu.	Bus1	Bus13	2.48	15.16	15.36	OJ8J1267
Line3	Liu.	Bus2	Bus8	1.96	18.06	18.30	0.3381157
Liu..1	Un..	Bus21	Bus11	1.93	11.18	11.94	0.2%09015
Line5	Liu.	Bus1	Bus27	1.03	6.15	6.37	0.1178U
Liu.6	Liu.	Bus1	Bus1	as1	3.U	3.18	0.0589071
Liu.1	Liu.	Bus1	Bus5	0.51	3.U	3.18	0.05\$9071
Lin.8	Liu.	Bus1	Bus7	0.51	3.U	3.18	0.05\$9071
Uii.9	Un.	Bus1	Bus8	0.51	3.U	3.18	0.0589071

Project: IL\Si:R THESIS ETAP Page: 9
 Location: HOUN LIBYA 12.6.OH Date: 28-06-2016
 Contract: NEAREASTUNIVERSITY-EEE Department SN:
 Engineer: SA!l>h!USTAFAAL-REFAI Revision: Base
 Filename: HOUN SUBSTATION220kV Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Ckt/Busbar			Connected Bus ID		% Impedance, Pos. Seq., 100 MVA Base			
ID	Type	From Bus	To Bus:		R	X	Z	y
Lindo	Lin.	BusI	Bus.II		1.03	6.28	6.37	0.1178141
Lin.11	Line	BusI	Bus30		1.03	6.28	6.37	0.1178142
Linell	Lin.	BusI,17	Bus21		1.70	16.49	16.71	0.3092622
Lin <i>i</i>	Lin.	BusI,7	BusI,3		20.70	126.43	115.11	2.3710100
Lin <i>d</i>	Line	BusI,21	BusI,9		18.00	109.9	111.0	1.0617480
SW1	TieSmtch	BusI	BusI					
SW2	TieSmtch	BusI,7	BusI,8					
SW3	TieSmtch	BusI,I	BusI,U					
SW4	TieSmtch	BusI,17	BusI,S					
SW5	TieSmtch	BusI,23	Bus24					
SW6	TieSmtch	BusI,S	Bus26					
SW7	Tie Smtch	Bus28	BusI,9					
SWS	TieSmtch	BusI,0	BusII					
SW9	Tie Smtch-h	BusI,?	BusU					
SW10	TieSmtch	BusI,11	BusI,42					

Project: AL-SIER TIIIE-IS ETAP Page: 10
 Location: HOUNnn LIBYA 12.6.OH Date: 2s-or;2016
 Contract: NEAR EAST UNIVERSITY-EEE Department SN:
 Engineer: SANDY USIMAAL-REFAI R'slon: Base
 Filename: HOUN SUBSTATION220kV Config: Nonnal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM IN LIBYA. IMPACT ANALYSIS OF ITS INTEGRATION IN POWER GRID

Branch Connections
Zero Sequence Impedance

Circuit/Bus	ID	Type	Connected Bus ID		%Impedance, Zero Seq., 100 J/YAb			
			Frem Bus	To Bus.	RO	XO	ZJ	VO
T1	IWXFMR	Bus3		Bus1				
T2	ZW:XN.m	Bus4		Bus1				
T3	IV:XN.m	Bu\$S		Bu,2				
T4	IWXEhR	Bus1		Bu,w				
TS	IW:i:BR	Bu,7		Bus9				
T6	IWXFlhR	Bu,S		Bus10				
T7	IWXFMR	Bu\$nl		Bus11				
TS	IWXFlhR	Ih'41		Bus11				
T9	IWXFMR	Bu,B		Bu\$ts				
TIO	ZW:XN.m	Bu,14		Bu,16				
rii	ZWXnm	Bu\$17		Bu,19				
TU	2w:xn.m	Bus1S		Bm20				
TU	ZW:xn.m	Bus1!		Bu!l				
T14	ZW"X#AFR	Bu,2!		Bu!5				
TIS	IWXFMR	Bus14		Bu,26				
T16	IW:XN.m	Bu!7		Bus28				
T17	2WXF&R	Bu,27		Bu!9				
TIS	ZWXFlhR	Bu,10		Bu!l				
T19	2WXFMR	Bus1!		Bus33				
no	IW:XN.m	Bu<,4		Bus41				
rn	ZW:Xnm	Bus15		Bus41				
T12	2wxnm	Bus36		Bus41				
T23	IWXFMR	Bus17		Bus41				
T24	ZWXnm	Bus1S		Bus42				
T1S	?WXF!IR	Bu,39		Bu-.f2				
T16	IWXFMR	Bu,40		Bu!1				
C,bld	C.bl*	Bud!		Bud				
Cable?	Cab!*	Bud1		Bud				
Lhel	Lln*	Bus1		BusU				0.0100US
Unt?	Un*	Bud		Bu,U				0IJ41983
Lind	Un,	BuZ		Bus1S				0.I599?5S
Unt-1	Un*	Bus27		Bu,17				0.10~992
Lin,5	Liu*	Bud		Bu'il7				0.0556!63
Lint6	Liu*	Bu1		Bu,7				0.078131
tin,7	Liu,	Bud		Bu,S				0.0781'l

Project: IMASTER THE&IS
 Location: HOUN CHY - LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAJ\DImlSTAFA AL-REFAI
 Filename: HOUNSUBSTATION220kV

ETAP

Page: 11
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

CKr/Brand.			Connected Bus ID		% Impedance, Zero Seq., 100% YAI>			
ID	Type*	From Bus	To Bus		R0	X0	Z0	Y0
Liu,8	Liu,	Bus1	Bus7					0.0Z7SUJ
Liu,9	Liu*	Bus1	Bus8					0.0N8M
Liu,10	Liu*	Bus1	Bus31					0.0526163
Liu,11	Liu,	Bus1	Bus30					0.0556263
Liu,12	Liu*	Bud?	Bn11					0.14601S9
Liu,13	Liu,	Bu,17	Bn,23					1.1194780
Liu,14	Liu,	Bus21	Bus8					0.9734595
SW1	TieSmich	Bm1	Bm1					
SW1	Tit-Sltitch	Bu,7	Bus8					
SW3	Til"Smich	Bus13	Bn,14					
SM	TL,Smth	Bus17	Bud8					
SW5	Tie-Slrlkh	Bus1J	Bu<;24					
SW6	Tat-Snitch	Bus25	Bu,26					
SW7	r**sl lit<h	Bus28	Bu,19					
SWB	Ti,Smil<h	Bn,10	Bm					
SW9	TitSutth	Bus32	Bn533					
SW10	TN'Snitch	Bn,n	Bm42					

Project: MASTER THESIS
 Location: HOUN CITY-LIBYA
 Contact: NEAR EAST UU\TURKEY EEE Department
 Engineer: SAWAFI AL-REI'AI
 Filename: HOUN STATION 220kV

ETAP
 12.6.0H
 Study Case: TS

Page: 12
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nominal

DESIGN OF A MEDIUM SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Synchronous Machine Parameters

Machine ID	T-Jit	Modol	Rating MVA kV	Positive Sequence Impedance (%)								Zro S,q Z (%)		
				R.	Xd"	Xd'	Xa	Xq"	Xq'	Xq	XI	XIR	RO	XO
U1 PonnGrid	NIA		Z2.101-120/100	9.95		99.50							38.68	356.48
U2 PonnGrid	NIA		11.101 100;000	9.95		99.50							11.74	111.38
U3 Power Grid	NIA		Z2.101-100/100	9.95		99.50							11.14	111.38

Machine ID	Connected Bus	Time Constants (Sec.)								Generator or Loading			Grounding		
		Tdo"	Tdo'	Tqo"	Tqo'	H	D	J1(Wpu/Hi)	& Saturation	MV	Ifar	Coum.	Type	Amp	
<hr/>															
Winding	Generator/Totor					Coupling				Prime/Load			Equiva-lent	Total	
ID	Type	R1'M	WR	H	RPM	WR'	H	RPM	WR'	H	R1'M	WR	H		

WR: kg-m² H,MW-S0<IMVA

Machine		Shaft Tersten			
ID	Type	DI	DI	KI	KI

DI, D': MW(pu)/Sp.ed (pu) KI, K2: R/W (pu)/Radian

Project: MASII:R THESIS

ETAP

Page: 13

Location: HOUN cm -LIBYA

12.6.0H

Date: 28-06-2016

Contract: I°EAR EAST UNIVERsm - EEE Department

SN:

Enginner: SAND MUSTAFA AL,REFAI

Revision: Base

Filename: HOUN SUBSTATION 220KV

Study Case: TS

Config: Norinal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Lumped Load Input Data

Conventional Type

ID	kV	kVA	kW	Lmpar	~PF	Amp	Load		R.	Gamma
							%Motor	%Sntk		
Lump1	11.000	1243	0	11M	0.01	65.3	80	10	0	0
Lump10	11.000	5581	5000	3098	85.000	308.7	80	10	0	0
Lump11	11.000	3519	3000	1859	85	185.2	80	20	0	0
Lump12	11.000	3529	3000	1859	85	185.1	80	10	0	0
Lump13	11.000	11941	11000	6818	85.000	619.3	80	10	0	0
Lump14	11.000	5883	5000	3099	85.000	308.8	80	10	0	0
Lump15	11.000	1353	1000	1M0	85	123.5	80	10	0	0
Lump16	11.000	8136	7000	4339	85.000	431.3	80	10	0	0
Lump17	11.000	7058	6000	3718	85	370.5	80	10	0	0
Lump18	11.000	7058	6000	3718	85	370.5	80	10	0	0
Lump19	11.000	5500	SSW	0	100	188.7	80	Z0	0	0
Lump20	11.000	3500	3500	0	100	183.7	80	10	0	0
Lump21	11.000	6000	6000	0	100	3U.9	80	10	0	0
Lump22	11.000	2351	1000	1239	85	nas	80	10	0	0

Project: ~IASTER THESIS; ETAP' Page: 14
Location: ROUNC,ITY-LIBYA 12.6.0H Date: 28-06-2016
Contract: I'1:AREASTUNIVERSITY-EEDepal'ment SN:
Engineer: SAND A!USTAFA AL-REFAI StudyCise: TS Revision: Base
Filenamrt: ROUN' SUBSTATION 220KV Config: Normal

DESIGN OF A LARGE SCAU:SOLARPV SYSTEM AND IMPACT ANALYSES OF ITS INTEGRATION INTO LIBYA'S POWERGRID

LQAD.FLOWREPORT<WithPV>, @I=0.000

Bus	Voltage			Generation			Load			Load Flow			XFJ\ffl			
	ID	IN	U:0.000	Mw	Ang.	MW	Pfou	MW	fmf	Bus	ID	MW	Mi-r	Amp	%PF	%Tp
Bus1										Bus13		6.014	3.961	63.8	S3.5	
										Bus7		19.539	1.129	171.3	99.8	
										BusS		J.1S3	1.178	36.6	S3.7	
										Bu.S		3.183	2.278	36.6	83.7	
										Bu-O		10.991	M91	118.1	81.9	
										Bu3		45.161	-18.711	353.3	SS.1	1.750
										Bu-6		0.001	L.248	11.6	O.1	
Bm2	66.000	99.061	-19.0	0	0	0	0	0	Bu.11		(1.8)1	(J.725	S1S	99.1		
									Bud4		MH	3.993	63.7	S3.3		
									Bud8		3.191	11.18	30.9	99.7		
									Bm7		0.994	0.573	JO.I	86.7		
									Bm7		0.994	0.573	10.1	S6.7		
									Bui31		5.027	3.700	52.6	84.4		
									Bu-s		-10.700	-7.365	1U.1	SJ.J	0.618	
*Bus3	110.000	100.000	-35.3	0	0	0	0	0	Bm1		35.W1	2L594	10.0	85.6		
									U1		-35.844	-2U94	110.0	SS.8		
*Bus4	220.000	100.000	0.0	0	0	0	0	0	UZ		0.000	0.000	0.0	0.0		
"Bu-5	220.000	100.000	-17.8	0	0	0	0	0	Bus1		10.708	7.711	34.6	81.1		
									US		-10.708	7.711	34.6	81.1		
Bu.6	11.000	98.343	-3M	0	0	0.000	1.235	1.235	Bud		0.000	LZSS	6.5.9	0.0		
Bu17	66.000	99.036	-19.0	0	0	0	0	0	Bu.2?		Q.994	(J.630	10.4	84.5		
									Bu\$2		(J.994	(J.630	10.4	84.5		
									Bu.1?		1.985	1.160	20.8	84.5		
Bu.8	66.000	99.297	J9.6	0	0	0	0	0	Bud		3AS1	Z.330	36.9	83.1		
									Bus1		-3.482	-4.110	36.9	SS.1		
									Bud 0		6.964	4.661	73.8	83.1		
Bus9	11.000	98.356	-19.6	0	0	1.987	1.232	Bus7		J.987	-1.132	124.8	BS.0			
BicIO	11.000	98.048	-11.6	0	0	6.946	4.305	Bu.S		~.946	-4.305	31.8	BS.0	1.250		
Bud!	66.000	99.061	-19.0	0	0	0	0	0	Bus1		SSN	0.6.<1	51.7	99.1		
									Bu-1?		-5.SU	(J.654	51.7	99.4		
Bud?:	66.000	99.390	-39.5	0	0	0	0	0	Bud		7.754	0.306	Q1.3	99.9		
									Bu>ll		7.754	(J.306	68.3	9M		
Bu13	66.000	98.615	-10.0	0	0	0	0	0	Bu1		6.011	-LM1	64.8	SZ.2		
									Bud5		6.011	4.161	6-1.8	SZ.2		
B"44	66.000	98.224	-19.5	0	0	0	0	0	Bu.l		~.001	-1.157	65.0	S2.1		
									Bud6		6.001	,1S1	65.0	S1.Z		

Project: J.L.,STER. THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR EAST UNIVERSITY -EEE Department
 Engineer: SAND IWSTAF A AL-REFAI
 Fileunme: HOUN Str'BSTATION 220kV

ETAP 12.6.0H
 Page: 15
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nominal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

LOAD FLOW REPORT ON PV @ T = 0.000

Bus	ID	kV	Voltage		Generation		Load		ID	Load Flow			Xf/R	
			%Mag.	Ang.	MW	Mvar	MW	Mvar		Mvar	Mvar	Amp	%PF	
Bus\$		11.000	98.933	~	-0	-0-	5.707	3.103	Bus3	-1.978	-3.703	11.85	85.0	j.378
Butl6		11.000	95.561	-22.4	0	0	5.968	3.697	Bu,U	-5.968	-3.691	373.7	BS.0	4J78
Busl7		66.000	99.192	.u.1	0	0	0	0	Bus27	-13.187	1.837	121.5	97.9	
									Bu21	M09	J.3.1	S9.5	-98.0	
									Bu23	1.191	-1.657	19.1	-64.1	
									Bu,19	5.486	E.188	48.4	100.0	
Bu,18		66.000	98.913	.19.1	0	0	0	0	Bu1	J.487	-0.042	30.8	!OM	
									Bu,10	3.187	0.061	30.8	100.0	
Bus19		11.000	99.016	.u.8	0	0	5.478	0.000	Bu,17	-5.478	0.000	290.1	100.0	
Bus 0		11.000	98.870	-IM	0	0	3.484	0.000	Bu,18	-3.484	0.000	185.0	100.0	
Bus11		66.000	99.115	.u.9	0	0	0	0	Bu17	-6.597	1.1e1	59.0	-98.6	
									Bu,13	0.604	-U09	13.8	J9.4	
									Bus?	S.992	0.101	52.9	99.9	
B"21		11.000	98.700	.u.8	0	0	5.969	0.000	Bu,n	-5.969	0.000	317.4	100.0	
Bus13		66.000	99.545	-11.3	0	0	0	0	Bus7	-1.187	-0.656	13.5	90.4	
									Bu,11	0.603	-U1U	7.6	69.6	
									Bu1S	1.990	1.178	20.8	84.1	
Bus15		11.000	98.160	--2	0	0	1.987	1.1n1	Bu,13	-1.987	-1.231	124.7	85.0	
Bu-21		66.000	99.119	-10.1	0	0	0	0	Bus7	13.524	-1.826	U1U	-91.9	
									Bud	-IM!!!	-1.001	17Lk	99.9	
									Bu28	1.988	UU	31.1	84.2	
									Bu,49	1.988	1.914	31.3	84Z	
Bus18		11.000	98.703	-IIJ	0	0	1.984	1.840	Bus7	-1.184	-1.850	186.7	85.0	0.615
Bus19		11.000	98.703	-IJ.1	0	0	1.984	1.850	Bus7	-2.98	-1.850	156.7	SS.0	0.625
Bus30		66.000	95.787	.J9.9	0	0	0	0	Bud	-10.973	-7.693	118.7	SU	
Bu31		66.000	98.502	-It.1	0	0	0	0	Bu1Z	-5.023	J.19.2	S3.1	SM	
									Bu33	S.011	3.191	53.1	83.6	
Bus31		11.000	98.316	-IM	0	0	10.927	6.773	Bu,30	-10.927	-6.713	686.2	85.0	3.750
Bus33		11.000	100.68!	-lb.ti	0	0	5.0U	3.108	Bus1	S.014	J.108	307.8	85.0	3.750
"Bus34		0.400	100.000	-34.1	0	0	0	0	Bu-fl	1.960	O.MS	283.1	99.1	
									In,1	0.980	-0.129	1426.6	99.1	
									hl,4	W1SO	0.119	UIM	99.1	
"Bus35		0.400	100.000	.u.1	0	0	0	0	Bu41	1.160	0.158	2853.1	99.1	
									hl,8	0.980	0.119	1416.6	99.1	
									hl,T	0.980	-0.129	UIM	99.1	
Bus36		0.400	100.000	J.j.8	0	0	0	0	Bu41	1.960	0.158	IW.2	99.1	

Project: JUSTER THESIS
 Location: HOUN CITY LIBYA
 Contract: NEAR EAST UNIVERSITY EEE Department
 Engineer: SAND MUSTAFA AL-REF AI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H

StudyCase: TS

Page: 16
 Date: 23-06-2016
 SN:
Revision: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

LOADFLOW REPORT Qwith PV @ T = 0.000

Bus	ID	Voltage	Gene-ration	Load	ID	ad. Flow	Xf11R							
							kV	%Mv	Ang.	MW	Mvar	LAV	Mvar	MW
*Bu-37		MOO	100.000	-~.3	Iodo					-LJ50	-M19	141M	99.1	
					lno1					-M80	-0.129	W6.6	99.1	
					Bn-ell					1.960	(.258	1853.1	99.1	
					Inr12					1.960	-0.980	-UI9	141M	99.1
					Inr91					1.960	-0.980	0.M	142M	99.1
*Bus38		MOO	100.000	-14.8	Io90					1.960	0.378	1880.8	98.1	
					Io-89					-MS0	.0.189	1440A	98.2	
"Bm39		0.400	100.000	-14.5	Io-86					1.960	0.378	1880.8	98.1	
					Bu'4Z					1.960	0.980	(.1119	1440.4	98.2
					lm'S7					1.960	0.119	1440.4	98.2	
					Io-86					1.960	0.189	WM	98.2	
*Bu-10		0.400	100.000	-us	Bn'2					1.960	0.378	1880.8	98.1	
					Jud Ol					1.960	-0.119	1440.4	98.2	
					IorU					1.960	0.189	WM	98.2	
Bm.tl		11.000	98.871	-36.6	BnsU					7.786	0.711	415.0	99.6	
					Bndt					-1.946	-0.178	103.8	99.6	
					Bu35					-1.946	-0.178	103.8	99.6	
					Bm36					-1.946	-0.178	103.8	99.6	
					Bum					-1.946	-0.178	103.8	99.6	
Bus42		11.000	98.630	-16.8	Budl					5.838	0.887	314.1	98.9	
					Bn&					-1.946	-0.296	104.8	98.9	
					Bu-39					-1.946	-0.296	IOU	98.9	
					BuwO					-1.946	-0.296	104.8	98.9	
u1		110.000	162.107	0.0	43.747	100.727	0	0	Bu'3	43.747	100.717	-110.0	39.8	
u1		ZZ0.000	100.000	0.0	0	0	0	0	Bu'4	0.000	0.000	0.0	0.0	
u1		:20.000	146.534	0.0	Jl,49!	15.880	0	0	BucS	11.491	15.550	34.6	59.4	
Inr2		0.400	160.800	-37.1	1.584	0.129	0	0	Bu34	1.584	0.129	WM	99.7	
Io,4		0.400	160.800	-37.1	1.584	0-IZ-	0	0	Bu'4	1.584	W9	1416.6	99.1	
Inx8		0A00	160.800	-37.1	1.584	0.129	0	0	Bu\$3\$	1.584	0.129	Ul6.6	99.7	
In,7		B400	160.800	-~1.1	1.584	0.119	0	0	Bm,15	1.584	0.129	1426.6	99.7	
Io,10		0.400	160.800	-37.1	1.584	0.119	0	0	Bu'66	1.584	0.129	HM.6	99.1	
In,~		0.400	160.800	-37.1	1.584	0.119	0	0	Bu'66	1.584	0.129	1426.6	99.7	
Io,11		D400	160.800	-37.1	1.584	OJ29	0	0	Bu37	1.584	0.129	1416.6	99.7	
Ind!		0A00	160.800	-37.1	1.584	0.119	0	0	Bu-7	1.584	0.129	Ul6.6	99.1	
Inr90		D400	161.026	-18.7	1.S96	0.189	0	0	Bu38	1.584	0.189	1440.4	99.3	
Inr19		0A00	161.016	-18.7	1.S96	0.189	0	0	Bu38	1.584	0.189	W0.4	99.3	
In,87		0.400	161.016	-18.7	1.S96	0.189	0	0	Bm39	1.586	0.119	1440.4	99.3	

Project: IL-STER THESIS
 Location: HOIIN CITY- LIBYA
 Contrarr: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND MUSTAFAAL-REFAI
 Filename: HOUN' SUII STATION220kV

ETAP

12.6.0H

Page: 17
 Date: 28-06-2016
 SN:
 R.dfl: Base
 Conflg: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

LOAD FLOW REPORT OVERVIEW @ I = 0.000

Bus	Voltage			Generation		Load		ID	Load Flow			XFMR	
	ID	KV	% Avg.	Avg.	MW	Mvar	MW	Mvar	MW	%frar	Amp	%PF	
Inv86		0.400	161.026	-18.7	1.596	0.189	0	0	Bus39		1.596	0.189	1440.4 99.3
Inv102		0.400	161.026	-18.7	1.596	0.189	0	0	BOHO		1.5%	0.189	1.400J 99.3
Inv14		0.400	161.016	-18.7	1.596	0.189	0	0	Bus-10		1.596	0.189	1440J 99.3

* Indicates a "Voltage regulated bus (voltage controlled or having "YP" machine connected to it)

indicates a bus with a load mismatch higher than 0.1MVA

Project: ALISTER THESIS
 Location: HOUN CTTY LIBYA
 Contract: NEAR-EASIU!<IVER.5IY EEE Department
 Engineer: SAID IWSIAAAL-REFAI
 Filename: HOUN SUBSIDIATION220KV

ETAP

12.6.0H

StudCase: TS

Page: 1S
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Non.nal

DESIGN OF A L4.R."E SCALE SOLAR PV SYSTEMA'D IMPACT ANALYSIS OF IS INTEGRATION INTO LIBYA;"POWERGRID

LOAD FLOW REPORT (With EV1@ T=0.800)

Bus	ID	KV	Voltage		Generation		Load		ID	Load Flow			XFMR	
			% Mdg.	Ang.	MW	MWhr	MW	hhr		Srw	Mm	Amp		
Bus1			~000	~111.47	0	0	0	0	Bus1	7.14!	4.264	31	85.9	
									Bus3	23.005	-LS5!	148.4	99.1	
									Bus8	4.105	2,563	31.0	84.8	
									Bus8	4.105	2,563	31.0	84.8	
									Bus30	13,023	S.W	99.8	83.5	
									Bus3	46.971	-16.83	318.2	94.6	
									Buw	0.001	1A61	9.4	0.1	
Bus2			~000	99.061	-19.0	0	0	0	0	Bm1	-5.821	0.725	S1S	99.1
									Bud-1	MU	3.993	61.7	83.3	
									Bu18	3.491	.248	30.9	97.7	
									Bus7	0.994	0.573	10.1	86.7	
									Bm7	0.994	0.573	121	86.7	
									Bu-n	5.077	1,100	52.6	84.4	
									Buf	10.100	-J.365	114.7	SI,4	
Bm3		Z20,000	134,501	J5.z	0	0	0	0	0	Bud	47.014	19.109	99.1	92.6
									U1	47.014	-19.109	99.1	91.6	
Bu-i		10,000	100,000	0.0	0	0	0	0	0	UZ	0.000	0.000	0.0	0.0
Bus5		ZZ,000	100,000	-17.8	0	0	0	0	0	Bus1	10,708	7.711	34.6	81.1
									U3	-10,708	-7.711	11.6	SU	
Buw		11,000	US.756	JS.1	0	0	0.000	1,453	Bus1	0.000	1.453	56.2	0.0	
Bus7		66,000	99,036	-19.0	0	0	0	0	0	Bus1	-0.994	-0.630	10.4	84.5
									Bus1	-0.994	(0.630	10.1	84.5	
									Bus9	1,989	1,260	20.8	84.8	
Bu.S		66,000	136,512	JS.z	0	0	0	0	0	Bud	4.105	-2,669	31.4	83.8
									Bm1	-ues	Z-SI	11.4	83.8	
									Bus10	8.109	5,337	61.7	83.8	
Bus9		11,000	98,356	-19.6	0	0	1,987	1,231	Bus7	-1.987	-U31	124.8	85.0	
Bus10		IL,000	136,181	-0.5	0	0	8,196	S.080	Bus8	-8.196	~.080	371.7	85.0	
Bus11		~000	99,062	-19.0	0	0	0	0	Bus1	5.81	MS4	51.7	99.1	
									Bus1	5.81	-0.654	51.7	99.1	
Bus11		66,000	136,648	-38.1	0	0	0	0	Bm1	U10	0.150	18.1	99.9	
									B"41	4,410	-0.150	18.2	99.9	
Bu.1.U		66,000	116,017	JS.5	0	0	0	0	0	Bud	-7.13!	-17.14	55.1	S1.3
									Bus1	7.112	4.714	55.1	83.1	
Bud.1		~000	98,17.1	-19.1	0	0	0	0	0	Bus?	~.001	4,157	6.~0	8Z.J
									Bus.16	6,001	4,157	65.0	SL.?	

Project: IL-1-STER THESIS
 Location: HOUN (TLY) LIBYA
 Contract: NEAR EAF-TUNIVER&TLY -EEE Department
 User: SAND WST.4JA AL-REFAI
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0FJ

Page: 19
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

LOAD FLOW REPORT With PY @ T=0.800

Bus	Voltage			Generation		Load		ID	Loadflow			XFB	
	ID	kV	% M.g.	Ang.	SfW	Mvar	XfW	M, Vr	AnV	M, ar	Amp	PF	
Bus1		11.000	136.660	-70.0	-0	-0	-	To ~	Bus3	710f	~	316.5	"ru "7.7m
Bud 0		11.000	98.564	-1M	0	0	S.965	J.697	Bm14	-5.965	-3.697	373.7	SSE 4.375
Bus17		-0.000	136.1196	-39.1	0	0	0	0	Bu-17	-11.901	7.046	111.1	-91.4
									Bus11	7.790	-1.462	SU	-91.4
									Bm13	1.645	J.-695	IS.S	-40.7
									Bud9	M66	E.111	41.1	100.0
Bu.18		-0.000	98.973	-19.1	0	0	0	0	Bu18	J.187	-0.061	30.8	100.0
									Bus10	3.487	(1.162)	30.8	100.0
Bus9		11.000	136.888	-40.1	0	0	M60	0.000	Bud?	-6.460	0.000	247.8	10.0
Bus10		11.000	98.870	-20.4	0	0	3.484	0.000	Bu.18	3.184	0.000	ISM	100.0
Bu.21		66.000	137.ZUJ	-39.7	0	0	0	0	Bu17	-7.780	2.94.1	SJ.O	-93.5
									Bus3	0.716	J.163	20.7	.U.1
									Bus11	7.064	0.2;21	J.51	100.0
Bu-1		11.000	136.831	-41.5	0	0	7.047	0.000	Bus1	-7.047	0.000	170.3	100.0
Bus3		-0.000	138.115	-40.0	0	0	0	0	Bu17	-1.640	-0.159	11.1	90.8
									Bus11	-0.714	-0.733	6.5	69.8
									Bu25	1.3.5.C	1.191	17.6	84.8
Bus25		11.000	138.111	-40.5	0	0	1.351	1.457	Bus23	Z..1S1	-US7	105.9	S.,0
Bus27		-0.000	136.604	-38.6	0	0	0	0	Bnd7	IS.933	-7.267	II.2.I	-91.0
									Bud	-22.975	2.813	III.2	-3.
									Bu28	J.m	2.IZ7	26.7	84.8
									Bud9	3.52]	2.127	Z.6.I	SES
Bus18		11.000	136.580	J9.2	0	0	1.519	1.181	Bu17	-J.519	-2.181	159.1	S.,0 MIS
Bus29		11.000	136.580	-39.1	0	0	3.519	2.181	Bud?	-J.519	-0.1S1	159.1	SS.0 0.62-
Bus30		66.000	136.151	-38.4	0	0	0	0	Bud	-13.009	-3.704	100.6	83.1
Bus11		-0.000	98.802	-19.1	0	0	0	0	Bu-1	-S.023	-3.292	53.1	83.6
									Bu33	S.023	3.292	53.2	83.6
Bw31		11.000	137.781	-40.4	0	0	U.976	8.0.U	Bu-0	-12.976	-3.0441	581.6	85.0 3.750
Bus11		11.000	100.682	-40.6	0	0	S.OU	3.105	Bu31	-5.014	-3.108	307.5	85.0 3.760
Bus14		0.400	136.865	-3M	0	0	0	0	Buw1	1.106	0.068	1179.8	99.8
									Bud	-0.514	-0.0-	589.9	99.8
									Bu4	-0.533	-0.0-	589.9	b1.8
Bu35		0.400	B5.S6S	JM	0	0	0	0	Bu41	1.106	0.068	1179.8	99.8
									Bu8	-0.553	-0.0-	589.9	99.8
									Bu7	-0.553	-0.034	589.9	b1.8
Bu36		0.400	135.565	J6.6	0	0	0	0	Bu141	1.106	0.068	1179.8	99.8

Project: MASTER THESIS
 Location: HOUN' CTY - LIBYA
 Contr-ct: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SAND IIDSTAF AAL-REFAJ
 Filename: HOUN SUBSTATION 220kV

ETAP
 12.6.0H
 Study Case: TS

Page: 20
 Date: 28-06-2016
 SN:
 Rejissou: Base
 Config: Normal

DESIGN OF ALARGE SCALE SOLARPV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATIONINIO LIBYAI< POWER GRID

LOAD FLOW REPORT QWith PJ, @T = 0.800

Bus	ID	KV	Angle	Voltage		Generation		Load		ID	AIW	frmr	Ainp	%PF	%Top	XFMR
				Mw	Mvar	Mw	Mvar	Mw	Mvar							
Ind 0																
Bus37	0.100	100.000	-36.6	0	0	0	0	0	0	Id.9	-0.5<3	-0.03-1	589.9	99.8		
										Bu.41	1.106	0.068	1179.8	99.8		
										tn.11	-~58.~	-0.03-1	589.9	99.8		
										lm.11	-~5.3	-~0.034	589.9	99.8		
Bu.38	0.400	100.000	-14.5	0	0	0	0	0	0	Bu.42	1.960	0.378	2880.8	98.2		
										Im.90	-0.980	-~189	1440.4	98.2		
										Im.89	-0.980	-~189	1440.4	98.1		
Bus39	0.100	100.000	-14.5	0	0	0	0	0	0	Btu42	1.960	0.378	2880.8	98.1		
										Im.87	-~0.980	-D.189	1440.4	98.1		
										In.86	-0.980	-~189	1440.4	98.1		
Bu.40	0.100	100.000	-14.5	0	0	0	0	0	0	Bu.44	1.960	0.378	ISS0.8	98.2		
										ln.10!	-~0.980	-~189	1440.4	98.2		
										ln.14	-~0.980	-~189	1440.4	98.2		
Bu.41	11.000	135.192	-37.3	0	0	0	0	0	0	Busl2	4.418	O.119	17U	99.9	-USO	
										Bu.4	-1.104	-~0.055	42.9	9M		
										Bu.35	-1.104	-0.055	41.9	99.9		
										Bus36	-1.104	-~0.055	41.9	99.9		
										Bu.7	-1.104	-~0.055	42.5	99.9		
Bus42	11.000	98.610	-16.8	0	0	0	0	0	0	Bud!	5.038	0.087	314.3	98.9	-L150	
										Bu.38	-1.946	-~196	104.8	98.9		
										Bw.39	-1.946	-0.296	104.8	98.9		
										Busl0	-1.946	-~196	104.8	98.9		
U1	220.000	262.107	e.e	Sl.448	83.215	0	0	0	0	BusJ	\$~148	8.1.m	99.1	~0		
U2	110.000	100.000	o.o	o	0	0	0	0	0	Busl	0.000	0.000	o.o	o.o		
U3	110.000	U6.64	o.o	IU91	15.550	0	0	0	0	OB~	11.492	15550	31.6	59.4		
Ind	0.400	160.800	.57.1	o.656	0.034	0	0	0	0	Bu'34	0.656	0.034	589.9	99.9		
Inr4	0.100	160.800	-37.1	0.656	0.034	0	0	0	0	Bu~1	0.656	0.034	589.9	99.9		
Inr5	0.400	160.800	J7.1	0.656	0.034	0	0	0	0	Bus35	0.656	0.034	589.9	99.9		
Inr7	MO0	160.800	J7.1	0.656	0.034	0	0	0	0	But38	o.656	0.034	589.9	99.9		
Inr10	0.400	160.800	-37.1	0.656	0.034	0	0	0	0	Bu.36	MS-S	0.034	589.9	99.9		
Inr11	0.100	160.800	-37.1	0.656	0.034	0	0	0	0	BusJ6	MS-S	0.034	589.9	99.9		
Ind2	0.100	160.800	J7.1	MS-S	0.0J1	0	0	0	0	BusJ7	0.656	0.034	589.9	99.9		
Inr91	0.100	160.800	J7.1	0.656	0.0J1	0	0	0	0	BnsJ7	0.656	0.034	589.9	99.9		
Inr90	0.400	161.016	-18.7	L.S96	0.189	0	0	0	0	Bu38	1.596	0.189	1440.4	99.3		
Inr89	0.100	161.026	-11.7	1.596	0.189	0	0	0	0	BusJS	1.596	0.189	1440.4	99.3		
InrS7	0.100	161.026	-18.7	L.S96	0.189	0	0	0	0	Bm39	1.596	0.189	1440.4	99.3		

Project: MASTER THESIS ETAP Page: 21
Location: HOUN' GUY- LIBYA 12.6.0H Date: 28-06-2010
Contract: NEAR EAST UNIVERSITY - EEE Department SN:
Engineer: SANDMUSTAFAAL-REFAI Stud/Qise: TS Mission: Base
Filename: HOUN SUBSTATION 220kV Config: Nonnnl

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

LOAD FLOW REPORT QVjth_P\1@T=0.800

Bus	Voltage			ne-ration		Load		Load Flow				XFMR		
	ID	kV	% Ifag.	Aug.	MW	Mvar	MW	Ifarr	ID	MW	Ifarr	Amp	% PF	% Tap
Inv86		0.400	161.026	-18.7	1.596	0.189	0	0	Bus39	~	~	1.717	Or-;	-;
Ind Ol		0.400	161.026	-18.7	1.596	0.189	0	0	Bus10	1.596	0.189	Wo.4	99.3	
In\14		MOO	161.026	-18.7	L596	0.189	0	0	Bu<40	1.596	0.189	1440.t	99.	

* Indicates a voltage regulated bus (voltage controlled or main type machine connected to it)

iudiclltt-sa bu,: uitb a JOldmlnnate-het mere tb.'la 0.1 IfFA

Project: IIASTI:R THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR EAST UNIVERSITY - EEE Department
 Engineer: SA: NO 2: WSTAF A AL-REF AI
 Filename: HOUNSUBSTATION 220kV

ETAP
 12.6.0H
 Page: 22
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV 51: SIEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER CSM

LOADFLOW REPORT (QV)@T=1.000

Bus	Voltage			Generation		Load		ID	Load Flow			X:1[R]
	ID	SV	Ott.Mag...	MW	M.u.	MW	Ifar		MW	M,ar	Amp	
Bu.1		90.0	0.0	0.0	0.0	0.0	0.0	Bu.1	0.000	0.000	IU7	0.0
								Bud3	0.000	0.000	0.0	0.0
								BmZ7	0.000	0.000	0.0	0.0
								Bu.8	0.000	0.000	0.0	0.0
								Bu.8	0.000	0.000	0.0	0.0
								Bu.10	0.000	0.000	0.0	0.0
								Bu.33	0.000	MOO	468.0	0.0
								Bu.34	0.000	0.000	0.0	0.0
Bu.1	6/1.000	1.9	59.9	0	0	0	0	Bud1	0.00	0.14	131	5.5
								BudU	0.605	0.003	1.9	8.14
								Bud8	0.003	0.000	0.9	.99,1
								Bu.7	0.001	0.000	0.5	86.7
								Bu.7	0.001	0.000	0.3	SM
								Bu.31	0.005	0.003	M	84.3
								Bu.1	0.010	M37	129.1	2.1
81153	220.000	11.012	43	0	0	0	0	Bus1	0.136	6.110	US.7	2.1
								U1	-0.136	-6.110	w.1	2.1
Bus4	220.000	100.000	0.0	0	0	0	0	tn	0.000	0.000	0.0	0.0
Bu.5	220.000	0.000	90.0	0	0	0	0	Bu.11	0.000	0.000	39.0	0.0
								UJ	0.000	0.000	8!0	0.0
Bu.6	11.000	0.000	90.0	0	0	0	0	Bud	0.000	0.000	0.0	0.0
Bu.7	66.000	1963	59.11	0	0	0	0	B112	0.001	0.001	03	84.5
								Bu.2?	0.001	0.001	M	S1S
								Bu.1>	0.001	0.001	0.6	84.S
Buss	~0.000	0.000	90.0	0	0	0	0	Busl	0.000	0.000	0.0	0.0
								Busl	0.000	0.000	0.0	0.0
								Bull0	0.000	0.000	0.0	0.0
Bu.9	11.000	1943	59\$	0	0	0.002	0.001	Bu.7	-0.00?	.001	3.6	85.0
Bu.10	11.000	0.000	90.0	0	0	0	0	Bu.5	0.000	0.000	0.0	0.0
Bu.11	6/1.000	1961	59.11	0	0	0	0	Busl	0.015	0.445	1313	5.6
								Bu.W1	0.028	OMS	UI,\$	S.6
Bus11	~0.000	0.0DS	S.S	0	0	0	0	Busl	0.001	0.001	174.7	65.8
Bus13	~0.000	0.000	90.0	0	0	0	0	Busl	0.000	0.000	0.0	0.0
								Bull5	0.000	0.000	0.0	0.0
BusU	~0.000	1.1140	59.4	0	0	0	0	Bu.11	0.005	0.004	1.9	S2.3
								Bu.16	0.008	0.004	1.9	81.3

9Tl	896?L	681i	6fl'0		It•II	0	0	0	0	SLf	989'ft	00t'0		9fIII	
!Yll	1"819,	S6!O-	6900"		I,III										
9"ll	t'819f	S6'SO"	6900"		S-III										
!Yll	8'96U	68!"t	6fl'0		I'III	0	0	0	0	8'Lf	989'.t	00t'0		SfIII	
9!!	t'S19f	S6\$O"	6900"		t-"										
	9't!	t'819.	S6\$O"	6900"	z.mJ										
	9T!	896?E	6811	sere	ttmg	0	0	0	0	SLf	989'z	00t'0		tf11!	
osL'f	o-ss	t6	m-o-	soo-0-	if>ll	roo-0	soo-0	0	0	RSS	no-,	0001!	w*a		
osn	,ro	o-0	000-0	000-0	orma	0	0	0	0	0-06	000-0	00011	,fIII		
	9,s	9.1	roo-0	soo-0	W*II										
	9,s	g4	1,00-0	800-0	I**II	0	0	0	0	L'6S	9,,r,	000.99	lf"II		
	0-0	0-0	000-0	000-0	I,III										
	0-0	0-0	000-0	000-0	ISII	0	0	0	0	0'06	000-0	000.99	o.sna		
	0-0	0-0	00011	000-0	W*II	0	0	0	0	0116	000-0	00011	6tmu		
	SW-0	,ro	0-0	000-0	000-0	L**II	0	0	0	0-06	000-0	000-ir	Si**II		
		,ro	0-0	000-0	000-0	A**II									
		0-0	0-0	000-0	000-0	sima									
		0-0	0-0	000-0	000-0	imu									
		0-0	0-0	000,0	000-0	W*II	0	0	0	0-06	000-0	000.99	W*II		
		0-0	0-0	000-0	000-0	,tsng	0	0	0	0-06	000'0	000-ii	Si**II		
		0-0	0-0	00011	000-0	simu									
		,ro	0-0	00011	000-0	W*II									
		,ro	0-0	000-0	000-0	L**II	0	0	0	0-06	000-0	000.99	simu		
		,ro	0-0	000-0	000-0	risnu	0	0	0	0-0	000-0	000-ii	numu		
		0-0	0-0	000*0	000*0	ttmg									
		0-0	0-0	000-0	000-0	,jIII									
		0-0	0-0	000-0	000-0	lma	0	0	0	0-06	000-0	000.99	usmu		
		if-001	rs	000-0	iQO'O-	sisna:	000-0	,00-0	0	0	!Yll	SS6't	000-ir	0imh	
		0-0	0-0	000-0	000-0	Lrnu	0	0	0	0-06	000-0	ceru	61"!1		
		0'0!	60	000-0	roo'0	ozsng									
		0-001	0-0	000-0	,00-0-	sna:	0	0	0	0	9,z	19,rz	00099	simu	
		0-0	0-0	0000	000-0	5isna:									
		0-0	0-0	000-0	000-0	Hra									
		0-0	0-0	00011	000-0	nsna:									
		0'0-	o-0	00,0	000-0	wnu	0	0	0	0	0-06	000-0	000.99	uma	
srt	o-ss	0-01	00-0	soo-0-	tisnu	roo-0	soo-0	0	0	.ms	,so-t	000-u	n**II		
	~	2!	!2..	~	~	nsnu	0	0	!	0	~~~	~~~	st=a		
	d•	100	duv	~	ar	"~	AU-	~	~	~	~	~			
1W IX			hour: p~		ptto'l		nouvan~			a-h:	2.w"	A1	sng		

T=1000

anJ's 21:LL1V.S1LN1 SIR.mSIS, TINV LJV di- a>lv JIII.SAS Ad'IV10S 3.IVOS 3:EJIIVT V SO NEJS3a

temor: r :lguo:)	SI ase:,pnis	A'0//NOHV.LSILIS NIIOH :ameu•H
*sein noisemle		IV.III-TVVJ;VI Sil\l(t< VS u,amflu3'
910"99"8Z :atea	ao·g·t	iuamuedao: :in ,UISH3'AL<fl .ISV;; t In;J, l n.e.mno;3
71 :!-d	dVLfl	V,II'1 • A.ID NIIOH :nop>OJ
		SISMI li'ls'v'T(t ,.fot

Project: **MASTER THESIS**
 Location: **BONN CITY - LIBYA**
 Contract: **NEAR EAST UNIVERSITY - EEE Department**
 Engineer: **SAMI MUSTAFA AL-REFAI**
 Filename: **BONN SUBSTATION 2MVA**

ETAP
12.6.0H

Study Case: TS

Page: 24
 Date: 28-06-2016
 SN:
 Jw.i iou: Base
 Config: Nomal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS; ITS INTEGRATION INTO LIBYAN POWER GRID

LOAD FLOW REPORT (With PV) @ T = 1.0000

Bus	ID	Voltage			Generation			Load			Load Flow				Xf\IR
		kV	% Mag.	Ang.	MW	Mvar	MW~	ID	MW	hivar	Amp	%PF	%Top		
								Jn.10		-0.069	-0.895	3618.1	11.6		
Bus37		0.400	23.686	37.8	0	0	0	Bu1U	0.139	1.159	1296.8	11.6			
								In.9	-0.069	-0.895	3618.4	11.6			
								InVII	-0.069	-0.895	3618.4	11.6			
								In.91	-0.069	-0.895	3618.4	11.6			
Bus38		0.400	23.363	56.5	0	0	0	Bm:42	0.135	1.176	7313.7	11.4			
								Jn.90	-0.067	-0.888	3618.4	11.4			
								InvS9	-0.067	-0.888	3618.4	11.4			
Bus39		0.400	23.363	56.5	0	0	0	Bm:Z	0.135	1.176	7313.7	11.4			
								InvS7	-0.067	-0.888	3618.4	11.4			
								IovS6	-0.067	-0.888	3618.4	11.4			
Bus40		0.400	23.363	56.5	0	0	0	Bus1L	0.135	1.176	7313.7	11.4			
								IndOl	-0.067	-0.888	3618.4	11.4			
								Invl4	-0.067	-0.888	3618.4	11.4			
Bus41		11.000	13.177	40.0	0	0	0	Ba1U	0.208	2.657	1061.4	7.7	-1.250		
								Bm34	-0.051	-0.664	265.3	7.7			
								BuoIS	-0.01	-0.4	265.1	7.7			
								Bu36	-0.051	0.664	US.1	7.1			
								Bu137	-0.051	0.664	16S.1	7.7			
Bus42		11.000	12.832	58.9	0	0	0	Bu11L	0.140	1.946	797.9	7.1	.1.1-0		
								BuJS	-0.047	-0.649	266.0	7.2			
								Bu39	-0.017	-1.649	26M	7.2			
								Bu140	-0.017	-0.649	266.0	7.2			
U1		220.000	262.107	0.0	14.004	144.797	0	Bu33	14.004	1-14.797	m.1	9.6			
U2		220.000	100.000	0.0	0	0	0	Bu21	0.000	0.000	0.0	0.0			
U3		220.000	146.534	0.0	4.22	47.220	0	Bu15	0.721	47.110	88.0	10.0			
In.1		0.400	160.800	-37.1	4.011	0.595	0	Bu34	4.021	0.595	3618.4	98.9			
In.4		0.400	160.800	-17.1	1.011	asss	0	Bu13f	4.011	0.595	1618.4	98.9			
In.11		0.400	160.800	-37.1	4.021	0.595	0	Bus3S	4.021	0.595	M9S	3648.4	98.9		
In.7		0.400	160.800	-37.1	4.011	-0.595	0	Bu-S	4.021	0.595	M9S	3611.4	98.9		
In10		0.400	160.800	-37.1	4.021	0.595	0	Bu36	4.021	0.595	3618.4	98.9			
In.5		0.100	160.800	-37.1	4.021	0.595	0	Bu36	4.021	0.595	1618.4	98.9			
In.11		0.400	160.800	-11.1	4.021	0.595	0	Bu,n	4.021	0.95	3618.1	98.9			
In.11		0.400	160.800	-37.1	4.021	0.595	0	Bn,37	4.021	0.595	1618.4	98.9			
In.90		0.100	161.026	-18.7	4.037	0.588	0	Bum	4.037	0.588	3656.9	99.0			
In.89		0.400	161.016	-18.7	4.037	0.585	0	Bum	4.037	0.588	3656.9	99.0			
In.117		0.400	161.026	-18.7	4.037	0.588	0	Bu39	4.037	0.588	3656.9	99.0			

Project: IL-STER IJIESIS
 Location: HOUN CITY -LIBYA
 Contract: NEaR EAST UNIVERSITY -EEE Department
 Engineer: SALILO MUSTAFA AL-REFAI
 Filenrune: HOIN SLBSTATION220KV

ETAP

Page: 25
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Nominal

DESIGN OF A LARGE SCALE SOLARPV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYA'S POWER GRID

LOAD FLOW REPORT (WITH PY) @ T = 1.000

Bu, ID	Voltage kV	Generation		Load		Load Flow ID	Xf/MR		
		% Mag.	Ang.	MW	hb/var		MW	Amp.	%PF %TOP
Inv86	MOO	"Tl:öü ""Ts," ~	O:, --"o' ---;	~		4.037	0.588	3656.9	99.0
IndOZ	0.100	161.016	-18.7	J.0J7	0.88	0	0	BuJO	J.037 0.588; 36.6.9 99.0
hwIJ	MOO	161.016	-18.7	J.037	0.888	0	0	BnW0	J.037 0.588; 3656.9 95U

* Indicates a voltage regulated bus (voltage controlled or single type machine connected to it)

indicates a bus with load min:act of more than 10.1MVA

Project: **MASTER THESIS** ETAP Page: 26
Location: **HOUN CITY - LIBYA** 12.li.OH Date: 28-06-2016
Contract: NEA.REASTUNIVERSITY-EEE Department SN:
Engineer: SAND MUSTAFA AL-REF AI R.-i.on: Base
Filename: HOUN SUBSTATION 220kV StudyCase: TS Config: Nonna!

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Demandability

The tabulated plot data is not printed since the Plot of "Transient Tabulated Plots" is selected.
To print tabulated plot data go to the Transient Stability Study Case Editor and in the Info Page uncheck the "Skip Tabulated Plots" option.

Project: MASTER THESIS
 Location: HOUN CITY- LIBYA
 Contract: NEAR-EAST UNIVERSITY- EEE Department
 Engineer: SAJ\I~IDSTAFA AL-REFAI
 Filename: HOUN sti'BSTATION220kV

ETAP
 12.6.0H
 Study Case: TS

Page: 27
 Date: 28-06-2016
 SN:
 Revision: Base
 Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM WITH IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWERGRID

System Islandin & Inde:

Thne(S*)	Element ID	Typ<	ZontNo.
0.000	Bus1	Bus	2
0.000	Bus0	Bus	2
0.000	Bus1%	Bus	1
0.000	Bus13	Bus	2
0.000	Bu,U	Bus	1
0.000	Bu,15	Bus	2
0.000	Bu,16	Bus	1
0.000	Bus7	Bus	2
0.000	Bu,18	Bus	1
0.000	Bud9	Bus	2
0.000	BusZ	Bus	1
0.000	Bu,20	Bus	1
0.000	Bus:1	Bus	2
0.000	Bus22	Bus	2
0.000	Bus:11	Bus	2
0.000	Bu,25	Bus	2
0.000	Bus%7	Bus	2
0.000	Bin28	Bus	2
0.000	Bu,29	Bus	2
0.000	Bu,3	Bus	2
0.000	Bus30	Bus	2
0.000	Bus:31	Bw;	1
0.000	Bus32	Bus	2
0.000	Bus33	Bus	1
0.000	Ilu,3,I	Bus	2
0.000	Bus35	Bus	2
0.000	Bus:36	BII,	2
0.000	Bus:7	Bus	2
0.000	Bu,38	Bus	1
0.000	Bus:39	Bns	1
0.000	Bu,1	bus	3
0.000	Bu>IO	Bus	1
0.000	Bu,U	Bus	2
0.000	Bus:42	BIII	1
0.000	Bm5	Bu,	1

Project: ?USL:ER THESLS

ETAP

Pag• 1S

Location: HOUN CITY-LIBYA

12.6.0H

Date: 28-06-2016

Contact: NEAR EAST UNIVERSITY - EEE Department

18

Engineer: SANDIPSTAFA AL-REEAI

Study Case: TS

Revision: Base

Filename: HOUN SUBSTATION 220KV

Config: Normal

DESIGN OF A LARGE SCALE SOLAR PV SYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

System Isfanding Inlæsning

Time (Ste.)	EltmeutID	Typ	Zour-No.
0.000	Bu,6	Bu,s	2
0.000	Bu-7	Bu,	1
0.000	Bin8	Bu,	2
0.000	Bu'9	Bu,	1
0.000	Ial'lO	PowtrGrid	2
0.000	hl'\102	PomrGrid	1
0.000	Iav1l	P-0mrGrid	2
MOO	Ind4	PonuGrid	1
0.000	Ind	PomrGrid	2
0.000	In,4	PomrGrid	2
0.000	In'\1	PomrGrid	2
0.000	Ia,S	PewtrGrid	2
0.000	Im-86	Pom,rGrid	1
0.000	Ii,-87	PomrGrid	1
0.000	Jn,-89	Pomi-Grid	1
0.000	J,-11	PomrGrid	2
0.000	Ia-O	PO\ tJ"Grid	1
0.000	In,-III	PomrGrid	2
0.000	Ul	Pomr Grid (Rot)	2
0.000	Ul	Pomr Grid (RöE)	3
0.000	U3	Pomr Grid (Röi)	1

Project: MASTER THESIS
Location: HOUN (11Y-LIBYA
Conraacn: i:\EAREASTUNIVERSITY-EEE Department
Enginor: SA. HINDSTAFA AL-REFAI
Filename: HOUN SUBSTATIONZIOkV

ETAP
12.6.0H

Study Case: TS

Page: 29
Date: 28-06-2016
SN:
Re,ision: Base
Config: Normal

DESIGN OF A LARGE SCALE SOLAR.PYSYSTEM AND IMPACT ANALYSIS OF ITS INTEGRATION INTO LIBYAN POWER GRID

Action Summary

EwnID	Time(Se<)	Device Type	Dedc.ID	Action
tPDU	0.500	Bus	Bus	J PluseFout
tventl	0.800	Bus	Bu~	3 PluseFout